

CAMPANIA KINKORA, Australia

WMO: 959720

Lat: 42.6867S

Lon: 147.4258E

Elev: 148

StdP: 14.62

Time Zone: 10.00 (AUS)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	32.0	33.8	29.1	23.2	39.1	30.4	24.7	40.0	31.3	52.9	26.6	55.4	6.6	0	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	85.7	64.3	81.2	63.0	77.3	61.8	67.0	79.6	65.3	76.7	63.6	74.0	16.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.2	87.2	69.5	61.2	81.1	68.9	59.2	75.6	67.8	31.5	79.6	30.2	77.1	29.0	74.0	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	22.9	20.1	DB	28.7	95.8	1.2	5.5	27.8	99.8	27.1	103.0	26.5	106.1	25.6	110.1	(4)
(5)			WB	28.1	71.0	1.2	2.0	27.2	72.4	26.5	73.6	25.9	74.8	25.0	76.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.8	63.6	62.6	60.5	55.3	51.3	47.6	46.9	48.0	50.7	53.5	57.5	60.6
	DBStd	7.71	5.81	5.56	5.64	5.13	4.82	4.27	3.87	4.41	4.60	5.48	5.62	5.42
	HDD50	430	0	0	1	9	43	97	114	94	45	23	4	0
	HDD65	3879	96	103	164	293	426	522	562	528	429	360	237	159
	CDD50	2178	421	353	326	170	82	25	17	31	66	131	227	329
	CDD65	154	52	36	24	4	0	0	0	0	0	3	11	24
	CDH74	1679	581	357	236	29	0	0	0	0	1	52	156	267
	CDH80	516	207	108	70	3	0	0	0	0	0	12	44	72
Wind	WSAvg	9.6	10.4	9.4	9.1	8.7	9.6	8.5	8.8	9.6	10.4	10.4	9.8	10.4
Precipitation	PrecAvg	21.0	1.9	1.5	1.4	1.6	1.3	1.7	1.8	2.1	2.0	1.8	1.9	2.1
	PrecMax	30.0	3.7	4.2	3.5	5.0	4.3	5.4	3.9	4.3	5.0	3.6	4.2	6.8
	PrecMin	12.7	0.3	0.2	0.3	0.4	0.0	0.3	0.4	0.2	0.7	0.4	0.1	0.0
	PrecStd	3.9	1.1	0.9	0.8	1.1	0.9	1.3	0.9	1.1	1.0	0.7	1.1	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.3	89.7	87.5	77.4	69.3	62.4	61.2	65.1	70.8	80.7	85.9	87.1
		MCWB	67.7	66.6	65.5	60.6	56.8	54.1	51.9	53.7	56.0	58.7	62.9	63.3
	2%	DB	85.4	83.1	79.9	72.8	65.2	60.1	58.5	61.5	65.8	72.6	78.4	80.8
		MCWB	64.5	64.9	63.0	59.0	55.0	52.4	50.3	51.6	53.9	57.1	62.0	62.9
	5%	DB	79.9	78.0	75.2	68.8	62.8	58.0	56.5	59.0	62.8	68.3	72.9	76.0
		MCWB	62.9	62.7	61.1	57.4	53.8	50.8	49.2	50.2	52.5	56.1	59.4	61.0
	10%	DB	75.7	74.2	71.4	65.7	60.4	56.1	54.7	56.8	60.2	64.6	68.7	72.1
		MCWB	61.0	61.3	59.8	55.8	52.5	49.5	48.3	49.3	51.2	54.0	57.4	59.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.8	69.2	67.9	63.1	58.5	56.7	53.5	54.9	57.8	62.3	66.3	67.5
		MCDB	84.5	81.8	79.2	73.2	65.2	60.5	57.8	61.5	67.7	70.5	77.8	80.9
	2%	WB	66.6	66.7	65.2	60.5	56.4	53.1	51.2	52.8	55.3	59.4	63.2	64.9
		MCDB	80.3	79.1	75.3	69.2	63.4	58.4	56.8	59.6	63.0	69.5	74.7	75.7
	5%	WB	64.6	64.6	63.2	58.5	54.7	51.5	49.8	51.0	53.5	57.0	60.8	62.8
		MCDB	76.5	74.9	72.6	66.6	61.3	56.7	55.5	57.8	60.9	66.5	71.1	73.1
	10%	WB	62.6	62.6	61.3	56.8	53.0	50.1	48.7	49.6	51.9	54.8	58.5	60.7
		MCDB	73.4	71.8	69.9	64.3	59.4	55.5	54.0	56.1	59.4	63.4	67.0	70.6
Mean Daily Temperature Range	5% DB	MDBR	21.0	20.1	19.2	18.5	15.6	15.0	14.8	15.8	17.2	18.8	18.9	19.6
		MCDBR	30.0	27.8	25.8	23.7	18.5	16.4	16.5	18.6	20.9	25.8	27.2	27.3
		MCWBR	13.0	12.3	11.7	12.1	10.8	10.5	10.7	11.0	12.1	13.3	13.3	12.5
	5% WB	MCDBR	25.5	23.8	22.8	21.6	17.0	15.6	15.0	17.4	19.1	23.6	25.1	24.1
		MCWBR	12.4	12.2	11.1	11.8	10.8	10.8	10.3	10.8	12.0	13.2	13.7	12.2
Clear-Sky Solar Irradiance	taub	0.346	0.333	0.332	0.312	0.303	0.291	0.292	0.305	0.326	0.331	0.335	0.339	
	taud	2.492	2.552	2.544	2.583	2.582	2.601	2.600	2.569	2.493	2.495	2.507	2.504	
	Ebn at Noon	311	306	292	276	255	248	257	274	289	304	312	315	
	Edh at Noon	36	32	29	24	20	18	19	24	30	33	35	36	
All-Sky Solar Radiation	RadAvg	2100	1788	1346	915	568	449	518	770	1158	1596	1885	2102	
	RadStd	165	88	72	54	33	35	22	49	58	91	147	123	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	DBAvg	+0.97	N/A	N/A	N/A	N/A	N/A	-286	+270	+61
(47) Regional (31 neighbors)	DBAvg	+0.58	N/A	N/A	+1.19	N/A	N/A	-171	+185	+22

Nomenclature: See separate page