

CAMPANIA KINKORA, Australia

WMO: 959720

Lat: 42.6867S

Lon: 147.4258E

Elev: 45

StdP: 100.79

Time Zone: 10.00 (AUS)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.0	1.0	-1.6	3.3	4.0	-0.9	3.5	4.4	14.0	11.6	11.9	13.0	2.9	0	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.7	29.9	17.9	27.3	17.2	25.2	16.5	19.4	26.4	18.5	24.8	17.6	23.3	7.2	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.3	12.5	20.8	16.2	11.6	20.5	15.1	10.8	19.9	55.4	26.4	52.4	25.0	49.5	23.3	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.1	10.2	9.0	-1.9	35.4	0.7	3.1	-2.3	37.7	-2.7	39.5	-3.1	41.2	-3.6	43.4
			-2.2	21.7	0.7	1.1	-2.6	22.5	-3.0	23.1	-3.4	23.8	-3.9	24.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	17.5	17.0	15.8	13.0	10.7	8.7	8.3	8.9	10.4	11.9	14.1	15.9
	DBStd	4.28	3.23	3.09	3.13	2.85	2.68	2.37	2.15	2.45	2.55	3.05	3.12	3.01
	HDD10.0	239	0	0	1	5	24	54	63	52	25	13	2	0
	HDD18.3	2155	53	57	91	163	237	290	312	293	238	200	132	88
	CDD10.0	1210	234	196	181	94	46	14	9	17	37	73	126	183
	CDD18.3	86	29	20	13	2	0	0	0	0	0	2	6	13
	CDH23.3	933	323	198	131	16	0	0	0	0	1	29	87	148
	CDH26.7	287	115	60	39	2	0	0	0	0	0	7	24	40
Wind	WSAvg	4.3	4.7	4.2	4.1	3.9	4.3	3.8	4.0	4.3	4.7	4.7	4.4	4.6
Precipitation	PrecAvg	533	47	39	36	40	33	44	46	53	50	45	49	53
	PrecMax	762	93	107	88	128	109	136	98	110	128	92	106	173
	PrecMin	323	8	6	7	9	1	7	9	6	17	9	3	0
	PrecStd	99	28	24	21	27	23	32	23	28	25	17	27	37
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	32.1	30.8	25.2	20.7	16.9	16.2	18.4	21.6	27.1	29.9	30.6
		MCWB	19.9	19.2	18.6	15.9	13.8	12.3	11.0	12.0	13.3	14.8	17.1	17.4
	2%	DB	29.7	28.4	26.6	22.7	18.4	15.6	14.7	16.4	18.8	22.5	25.8	27.1
		MCWB	18.1	18.3	17.2	15.0	12.8	11.3	10.2	10.9	12.2	13.9	16.7	17.1
	5%	DB	26.6	25.5	24.0	20.5	17.1	14.5	13.6	15.0	17.1	20.2	22.7	24.4
		MCWB	17.1	17.1	16.2	14.1	12.1	10.4	9.6	10.1	11.4	13.4	15.2	16.1
	10%	DB	24.3	23.4	21.9	18.7	15.8	13.4	12.6	13.8	15.7	18.1	20.4	22.3
		MCWB	16.1	16.3	15.5	13.2	11.4	9.7	9.1	9.6	10.7	12.2	14.1	15.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	20.6	19.9	17.3	14.7	13.7	12.0	12.7	14.3	16.8	19.0	19.7
		MCDB	29.2	27.7	26.2	22.9	18.4	15.8	14.3	16.4	19.8	21.4	25.4	27.2
	2%	WB	19.2	19.3	18.4	15.8	13.6	11.7	10.6	11.6	12.9	15.2	17.3	18.3
		MCDB	26.9	26.2	24.0	20.7	17.4	14.7	13.8	15.3	17.2	20.8	23.7	24.3
	5%	WB	18.1	18.1	17.3	14.7	12.6	10.8	9.9	10.6	12.0	13.9	16.0	17.1
		MCDB	24.7	23.9	22.5	19.2	16.3	13.7	13.0	14.3	16.1	19.1	21.7	22.8
	10%	WB	17.0	17.0	16.3	13.8	11.7	10.0	9.3	9.8	11.0	12.7	14.7	15.9
		MCDB	23.0	22.1	21.0	17.9	15.2	13.1	12.2	13.4	15.2	17.4	19.4	21.5
Mean Daily Temperature Range	5% DB	MDBR	11.7	11.1	10.7	10.3	8.7	8.3	8.2	8.8	9.6	10.5	10.5	10.9
		MCDBR	16.7	15.4	14.4	13.2	10.3	9.1	9.1	10.3	11.6	14.3	15.1	15.2
		MCWBR	7.2	6.8	6.5	6.7	6.0	5.9	5.9	6.1	6.7	7.4	7.4	6.9
	5% WB	MCDBR	14.2	13.2	12.6	12.0	9.4	8.7	8.3	9.7	10.6	13.1	13.9	13.4
		MCWBR	6.9	6.8	6.2	6.6	6.0	6.0	5.7	6.0	6.7	7.4	7.6	6.8
Clear-Sky Solar Irradiance	taub	0.346	0.333	0.332	0.312	0.303	0.291	0.292	0.305	0.326	0.331	0.335	0.339	
	taud	2.492	2.552	2.544	2.583	2.582	2.601	2.600	2.569	2.493	2.495	2.507	2.504	
	Ebn at Noon	979	966	919	870	805	783	811	865	910	957	985	992	
	Edh at Noon	112	100	92	75	63	56	61	75	94	105	109	112	
All-Sky Solar Radiation	RadAvg	6.62	5.64	4.24	2.88	1.79	1.42	1.63	2.43	3.65	5.03	5.94	6.62	
	RadStd	0.52	0.28	0.23	0.17	0.10	0.11	0.07	0.16	0.18	0.29	0.46	0.39	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-159	+150	+34
(47) Regional (31 neighbors)		+0.32	N/A	N/A	+0.66	N/A	N/A	N/A	-95	+103	+12

Nomenclature: See separate page