

MARIA ISLAND, Australia

WMO: 959880

Lat: 42.6622S

Lon: 148.0178E

Elev: 28

StdP: 100.99

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.3	5.9	-0.5	3.6	7.9	0.3	3.9	8.1	18.8	10.9	17.0	12.1	6.2	290	0.715

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.5	24.4	17.6	22.6	16.9	21.4	16.4	19.0	22.4	18.2	21.1	17.6	20.3	8.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	12.9	19.9	17.2	12.3	19.6	16.3	11.6	19.1	54.3	22.4	51.8	21.1	49.7	20.4	22.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.5	13.1	DB	4.0	29.6	0.6	2.2	3.5	31.2	3.2	32.5	2.8	33.7	2.4	35.3	(4)
(5)			WB	2.1	20.3	0.8	0.8	1.5	20.8	1.1	21.3	0.7	21.7	0.1	22.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	17.2	16.9	16.3	14.4	12.3	10.6	10.0	10.2	11.4	12.6	14.0	15.6	(6)	
	DBStd	3.31	2.43	2.27	2.40	2.24	2.05	1.72	1.64	1.90	1.95	2.22	2.37	2.27	(7)	
	HDD10.0	69	0	0	0	1	4	13	20	21	8	3	1	0	(8)	
	HDD18.3	1834	52	51	72	120	188	233	257	252	208	178	133	91	(9)	
	CDD10.0	1319	222	194	196	132	74	30	21	27	49	83	119	172	(10)	
	CDD18.3	43	16	11	9	1	0	0	0	0	0	1	2	4	(11)	
	CDH23.3	111	54	26	12	1	0	0	0	0	0	3	7	9	(12)	
(13)	CDH26.7	18	12	4	1	0	0	0	0	0	0	1	1	1	(13)	
(14)	Wind	WSAvg	6.5	6.6	6.4	6.2	6.1	6.6	6.0	6.5	6.9	6.8	6.8	6.7	6.6	(14)
(15) Precipitation	PrecAvg	533	57	39	40	45	30	48	42	45	46	39	58	53	(15)	
	PrecMax	850	239	115	136	121	164	207	96	96	148	95	192	218	(16)	
	PrecMin	341	3	7	4	2	0	8	0	7	12	11	3	0	(17)	
	PrecStd	134	54	27	32	30	32	44	25	25	34	21	44	51	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	26.1	24.8	22.1	18.5	16.3	15.3	16.3	18.5	21.9	24.1	24.6	(19)	
		MCWB	18.3	18.3	18.0	16.2	13.5	11.9	11.4	11.3	12.8	14.3	16.4	16.8	(20)	
	2%	DB	24.5	23.4	22.6	20.2	17.3	15.0	14.2	15.2	16.9	19.2	20.9	22.2	(21)	
		MCWB	17.5	18.2	17.2	15.4	13.0	11.7	10.7	11.1	12.0	13.2	15.4	16.0	(22)	
	5%	DB	22.3	21.8	21.1	18.9	16.4	14.2	13.4	14.2	15.7	17.6	19.2	20.7	(23)	
		MCWB	16.9	17.0	16.7	14.6	12.7	11.3	10.3	10.7	11.3	13.0	14.2	15.6	(24)	
	10%	DB	21.0	20.5	20.0	17.8	15.6	13.4	12.8	13.3	14.6	16.3	17.7	19.3	(25)	
		MCWB	16.3	16.6	16.1	14.2	12.3	10.7	9.9	10.3	10.9	12.3	13.7	15.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	19.9	19.5	17.4	14.7	13.6	12.6	12.6	13.9	15.7	17.5	18.4	(27)	
		MCDB	24.2	23.0	22.1	20.0	16.6	14.4	14.3	14.4	16.7	18.2	21.3	22.1	(28)	
	2%	WB	18.7	19.1	18.4	16.4	14.0	12.3	11.5	11.9	12.9	14.7	16.3	17.4	(29)	
		MCDB	22.6	22.3	20.9	18.7	16.1	13.8	13.3	14.0	15.3	17.7	19.5	20.2	(30)	
	5%	WB	18.0	18.3	17.7	15.6	13.4	11.7	10.8	11.2	12.1	13.8	15.4	16.6	(31)	
		MCDB	21.1	20.8	20.3	17.9	15.7	13.5	12.8	13.7	14.8	16.8	18.1	19.4	(32)	
	10%	WB	17.1	17.4	16.7	14.7	12.8	11.0	10.2	10.6	11.4	12.9	14.5	15.7	(33)	
		MCDB	20.2	19.9	19.6	17.3	15.3	13.0	12.3	13.1	14.1	15.8	17.0	18.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.0	5.8	5.4	4.6	4.1	4.2	4.8	5.6	6.1	5.9	6.1	(35)	
		MCDBR	9.0	7.5	7.4	6.5	5.4	4.7	4.8	5.7	6.8	7.8	8.1	8.0	(36)	
		MCWBR	4.9	4.3	4.2	3.8	3.7	3.2	3.4	3.7	4.2	4.6	4.4	4.8	(37)	
	5% WB	MCDBR	8.1	6.7	6.5	5.8	4.6	4.0	4.3	5.0	6.1	7.0	7.0	7.0	(38)	
		MCWBR	4.7	4.4	4.0	3.9	3.5	3.1	3.3	3.6	4.2	4.7	4.2	4.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.351	0.340	0.335	0.320	0.305	0.297	0.293	0.309	0.331	0.338	0.342	0.341	(40)	
	taud		2.519	2.568	2.576	2.592	2.606	2.608	2.623	2.585	2.512	2.510	2.521	2.540	(41)	
	Ebn at Noon		975	959	918	862	805	777	811	861	905	950	977	991	(42)	
	Edh at Noon		109	98	89	75	62	56	60	74	93	103	108	108	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.58	5.58	4.25	2.90	1.83	1.45	1.68	2.48	3.76	5.11	5.92	6.70	(44)	
	RadStd		0.48	0.24	0.21	0.19	0.11	0.11	0.08	0.15	0.21	0.27	0.46	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.32	N/A	N/A	+0.75	N/A	N/A	N/A	-111	+115	+19

Nomenclature: See separate page