

SABANG, Indonesia

WMO: 960010

Lat: 5.8740N

Lon: 95.3400E

Elev: 371

StdP: 14.50

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	73.3	74.1	67.3	101.8	82.7	68.6	106.5	81.9	23.0	79.9	21.6	79.3	6.0	210	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	9.6	91.0	79.6	90.0	79.7	89.3	79.7	83.6	88.3	82.7	87.7	81.8	87.0	8.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.3	170.5	87.7	81.3	165.0	86.9	80.3	159.3	86.1	48.0	88.4	47.0	87.7	45.9	87.1	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.5	20.5	18.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.6	80.1	80.7	82.0	82.7	83.1	83.2	82.6	82.0	81.7	80.6	80.3	79.6
	DBStd	2.20	1.67	1.61	1.32	1.62	1.94	2.29	2.13	2.17	2.05	1.77	1.51	1.79
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11520	933	861	993	981	1025	996	1011	993	952	949	908	918
	CDD65	6045	468	441	528	531	560	546	546	528	502	484	458	453
	CDH74	61756	4288	4257	5690	5849	6323	6275	6019	5532	5094	4440	4099	3890
	CDH80	18058	855	996	1835	2037	2217	2282	2007	1699	1468	1063	896	703
Wind	WSAvg	6.8	7.4	7.6	3.9	3.8	6.4	9.5	10.2	9.8	7.7	4.7	4.2	6.2
Precipitation	PrecAvg	82.4	10.0	4.7	5.1	3.7	5.4	4.8	4.5	5.6	5.2	8.2	11.8	13.5
	PrecMax	113.6	30.1	10.4	14.3	10.3	12.2	11.3	21.8	12.9	11.1	18.9	25.7	24.8
	PrecMin	59.5	3.6	0.4	0.0	1.2	0.9	0.5	0.6	0.6	1.3	2.6	5.4	4.3
	PrecStd	12.7	5.2	3.1	3.1	2.0	2.9	3.0	4.0	3.7	2.4	4.1	4.4	5.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.3	88.2	89.9	91.1	91.7	92.5	91.5	91.5	90.6	89.8	88.4	87.3
		MCWB	79.0	78.9	81.7	81.1	80.9	78.5	77.9	77.6	78.9	79.2	80.0	79.3
	2%	DB	86.2	86.8	88.8	90.0	90.5	90.7	89.9	89.7	88.9	87.7	87.0	86.0
		MCWB	79.2	78.7	81.1	81.1	81.0	78.9	77.9	78.6	78.8	79.5	79.5	79.0
	5%	DB	85.3	85.9	87.9	89.0	89.4	89.5	88.8	88.3	87.9	86.4	85.9	84.9
		MCWB	78.9	78.6	80.5	80.8	80.6	79.0	77.7	78.5	78.3	79.2	79.1	78.4
	10%	DB	84.2	85.0	86.9	87.8	88.2	88.2	87.7	87.1	86.6	85.2	84.7	83.8
		MCWB	78.4	78.3	80.1	80.3	80.4	78.5	77.5	78.1	77.9	78.6	78.7	77.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.8	80.9	84.2	85.2	84.4	83.2	81.6	82.8	83.2	82.8	82.7	81.1
		MCDB	85.6	85.6	87.9	89.4	89.5	89.1	87.7	88.6	88.5	86.7	86.6	85.5
	2%	WB	80.3	80.1	83.1	83.5	83.2	81.6	80.2	80.9	81.1	81.1	80.8	80.0
		MCDB	84.6	85.0	87.4	88.0	88.6	88.1	87.1	87.2	86.8	85.8	85.3	84.5
	5%	WB	79.4	79.3	81.9	82.1	81.9	80.3	79.1	79.6	79.8	79.7	79.7	79.1
		MCDB	83.8	84.4	86.7	87.0	87.6	87.0	86.4	86.2	85.6	84.8	84.4	83.6
	10%	WB	78.7	78.7	80.6	80.9	80.9	79.2	78.2	78.4	78.8	78.8	78.9	78.2
		MCDB	83.1	83.7	85.7	86.3	86.8	85.7	85.3	84.9	84.5	84.1	83.7	82.4
Mean Daily Temperature Range	5% DB	MDBR	8.1	8.6	10.3	10.6	9.9	9.6	9.6	9.9	9.6	9.1	8.8	7.9
		MCDBR	9.3	9.7	11.5	11.8	11.3	11.1	11.1	11.5	11.0	10.8	10.5	9.7
		MCWBR	5.0	4.9	5.9	5.7	5.3	4.9	4.6	5.2	4.7	5.3	5.2	4.9
	5% WB	MCDBR	9.0	9.1	11.7	11.1	10.8	10.7	10.6	11.0	10.7	10.3	9.8	9.0
		MCWBR	5.3	5.0	7.3	6.9	6.4	5.8	5.3	5.8	5.8	5.8	5.6	5.0
Clear-Sky Solar Irradiance	taub	0.453	0.468	0.468	0.442	0.429	0.430	0.430	0.420	0.411	0.424	0.425	0.450	
	taud	2.367	2.289	2.322	2.406	2.478	2.484	2.470	2.488	2.502	2.476	2.467	2.386	
	Ebn at Noon	275	273	273	276	273	269	271	278	285	283	282	273	
	Edh at Noon	40	44	43	39	35	34	35	35	35	36	36	38	
All-Sky Solar Radiation	RadAvg	1532	1762	1780	1731	1621	1614	1590	1625	1597	1499	1370	1356	
	RadStd	107	108	125	104	100	109	80	81	64	110	85	99	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page