

SABANG, Indonesia

WMO: 960010

Lat: 5.8740N

Lon: 95.3400E

Elev: 113

StdP: 99.97

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.0	23.4	19.6	14.5	28.1	20.3	15.2	27.7	10.3	26.6	9.6	26.3	2.7	210	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.3	32.8	26.4	32.2	26.5	31.8	26.5	28.7	31.3	28.2	30.9	27.7	30.6	3.9	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.4	30.9	27.4	23.6	30.5	26.8	22.8	30.0	93.8	31.4	91.4	30.9	88.9	30.6	30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.2	8.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	26.7	27.1	27.8	28.2	28.4	28.4	28.1	27.8	27.6	27.0	26.8	26.5
	DBStd	1.22	0.93	0.89	0.73	0.90	1.08	1.27	1.19	1.21	1.14	0.98	0.84	0.99
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6400	518	478	552	545	569	553	562	552	529	527	504	510
	CDD18.3	3358	260	245	293	295	311	303	303	293	279	269	254	252
	CDH23.3	34309	2382	2365	3161	3249	3513	3486	3344	3073	2830	2467	2277	2161
	CDH26.7	10032	475	553	1019	1132	1232	1268	1115	944	816	591	498	391
Wind	WSAvg	3.0	3.3	3.4	1.8	1.7	2.9	4.3	4.6	4.4	3.4	2.1	1.9	2.8
Precipitation	PrecAvg	2093	254	119	130	93	137	121	115	141	132	209	299	342
	PrecMax	2886	765	265	362	262	311	287	554	327	283	479	654	631
	PrecMin	1511	91	11	1	30	22	12	16	16	34	65	136	109
	PrecStd	323	132	78	80	50	73	77	101	94	61	105	113	135
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	31.2	32.2	32.8	33.2	33.6	33.1	33.1	32.6	32.1	31.4	30.7
		MCWB	26.1	26.0	27.6	27.3	27.2	25.8	25.5	25.4	26.1	26.2	26.7	26.3
	2%	DB	30.1	30.5	31.6	32.2	32.5	32.6	32.2	32.0	31.6	31.0	30.5	30.0
		MCWB	26.2	26.0	27.3	27.3	27.2	26.0	25.5	25.9	26.0	26.4	26.4	26.1
	5%	DB	29.6	30.0	31.1	31.6	31.9	31.9	31.5	31.3	31.0	30.2	29.9	29.4
		MCWB	26.0	25.9	27.0	27.1	27.0	26.1	25.4	25.9	25.7	26.2	26.2	25.8
	10%	DB	29.0	29.4	30.5	31.0	31.2	31.2	30.9	30.6	30.4	29.6	29.3	28.8
		MCWB	25.8	25.7	26.7	26.9	26.9	25.8	25.3	25.6	25.5	25.9	25.9	25.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.2	29.0	29.6	29.1	28.4	27.5	28.2	28.4	28.2	28.2	27.3
		MCDB	29.8	29.8	31.1	31.9	32.0	31.7	30.9	31.4	31.4	30.4	30.3	29.7
	2%	WB	26.8	26.7	28.4	28.6	28.4	27.5	26.8	27.2	27.3	27.3	27.1	26.6
		MCDB	29.2	29.5	30.8	31.1	31.4	31.2	30.6	30.7	30.4	29.9	29.6	29.2
	5%	WB	26.3	26.3	27.7	27.8	27.7	26.8	26.2	26.4	26.6	26.5	26.5	26.1
		MCDB	28.8	29.1	30.4	30.6	30.9	30.6	30.2	30.1	29.8	29.3	29.1	28.7
	10%	WB	25.9	25.9	27.0	27.2	27.2	26.2	25.7	25.8	26.0	26.0	26.1	25.7
		MCDB	28.4	28.7	29.8	30.2	30.4	29.8	29.6	29.4	29.2	28.9	28.7	28.0
Mean Daily Temperature Range	5% DB	MDBR	4.5	4.8	5.7	5.9	5.5	5.3	5.3	5.5	5.3	5.0	4.9	4.4
		MCDBR	5.2	5.4	6.4	6.5	6.3	6.2	6.2	6.4	6.1	6.0	5.8	5.4
		MCWBR	2.8	2.7	3.3	3.2	3.0	2.7	2.5	2.9	2.6	3.0	2.9	2.7
	5% WB	MCDBR	5.0	5.1	6.5	6.2	6.0	6.0	5.9	6.1	5.9	5.7	5.5	5.0
		MCWBR	2.9	2.8	4.1	3.8	3.5	3.2	2.9	3.2	3.2	3.2	3.1	2.8
Clear-Sky Solar Irradiance	taub	0.453	0.468	0.468	0.442	0.429	0.430	0.430	0.420	0.411	0.424	0.425	0.450	
	taud	2.367	2.289	2.322	2.406	2.478	2.484	2.470	2.488	2.502	2.476	2.467	2.386	
	Ebn at Noon	867	862	862	869	861	849	853	877	898	891	888	862	
	Edh at Noon	125	139	135	122	110	108	110	111	111	113	113	121	
All-Sky Solar Radiation	RadAvg	4.83	5.56	5.61	5.46	5.11	5.09	5.01	5.12	5.03	4.73	4.32	4.28	
	RadStd	0.34	0.34	0.39	0.33	0.31	0.34	0.25	0.25	0.20	0.35	0.27	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page