

BANDA ACEH BLANG BINTANG, IndonesiaWMO: **960110**Lat: **5.5225N**Lon: **95.4169E**Elev: **21**StdP: **101.07**Time Zone: **7.00 (E07)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.8	22.4	18.2	13.2	31.5	19.0	13.8	30.8	9.2	28.7	7.5	29.2	1.5	150	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.5	34.6	24.5	34.0	24.7	33.4	24.9	27.3	31.1	26.8	31.0	26.5	30.7	4.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.2	25.7	21.0	28.9	25.3	20.5	28.6	86.9	31.3	84.4	31.2	82.8	30.9	33.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.2	5.3	20.1	36.2	1.9	1.2	18.7	37.1	17.6	37.8	16.5	38.4	15.1	39.3		
(5)			18.5	29.1	1.6	1.6	17.3	30.2	16.3	31.1	15.4	32.0	14.2	33.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.8	27.0	27.5	27.9	28.4	28.6	28.3	28.1	27.9	27.3	27.1	26.8		
	DBStd	1.14	0.88	0.80	0.82	0.92	0.86	1.04	1.18	1.08	1.06	0.95	0.87	0.91		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6438	521	477	543	538	569	557	568	562	536	536	512	519		
	CDD18.3	3396	262	243	284	288	311	307	310	303	286	277	262	261		
	CDH23.3	34291	2352	2303	2853	2981	3392	3528	3479	3275	2922	2580	2335	2291		
(13)	CDH26.7	12898	711	780	1050	1146	1364	1558	1539	1386	1163	882	683	637		
(14) Wind	WSAvg	2.0	2.3	2.3	2.1	1.7	1.8	2.1	2.1	2.1	1.9	1.8	1.9	2.2		
(15) Precipitation	PrecAvg	1484	136	99	107	128	143	57	68	69	132	173	168	223		
	PrecMax	1912	508	350	236	234	512	135	284	188	304	453	338	526		
	PrecMin	1018	17	0	30	43	14	5	0	5	25	38	13	51		
	PrecStd	188	93	76	50	58	108	37	64	51	69	91	72	116		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.6	33.1	33.8	34.6	35.1	35.2	35.2	34.7	33.7	32.6	32.0		
		MCWB	25.3	25.4	25.9	26.4	25.4	24.5	24.3	24.3	24.3	24.5	25.1	25.5		
	2%	DB	31.4	31.9	32.5	33.1	33.6	34.2	34.4	34.1	33.6	32.6	31.6	31.2		
		MCWB	25.2	25.3	25.9	26.3	25.6	24.6	24.4	24.4	24.4	24.6	25.3	25.3		
	5%	DB	30.7	31.2	31.9	32.4	32.9	33.5	33.6	33.2	32.8	31.7	30.9	30.6		
		MCWB	25.1	25.3	25.8	26.1	25.7	24.8	24.5	24.5	24.6	24.8	25.3	25.2		
	10%	DB	30.1	30.6	31.2	31.6	32.1	32.7	32.7	32.3	31.9	30.7	30.1	29.9		
		MCWB	24.9	25.2	25.6	25.9	25.7	24.9	24.5	24.5	24.6	24.9	25.2	25.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.8	27.9	29.3	29.1	27.5	26.8	26.4	26.7	26.6	26.6	26.6		
		MCDB	30.3	30.6	30.4	30.6	30.4	31.8	31.6	31.4	31.5	30.5	30.3	30.3		
	2%	WB	26.0	26.2	26.8	27.2	27.2	26.5	26.0	25.8	26.1	26.0	26.1	26.1		
		MCDB	29.9	30.2	30.8	31.1	31.1	31.2	31.0	31.1	30.7	29.9	29.8	29.8		
	5%	WB	25.6	25.9	26.3	26.7	26.7	26.0	25.6	25.4	25.6	25.7	25.7	25.7		
		MCDB	29.4	29.8	30.4	30.8	30.8	30.8	30.6	30.6	30.1	29.4	29.3	29.2		
	10%	WB	25.3	25.5	25.9	26.2	26.2	25.6	25.1	25.0	25.2	25.3	25.5	25.3		
		MCDB	28.8	29.3	30.0	30.3	30.3	30.2	30.3	30.1	29.5	28.9	28.8	28.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.1	7.7	7.8	7.9	8.0	8.5	8.8	8.6	8.2	7.3	6.5	6.4		
		MCDBR	7.9	8.5	8.6	8.7	9.0	9.8	10.2	10.0	9.5	8.8	7.7	7.5		
		MCWBR	2.9	3.3	3.4	3.2	2.8	2.9	3.0	2.8	2.9	2.9	2.7	2.8		
	5% WB	MCDBR	7.1	7.5	7.8	7.9	7.8	8.6	8.9	8.7	8.3	7.2	6.9	6.5		
		MCWBR	2.9	3.2	3.5	3.6	3.5	3.2	3.2	3.1	3.1	2.9	2.8	2.8		
(40) Clear-Sky Solar Irradiance	taub	0.464	0.485	0.482	0.454	0.434	0.433	0.433	0.425	0.418	0.433	0.433	0.433	0.457		
	taud	2.322	2.234	2.272	2.360	2.450	2.462	2.448	2.457	2.466	2.431	2.429	2.353			
	Ebn at Noon	857	848	850	859	857	846	850	872	892	883	880	856			
	Edh at Noon	131	146	142	128	113	110	113	114	115	119	117	126			
(44) All-Sky Solar Radiation	RadAvg	4.81	5.44	5.52	5.36	5.06	5.04	4.94	5.08	5.02	4.68	4.32	4.30			
(45)	RadStd	0.30	0.29	0.31	0.28	0.29	0.33	0.21	0.24	0.20	0.34	0.25	0.27			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page