

MEULABOH CUT NYAK DHLEN, Indonesia

WMO: 960150

Lat: 4.0492N

Lon: 96.2481E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	21.9	22.4	20.8	15.4	23.3	21.4	16.0	23.6	8.4	25.8	5.5	28.1	1.3	90	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.7	32.2	27.5	31.7	27.3	31.4	27.2	28.6	31.2	28.2	30.9	28.0	30.7	2.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.7	30.8	27.5	23.3	30.6	27.1	22.9	30.3	92.4	31.4	91.0	31.1	89.7	30.8	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.5	4.6	4.2		20.3	33.4	1.8	0.8	18.9	34.0	17.9	34.4	16.9	34.9	15.6	35.5
				19.0	29.4	1.9	0.7	17.6	29.9	16.5	30.3	15.5	30.7	14.2	31.2
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.9	26.9	26.9	27.3	27.3	27.4	27.2	26.7	26.6	26.7	26.5	26.7	(6)	
(7)		DBStd	0.87	0.71	0.87	0.84	0.80	0.75	0.85	0.88	0.87	0.87	0.78	0.71	0.78	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6172	524	474	536	519	540	516	518	515	501	514	496	518	(10)
(11)		CDD18.3	3130	266	241	278	269	282	266	259	257	251	256	246	260	(11)
(12)		CDH23.3	29966	2596	2374	2836	2680	2936	2726	2497	2368	2303	2214	2091	2345	(12)
(13)	CDH26.7	9896	856	818	1017	913	1034	999	856	767	734	654	562	684	(13)	
(14)	Wind	WSAvg	1.6	1.7	1.7	1.6	1.5	1.6	1.6	1.7	1.6	1.5	1.4	1.5	1.6	(14)
(15)	Precipitation	PrecAvg	3855	274	234	341	391	309	245	248	295	340	393	450	321	(15)
(16)		PrecMax	4940	598	438	679	587	768	492	448	708	691	708	670	732	(16)
(17)		PrecMin	3171	126	99	86	179	106	52	97	128	118	105	229	145	(17)
(18)		PrecStd	475	121	91	156	102	160	98	93	144	149	133	122	123	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.7	32.0	32.5	32.2	32.2	32.6	32.2	32.1	32.1	31.7	31.1	31.4	(19)
(20)			MCWB	27.6	27.7	27.9	27.8	28.0	27.2	27.1	26.9	26.4	27.0	27.1	27.2	(20)
(21)		2%	DB	31.1	31.4	31.7	31.6	31.7	31.9	31.6	31.2	31.2	31.1	30.4	30.7	(21)
(22)			MCWB	27.2	27.3	27.8	27.6	27.6	27.2	26.8	26.8	26.6	26.9	26.8	27.0	(22)
(23)		5%	DB	30.7	31.0	31.2	31.1	31.2	31.3	31.0	30.6	30.7	30.5	30.0	30.3	(23)
(24)			MCWB	26.9	27.1	27.5	27.3	27.4	26.9	26.6	26.6	26.5	26.7	26.6	26.7	(24)
(25)		10%	DB	30.2	30.5	30.7	30.5	30.7	30.8	30.4	30.1	30.1	29.9	29.5	29.8	(25)
(26)			MCWB	26.6	26.8	27.2	27.1	27.1	26.7	26.4	26.4	26.3	26.5	26.4	26.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.6	28.7	28.7	28.7	29.0	28.7	28.2	28.1	28.1	28.0	28.2	(27)	
(28)			MADB	31.0	31.4	31.6	31.2	31.6	31.4	31.1	30.8	30.6	30.6	30.2	30.4	(28)
(29)		2%	WB	28.0	28.1	28.3	28.2	28.4	28.1	27.7	27.7	27.5	27.6	27.5	27.6	(29)
(30)			MADB	30.5	30.8	31.2	30.9	31.0	31.0	30.7	30.4	30.2	30.2	29.8	30.1	(30)
(31)		5%	WB	27.4	27.6	27.9	27.7	27.9	27.6	27.1	27.1	27.0	27.1	27.1	27.2	(31)
(32)			MADB	30.1	30.4	30.8	30.5	30.6	30.6	30.2	29.9	29.9	29.9	29.4	29.7	(32)
(33)		10%	WB	26.9	27.1	27.4	27.3	27.5	27.1	26.6	26.6	26.5	26.7	26.6	26.7	(33)
(34)			MADB	29.6	29.9	30.3	30.1	30.2	30.1	29.7	29.5	29.4	29.4	28.9	29.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	7.0	6.9	6.5	6.7	7.3	7.4	6.9	6.8	6.3	5.9	6.3	(35)
(36)			MADB	7.4	7.7	7.5	7.1	7.3	8.0	8.3	7.8	7.6	7.4	6.6	7.0	(36)
(37)			MCWBR	4.0	4.3	4.2	4.0	4.1	4.4	4.6	4.3	4.0	4.1	3.7	3.9	(37)
(38)		5% WB	MADB	6.9	7.3	7.3	6.8	6.9	7.7	8.0	7.4	7.2	7.0	6.3	6.6	(38)
(39)			MCWBR	4.3	4.5	4.3	4.1	4.2	4.7	4.9	4.6	4.2	4.2	3.9	3.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.428	0.458	0.463	0.434	0.418	0.420	0.418	0.424	0.418	0.431	0.414	0.411	(40)	
(41)		taud	2.429	2.321	2.328	2.423	2.482	2.483	2.484	2.450	2.457	2.422	2.480	2.489	(41)	
(42)		Ebn at Noon	895	874	867	875	869	855	862	872	893	887	902	906	(42)	
(43)		Edh at Noon	119	135	134	120	109	107	108	115	116	120	112	110	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.00	5.39	5.48	5.18	5.17	4.99	4.91	5.01	4.95	4.80	4.53	4.61	(44)	
(45)		RadStd	0.22	0.33	0.26	0.27	0.25	0.33	0.22	0.30	0.26	0.39	0.23	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page