

GUNUNG SITOLI BINAKA, Indonesia

WMO: 960750

Lat: 1.1650N

Lon: 97.7036E

Elev: 7

StdP: 101.24

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 10	(b) 21.9	(c) 22.3	(d) 21.3	(e) 16.0	(f) 23.0	(g) 21.8	(h) 16.4	(i) 23.1	(j) 7.2	(k) 28.6	(l) 5.6	(m) 28.2	(n) 0.4	(o) N/A	(p) 0.264

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.8	32.5	27.5	31.9	27.3	31.5	27.2	28.6	31.2	28.2	30.8	27.9	30.6	3.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	23.9	30.5	27.5	23.4	30.2	27.1	22.9	30.0	92.6	31.3	90.7	31.0	89.3	30.7	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.6	(b) 4.7	(c) 4.2	(e) 20.7	(f) 34.0	(g) 0.7	(h) 0.9	(i) 20.2	(j) 34.7	(k) 19.8	(l) 35.2	(m) 19.4	(n) 35.7	(o) 18.9	(p) 36.4		
(a) 5.6	(b) 4.7	(c) 4.2	(e) 20.2	(f) 29.5	(g) 0.8	(h) 1.2	(i) 19.6	(j) 30.3	(k) 19.1	(l) 31.0	(m) 18.6	(n) 31.6	(o) 18.0	(p) 32.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.8	26.8	27.1	27.3	27.1	27.3	27.2	26.6	26.6	26.6	26.3	26.4	26.5
	DBStd	0.95	0.83	0.98	0.91	0.92	0.86	0.81	0.90	0.91	0.85	0.89	0.89	0.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6138	522	479	536	513	537	514	514	498	506	492	513	513
	CDD18.3	3097	263	246	278	263	278	264	256	256	248	248	242	254
	CDH23.3	27177	2336	2347	2667	2420	2672	2464	2154	2136	2061	1953	1882	2086
	CDH26.7	8271	716	802	883	729	891	847	686	648	583	498	441	549
Wind	WSAvg	1.0	1.0	1.1	1.1	1.0	1.1	1.1	1.1	1.1	1.0	1.0	1.0	1.0
Precipitation	PrecAvg	2970	220	155	222	257	216	184	232	244	264	333	346	297
	PrecMax	3720	516	403	424	533	411	353	389	380	433	568	494	455
	PrecMin	2027	46	1	3	102	69	0	124	146	119	184	129	165
	PrecStd	367	102	85	79	103	91	73	74	58	75	104	95	76
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.2	32.9	32.6	32.6	32.5	32.1	32.1	32.1	31.5	31.7	31.9
		MCWB	27.1	27.1	27.2	28.1	27.9	27.7	27.1	27.3	27.6	27.1	27.0	26.7
	2%	DB	31.5	32.0	31.9	31.7	31.8	31.7	31.3	31.2	31.1	30.7	30.7	30.9
		MCWB	26.9	27.2	27.3	27.6	27.5	27.4	26.8	27.0	27.1	26.8	26.9	26.7
	5%	DB	30.7	31.2	31.3	30.9	31.2	31.3	30.7	30.7	30.4	30.1	29.9	30.2
		MCWB	26.8	26.9	27.1	27.2	27.3	27.2	26.7	26.9	26.8	26.6	26.6	26.6
	10%	DB	30.1	30.5	30.6	30.2	30.6	30.7	30.1	30.0	29.7	29.4	29.2	29.5
		MCWB	26.6	26.7	27.0	26.9	27.1	27.0	26.5	26.6	26.5	26.4	26.3	26.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.3	28.7	28.7	28.9	28.9	28.9	28.2	28.3	28.6	28.2	27.9	28.1
		MCDB	31.1	31.6	31.3	31.6	31.4	31.5	30.8	30.7	31.3	30.4	30.4	30.3
	2%	WB	27.7	28.0	28.1	28.1	28.2	28.2	27.7	27.7	27.8	27.6	27.4	27.4
		MCDB	30.4	31.0	31.0	30.8	30.8	30.8	30.3	30.3	30.4	29.9	29.9	29.7
	5%	WB	27.2	27.5	27.6	27.6	27.8	27.7	27.2	27.2	27.2	27.0	26.9	26.9
		MCDB	29.8	30.4	30.4	30.2	30.4	30.4	29.9	29.9	29.7	29.4	29.3	29.4
	10%	WB	26.7	26.9	27.1	27.0	27.2	27.2	26.6	26.8	26.7	26.5	26.4	26.5
		MCDB	29.3	29.8	29.9	29.6	29.9	30.0	29.4	29.5	29.1	28.8	28.7	28.9
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.0	6.8	6.3	6.8	7.0	7.1	6.7	6.5	6.0	5.7	6.1
		MCDBR	7.7	8.1	7.8	7.4	7.6	7.9	8.2	7.9	7.5	7.2	6.9	7.2
		MCWBR	3.9	4.1	3.9	3.8	4.0	4.3	4.4	4.3	4.1	3.9	3.6	3.7
	5% WB	MCDBR	7.1	7.6	7.2	7.0	7.1	7.5	7.6	7.4	7.0	6.6	6.4	6.6
MCWBR		4.1	4.3	4.2	3.9	4.2	4.4	4.5	4.5	4.3	4.0	3.7	3.8	
Clear-Sky Solar Irradiance	taub	0.420	0.461	0.472	0.416	0.413	0.423	0.419	0.438	0.444	0.480	0.425	0.400	
	taud	2.464	2.325	2.311	2.489	2.507	2.490	2.491	2.421	2.397	2.288	2.453	2.528	
	Ebn at Noon	909	875	859	890	870	849	857	858	870	847	897	923	
	Edh at Noon	116	135	137	112	106	106	107	118	124	138	116	107	
All-Sky Solar Radiation	RadAvg	4.97	5.30	5.22	4.90	5.02	4.79	4.71	4.73	4.62	4.61	4.33	4.60	
	RadStd	0.18	0.38	0.26	0.26	0.30	0.23	0.24	0.24	0.30	0.55	0.29	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page