

TANJUNG PINANG KIJANG, Indonesia

WMO: 960910

Lat: 0.923N

Lon: 104.532E

Elev: 59

StdP: 14.66

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	73.0	73.7	68.6	105.2	80.9	69.7	109.6	81.2	18.0	79.8	14.5	82.9	1.2	300	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.9	90.7	78.7	89.9	78.7	89.3	78.7	81.0	87.1	80.5	86.7	80.1	86.1	10.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.1	83.5	79.0	150.6	83.3	78.5	148.1	82.9	44.7	87.5	44.2	87.1	43.7	86.6	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.5	14.9	13.3	DB	69.7	92.4	3.9	0.5	66.9	92.7	64.7	93.1	62.5	93.4	59.6	93.8	(4)
			WB	69.3	82.3	2.0	0.9	67.9	82.9	66.7	83.4	65.6	83.9	64.1	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.5	80.7	81.1	81.6	82.1	82.3	81.9	81.4	81.5	81.7	81.6	80.8	80.7	
	DBStd	1.82	1.95	1.58	1.84	1.47	1.65	1.83	1.91	1.87	1.74	1.59	1.58	1.87	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11481	953	871	979	963	1001	957	973	977	950	980	925	952	
	CDD65	6006	488	451	514	513	536	507	508	512	500	515	475	487	
	CDH74	58554	4494	4295	5025	5109	5508	5232	5069	5138	4984	5022	4252	4426	
	CDH80	17798	1220	1317	1650	1644	1744	1703	1562	1598	1607	1557	1074	1122	
Wind	WSAvg	3.8	5.3	5.5	3.9	2.8	2.8	3.4	4.1	4.5	4.0	2.8	2.6	4.2	
Precipitation	PrecAvg	117.3	8.1	7.2	7.4	12.3	10.6	9.0	10.0	6.5	10.0	10.0	11.8	14.6	
	PrecMax	163.7	22.4	24.8	18.0	20.9	16.7	14.6	20.6	12.9	21.1	15.4	19.7	28.7	
	PrecMin	81.3	0.2	0.2	0.7	2.0	6.7	1.7	0.5	2.4	3.1	3.1	3.5	1.2	
	PrecStd	22.1	6.2	5.5	4.6	5.6	2.9	3.1	5.0	3.1	5.2	3.7	4.2	7.4	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.0	90.8	91.4	91.3	90.8	90.0	90.0	90.2	91.0	89.8	89.9	
		MCWB	78.3	77.7	77.5	79.3	80.2	78.9	79.2	78.5	77.9	78.1	78.5	78.7	
	2%	DB	88.2	88.8	89.7	89.9	89.9	89.7	88.9	88.9	89.3	89.7	88.3	88.2	
		MCWB	78.0	77.4	77.5	79.2	79.9	79.4	79.0	78.4	78.1	78.3	78.7	78.4	
	5%	DB	86.9	87.6	88.6	88.8	88.9	88.8	88.0	88.0	88.5	88.6	87.1	86.9	
		MCWB	77.5	77.2	77.6	79.0	79.8	79.4	78.8	78.2	78.2	78.4	78.7	78.1	
	10%	DB	85.7	86.5	87.5	87.6	87.6	87.7	87.0	87.0	87.5	87.3	85.7	85.6	
		MCWB	77.0	76.8	77.6	78.9	79.6	79.3	78.6	78.0	78.2	78.3	78.5	77.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	79.7	80.1	81.3	81.8	81.3	81.0	80.7	80.2	80.4	80.1	80.1
			MCDB	86.0	86.7	86.3	87.0	88.2	87.1	87.1	87.6	86.9	87.2	85.7	86.0
2%		WB	79.1	78.9	79.3	80.6	81.0	80.7	80.0	79.8	79.7	79.7	79.7	79.6	
		MCDB	85.0	85.4	85.7	86.8	87.0	86.9	86.4	86.3	86.3	86.2	85.2	85.2	
5%		WB	78.5	78.2	78.8	80.0	80.5	80.1	79.5	79.1	79.1	79.2	79.2	79.0	
		MCDB	84.1	84.4	85.3	85.9	86.3	86.0	85.6	85.3	85.6	85.3	84.4	84.5	
10%		WB	78.0	77.7	78.2	79.5	80.0	79.7	79.0	78.6	78.6	78.8	78.8	78.5	
		MCDB	83.3	83.6	84.3	85.1	85.3	85.4	84.9	84.5	84.9	84.7	83.9	83.5	
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.2	11.8	11.7	10.9	10.7	10.4	10.5	11.4	11.2	10.2	9.4	
		MCDBR	11.5	12.7	13.3	13.2	12.4	12.6	11.9	11.9	12.9	13.4	12.1	11.5	
		MCWBR	3.5	3.7	3.9	4.4	4.4	4.5	4.3	3.9	4.2	4.4	4.4	3.8	
	5% WB	MCDBR	10.3	11.4	11.9	11.8	11.3	11.3	11.0	10.9	11.7	11.7	10.9	10.2	
		MCWBR	3.8	4.1	4.2	4.7	4.6	4.7	4.4	4.4	4.5	4.4	4.5	4.3	
Clear-Sky Solar Irradiance	taub	0.467	0.473	0.472	0.454	0.448	0.460	0.456	0.499	0.533	0.558	0.469	0.464		
	taud	2.330	2.293	2.305	2.351	2.388	2.363	2.372	2.225	2.116	2.033	2.310	2.340		
	Ebn at Noon	274	274	272	272	266	259	261	256	252	248	272	273		
	Edh at Noon	42	44	43	41	38	38	38	45	52	57	43	41		
All-Sky Solar Radiation	RadAvg	1480	1739	1727	1657	1519	1422	1426	1472	1486	1441	1316	1308		
	RadStd	123	155	146	108	78	106	131	105	89	107	95	107		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.67	+0.16	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page