

TANJUNG PINANG KIJANG, Indonesia

WMO: 960910

Lat: 0.923N

Lon: 104.532E

Elev: 18

StdP: 101.11

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 11	(b) 22.8	(c) 23.2	(d) 20.3	(e) 15.0	(f) 27.2	(g) 21.0	(h) 15.7	(i) 27.3	(j) 8.0	(k) 26.6	(l) 6.5	(m) 28.3	(n) 0.5	(o) 300	(p) 0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 6.0	(c) 32.6	(d) 26.0	(e) 32.2	(f) 26.0	(g) 31.8	(h) 25.9	(i) 27.2	(j) 30.6	(k) 27.0	(l) 30.4	(m) 26.7	(n) 30.0	(o) 4.5	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.2	(b) 21.7	(c) 28.6	(d) 26.1	(e) 21.5	(f) 28.5	(g) 25.8	(h) 21.2	(i) 28.3	(j) 86.0	(k) 30.8	(l) 84.8	(m) 30.6	(n) 83.8	(o) 30.4	(p) 28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.8	(b) 6.6	(c) 5.9	(e) 21.0	(f) 33.5	(g) 2.2	(h) 0.3	(i) 19.4	(j) 33.7	(k) 18.1	(l) 33.9	(m) 16.9	(n) 34.1	(o) 15.4	(p) 34.3		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			20.7	28.0	1.1	0.5	19.9	28.3	19.3	28.6	18.7	28.9	17.8	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.1	27.3	27.5	27.8	27.9	27.7	27.4	27.5	27.6	27.6	27.1	27.1		
	DBStd	1.01	1.08	0.88	1.02	0.82	0.92	1.02	1.06	1.04	0.97	0.88	0.88	1.04		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6378	529	484	544	535	556	532	541	543	528	544	514	529		
	CDD18.3	3337	271	251	286	285	298	282	282	284	278	286	264	271		
	CDH23.3	32530	2497	2386	2792	2838	3060	2907	2816	2854	2769	2790	2362	2459		
	CDH26.7	9888	678	732	917	913	969	946	868	888	893	865	597	623		
(14) Wind	WSAvg	1.7	2.4	2.4	1.7	1.3	1.3	1.5	1.8	2.0	1.8	1.3	1.2	1.9		
(15) Precipitation	PrecAvg	2980	207	184	187	313	270	228	255	166	255	253	299	370		
	PrecMax	4157	569	630	457	532	424	370	524	327	537	390	500	730		
	PrecMin	2065	4	5	18	50	171	44	13	60	78	80	90	30		
	PrecStd	562	158	140	118	143	74	80	128	79	131	93	107	189		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.2	32.7	33.0	32.9	32.7	32.2	32.2	32.3	32.8	32.1	32.2		
		MCWB	25.7	25.4	25.3	26.3	26.8	26.0	26.2	25.8	25.5	25.6	25.8	25.9		
	2%	DB	31.2	31.6	32.0	32.2	32.2	32.1	31.6	31.6	31.8	32.1	31.3	31.2		
		MCWB	25.6	25.2	25.3	26.2	26.6	26.3	26.1	25.8	25.6	25.7	25.9	25.8		
	5%	DB	30.5	30.9	31.4	31.6	31.6	31.5	31.1	31.1	31.4	31.4	30.6	30.5		
		MCWB	25.3	25.1	25.3	26.1	26.5	26.3	26.0	25.6	25.6	25.8	25.9	25.6		
	10%	DB	29.8	30.3	30.8	30.9	30.9	30.9	30.5	30.6	30.8	30.7	29.9	29.8		
		MCWB	25.0	24.9	25.3	26.1	26.5	26.3	25.9	25.6	25.7	25.7	25.8	25.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.5	26.7	27.4	27.6	27.4	27.2	27.0	26.8	26.9	26.7	26.7		
		MCDB	30.0	30.4	30.2	30.6	31.2	30.6	30.6	30.9	30.5	30.7	29.9	30.0		
	2%	WB	26.2	26.1	26.3	27.0	27.2	27.1	26.7	26.5	26.5	26.5	26.5	26.4		
		MCDB	29.4	29.7	29.8	30.4	30.6	30.5	30.2	30.2	30.2	30.1	29.6	29.6		
	5%	WB	25.9	25.7	26.0	26.6	26.9	26.7	26.4	26.2	26.2	26.2	26.2	26.1		
		MCDB	29.0	29.1	29.6	29.9	30.1	30.0	29.8	29.6	29.8	29.6	29.1	29.1		
	10%	WB	25.6	25.4	25.7	26.4	26.6	26.5	26.1	25.9	25.9	26.0	26.0	25.8		
		MCDB	28.5	28.7	29.1	29.5	29.6	29.7	29.4	29.2	29.4	29.3	28.8	28.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.5	6.2	6.6	6.5	6.0	6.0	5.8	5.8	6.3	6.2	5.6	5.2		
		MCDBR	6.4	7.1	7.4	7.3	6.9	7.0	6.6	6.6	7.2	7.4	6.7	6.4		
	5% WB	MCWBR	1.9	2.1	2.1	2.5	2.5	2.5	2.4	2.2	2.3	2.4	2.4	2.1		
		MCWBR	5.7	6.3	6.6	6.6	6.3	6.3	6.1	6.0	6.5	6.5	6.0	5.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.467	0.473	0.472	0.454	0.448	0.460	0.456	0.499	0.533	0.558	0.469	0.464		
		taud	2.330	2.293	2.305	2.351	2.388	2.363	2.372	2.225	2.116	2.033	2.310	2.340		
	Ebn at Noon	Ebn at Noon	865	864	859	856	839	815	824	807	796	783	857	861		
		Edh at Noon	133	139	137	128	119	120	120	143	163	179	134	130		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.67	5.48	5.45	5.22	4.79	4.48	4.50	4.64	4.68	4.54	4.15	4.12		
	RadStd	RadStd	0.39	0.49	0.46	0.34	0.25	0.33	0.41	0.33	0.28	0.34	0.30	0.34		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (7 neighbors)	+0.37	+0.09	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page