

RENGAT JAPURA, Indonesia

WMO: 961710

Lat: 0.3494S

Lon: 102.3339E

Elev: 151

StdP: 14.62

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	71.3	72.1	68.8	106.4	81.1	69.9	110.6	79.6	11.8	83.0	10.2	83.4	0.4	N/A	0.279

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.4	92.7	78.7	91.8	78.7	91.1	78.6	81.4	88.4	80.8	88.0	80.3	87.4	3.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	153.8	85.2	78.9	151.0	84.9	78.3	147.9	84.3	45.2	88.9	44.6	88.4	44.1	87.7	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.2	7.7	68.5	94.9	2.7	0.8	66.6	95.5	65.0	96.0	63.5	96.4	61.5	97.0		
(5)			66.7	83.0	3.4	1.3	64.3	84.0	62.3	84.7	60.4	85.5	57.9	86.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.5	80.3	80.9	81.6	82.1	82.5	82.2	81.5	81.5	81.4	81.5	81.3	80.8	(6)
(7)		DBStd	1.86	1.93	1.77	1.77	1.72	1.85	1.83	1.80	1.77	1.79	1.64	1.58	1.70	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11488	941	866	981	963	1008	965	975	977	943	976	939	954	(10)
(11)		CDD65	6013	476	446	516	513	543	515	510	512	493	511	489	489	(11)
(12)		CDH74	56626	4088	4094	4893	4969	5593	5240	4926	4925	4572	4641	4378	4307	(12)
(13)		CDH80	20849	1272	1374	1820	1886	2210	2087	1905	1898	1762	1734	1541	1360	(13)
(14)	Wind	WSAvg	1.4	1.5	1.5	1.2	1.2	1.3	1.4	1.6	1.8	1.5	1.2	1.3	1.4	(14)
(15)	Precipitation	PrecAvg	87.8	7.7	7.7	7.9	9.4	7.2	4.7	4.5	4.8	6.9	7.6	10.4	8.5	(15)
(16)		PrecMax	129.9	19.6	15.4	18.1	20.7	20.2	11.2	11.5	9.8	21.7	15.8	28.1	16.2	(16)
(17)		PrecMin	47.3	1.5	1.0	0.4	1.8	1.3	0.2	0.3	0.7	0.4	0.4	2.7	2.1	(17)
(18)		PrecStd	21.9	4.4	3.6	4.6	3.9	3.7	2.7	2.8	2.2	5.2	3.8	5.0	3.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	91.4	92.7	93.2	93.6	93.5	92.6	92.6	92.8	92.7	92.1	91.2	(19)
MCWB			78.4	78.4	78.8	79.9	80.2	78.8	78.0	77.4	76.9	77.8	78.3	78.7	(20)	
2%		DB	89.5	89.8	91.2	91.6	92.1	91.8	91.1	91.2	91.3	91.2	90.5	89.6	(21)	
		MCWB	78.2	78.2	78.9	79.6	80.0	79.0	77.9	77.4	77.5	78.2	78.6	78.7	(22)	
5%		DB	87.9	88.6	89.8	90.2	90.8	90.6	89.9	89.9	90.0	89.8	89.1	88.2	(23)	
		MCWB	78.0	78.1	78.8	79.6	79.9	78.9	78.0	77.6	77.7	78.5	78.6	78.4	(24)	
10%		DB	86.3	87.2	88.3	88.7	89.4	89.2	88.6	88.5	88.6	88.2	87.6	86.5	(25)	
		MCWB	77.8	77.9	78.7	79.5	79.8	78.9	78.0	77.6	77.8	78.4	78.5	78.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.9	81.4	81.8	82.4	81.6	80.6	80.5	80.4	80.6	80.8	80.4	(27)
MCD B			87.0	87.5	88.6	88.9	89.6	88.2	87.3	87.2	87.2	87.6	87.5	87.4	(28)	
2%		WB	79.4	79.8	80.3	81.0	81.5	80.7	79.7	79.6	79.6	79.9	80.0	79.8	(29)	
		MCD B	86.2	86.6	87.6	88.2	88.7	87.9	86.8	86.7	86.9	87.1	87.0	86.5	(30)	
5%		WB	78.8	79.1	79.8	80.4	80.8	80.0	79.1	79.0	79.0	79.2	79.4	79.2	(31)	
		MCD B	85.6	85.9	87.0	87.6	88.1	87.2	86.5	86.4	86.6	86.6	86.4	85.8	(32)	
10%		WB	78.2	78.4	79.1	79.8	80.1	79.5	78.7	78.3	78.4	78.8	78.9	78.6	(33)	
		MCD B	84.4	85.0	86.3	86.8	87.1	86.7	86.0	85.6	85.7	86.3	85.9	85.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.5	13.3	14.4	14.5	14.4	14.8	14.8	14.7	14.8	14.5	13.9	12.5	(35)
MCDBR			14.9	15.1	16.2	16.4	16.2	16.5	16.8	16.8	16.9	16.5	15.9	14.8	(36)	
MCWBR			5.5	5.5	6.0	6.3	6.1	5.8	5.8	5.5	5.7	5.8	5.7	5.5	(37)	
5% WB		MCDBR	13.5	13.8	14.6	15.0	14.8	15.1	15.2	14.9	15.3	14.9	14.2	13.2	(38)	
		MCWBR	5.6	5.8	6.1	6.3	6.3	6.0	5.9	5.9	6.1	6.1	5.9	5.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.479	0.575	0.537	0.466	0.463	0.478	0.486	0.563	0.625	0.640	0.482	0.448	(40)
taud		2.228	1.934	2.056	2.274	2.286	2.233	2.209	1.974	1.816	1.768	2.225	2.341	(41)		
Ebn at Noon		272	247	256	268	261	252	252	239	231	229	269	279	(42)		
Edh at Noon		47	63	56	44	42	43	45	58	70	74	47	41	(43)		
(44)	All-Sky Solar Radiation	RadAvg		1354	1435	1519	1535	1500	1472	1442	1468	1434	1436	1447	1357	(44)
(45)		RadStd		97	69	98	47	47	67	72	81	124	161	58	103	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.58	+0.61	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	+0.58	+0.61	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page