

JAMBI SULTAN TAHA, Indonesia

WMO: 961950

Lat: 1.638S

Lon: 103.644E

Elev: 25

StdP: 101.03

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.4	22.8	20.3	15.1	29.8	20.9	15.6	28.8	7.4	28.1	5.8	27.6	1.2	160	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.3	33.3	25.5	32.9	25.6	32.5	25.5	27.2	30.8	26.8	30.5	26.6	30.3	2.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.0	25.8	21.2	28.6	25.6	20.9	28.4	86.1	31.0	84.4	30.7	83.2	30.5	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.8	5.1	4.4	20.2	34.3	2.6	0.5	18.3	34.6	16.8	34.9	15.4	35.2	13.5	35.6
			19.4	28.8	2.5	1.0	17.6	29.5	16.1	30.1	14.6	30.6	12.8	31.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	27.2	27.2	27.5	27.8	28.0	27.8	27.5	27.6	27.7	27.6	27.5	27.2
	DBStd	0.98	0.95	0.98	1.01	0.91	0.90	0.92	0.95	0.89	0.99	1.00	0.85	1.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6413	533	482	543	535	559	535	543	546	531	547	526	533
	CDD18.3	3371	275	249	284	285	301	285	284	288	281	289	276	274
	CDH23.3	32865	2589	2318	2702	2776	3081	2924	2853	2910	2831	2777	2533	2570
	CDH26.7	11338	743	682	904	968	1136	1086	1045	1126	1103	975	812	759
Wind	WSAvg	1.5	1.8	1.5	1.4	1.2	1.4	1.5	1.7	1.9	1.7	1.4	1.3	1.6
Precipitation	PrecAvg	2053	193	172	234	255	167	119	97	106	133	162	243	237
	PrecMax	2611	379	359	407	540	291	230	214	227	328	371	495	384
	PrecMin	1497	29	39	100	89	27	15	6	3	0	17	94	91
	PrecStd	332	89	74	81	107	64	66	60	64	68	87	96	78
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	32.6	33.2	33.5	33.5	33.2	33.2	33.5	34.0	33.6	33.0	32.7
		MCWB	25.0	25.5	25.5	26.4	26.3	25.7	25.2	24.8	24.5	25.1	25.7	25.2
	2%	DB	31.7	31.9	32.4	32.7	32.7	32.6	32.5	32.7	32.9	32.8	32.2	31.8
		MCWB	25.2	25.3	25.6	26.3	26.3	25.8	25.2	25.1	25.0	25.3	25.7	25.5
	5%	DB	30.9	31.1	31.7	32.0	32.2	32.0	31.9	32.1	32.3	32.0	31.5	31.0
		MCWB	25.2	25.2	25.6	26.2	26.2	25.8	25.2	25.1	25.1	25.4	25.7	25.5
	10%	DB	30.1	30.2	30.9	31.2	31.5	31.3	31.2	31.4	31.6	31.1	30.6	30.2
		MCWB	25.1	25.1	25.6	26.1	26.2	25.8	25.3	25.0	25.1	25.4	25.7	25.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.7	26.9	27.9	27.7	27.2	26.7	27.1	26.8	26.9	26.7	26.7
		MCDB	29.3	30.3	30.6	31.4	31.4	30.7	30.2	31.1	30.5	30.6	30.4	29.6
	2%	WB	26.1	26.2	26.5	27.1	27.1	26.7	26.2	26.3	26.2	26.4	26.4	26.2
		MCDB	29.1	29.6	30.1	30.8	30.9	30.4	30.1	30.3	30.3	30.3	30.1	29.4
	5%	WB	25.7	25.8	26.2	26.6	26.7	26.4	25.9	25.9	25.9	26.1	26.1	25.9
		MCDB	28.8	29.1	29.8	30.3	30.5	30.2	29.9	29.8	30.2	30.1	29.9	29.2
	10%	WB	25.5	25.6	25.9	26.3	26.4	26.1	25.7	25.6	25.6	25.7	25.8	25.6
		MCDB	28.5	28.7	29.5	29.8	30.1	29.9	29.5	29.5	29.8	29.5	29.5	28.8
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.3	7.1	7.3	7.3	7.3	7.6	7.9	7.9	7.3	7.0	6.2
		MCDBR	7.2	7.5	8.2	8.4	8.0	8.0	8.5	8.9	9.0	8.5	7.9	7.4
		MCWBR	2.1	2.2	2.7	2.9	2.7	2.5	2.6	2.5	2.7	2.5	2.6	2.4
	5% WB	MCDBR	6.3	6.7	7.4	7.7	7.4	7.5	7.5	7.7	7.9	7.5	7.1	6.7
		MCWBR	2.2	2.5	2.8	3.0	2.8	2.8	2.7	2.8	2.9	2.8	2.7	2.5
Clear-Sky Solar Irradiance	taub		0.481	0.525	0.496	0.451	0.460	0.464	0.478	0.546	0.658	0.668	0.506	0.451
	taud		2.228	2.090	2.185	2.320	2.293	2.281	2.236	2.023	1.730	1.702	2.149	2.329
	Ebn at Noon		856	822	839	856	823	806	800	766	703	702	828	878
	Edh at Noon		148	172	155	131	130	129	136	174	241	250	159	132
All-Sky Solar Radiation	RadAvg		4.22	4.45	4.67	4.75	4.69	4.62	4.60	4.79	4.72	4.50	4.46	4.20
	RadStd		0.29	0.23	0.23	0.17	0.13	0.21	0.23	0.21	0.32	0.43	0.20	0.25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page