

KERINCI DEPATI PARBO, Indonesia

WMO: 962070

Lat: 2.0911S

Lon: 101.4620E

Elev: 782

StdP: 92.28

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.7	17.5	14.6	11.4	20.5	15.5	12.1	20.5	9.4	23.7	7.9	24.3	0.2	N/A	0.199

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.5	29.6	22.5	29.1	22.4	28.7	22.3	23.9	27.9	23.5	27.5	23.1	27.1	3.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	19.1	26.0	22.2	18.6	25.5	21.9	18.3	25.3	75.9	28.0	74.3	27.6	72.9	27.3	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
7.4	6.1	5.2	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	12.6	26.5	1.6	1.8	11.4	27.7	10.4	28.8	9.5	29.7	8.3	31.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	23.0	23.1	23.6	23.9	23.9	23.6	23.0	23.1	23.1	23.3	23.4	23.3
	DBStd	0.95	0.95	1.06	0.81	1.00	0.95	0.84	0.89	0.87	0.87	0.79	0.86	0.94
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	4884	404	368	422	418	431	407	404	407	394	414	402	413
	CDD18.3	1843	146	135	164	168	173	157	146	148	144	156	152	154
	CDH23.3	8380	573	550	761	784	873	778	694	689	699	758	611	609
	CDH26.7	1228	59	80	119	137	157	121	97	98	105	115	69	70
(14) Wind	WSAvg	1.3	1.6	1.3	1.4	1.2	1.3	1.2	1.2	1.3	1.2	1.4	1.3	1.6
(15) Precipitation	PrecAvg	1933	202	193	171	229	121	109	93	107	139	177	238	206
	PrecMax	2536	380	382	634	463	210	209	331	376	237	340	467	411
	PrecMin	1094	101	49	21	67	23	19	25	31	51	89	115	113
	PrecStd	382	75	89	120	87	54	47	62	74	48	67	90	77
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.9	30.0	29.6	29.7	29.9	29.6	29.3	29.4	29.5	29.6	29.3	29.2
		MCWB	22.2	22.7	22.7	23.1	22.9	22.5	22.2	21.9	22.1	21.7	22.2	22.4
	2%	DB	28.1	28.6	28.8	29.0	29.1	28.8	28.6	28.6	28.7	28.7	28.3	28.2
		MCWB	22.1	22.4	22.6	23.0	22.9	22.5	22.0	21.8	21.7	21.6	22.4	22.2
	5%	DB	27.3	27.6	28.1	28.2	28.4	28.1	27.8	27.8	28.0	28.0	27.5	27.4
		MCWB	21.9	22.2	22.5	22.8	22.7	22.3	21.8	21.7	21.6	21.6	22.3	22.1
	10%	DB	26.4	26.6	27.2	27.4	27.5	27.3	26.9	26.9	27.1	27.1	26.6	26.5
		MCWB	21.6	22.0	22.2	22.5	22.5	22.1	21.7	21.6	21.5	21.5	22.1	21.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.7	23.7	24.1	24.2	24.2	23.9	23.4	23.2	23.2	23.2	23.6	23.5
		MCDB	27.5	28.3	28.1	28.1	28.2	27.9	27.3	27.5	27.9	27.4	27.6	27.5
	2%	WB	23.0	23.1	23.4	23.6	23.6	23.2	22.7	22.6	22.6	22.6	23.1	22.9
		MCDB	26.8	27.1	27.4	27.6	27.6	27.3	26.9	26.9	27.1	26.9	27.0	26.8
	5%	WB	22.4	22.6	22.9	23.2	23.2	22.8	22.3	22.2	22.2	22.2	22.6	22.5
		MCDB	25.9	26.4	26.7	27.0	27.1	26.8	26.4	26.4	26.4	26.3	26.4	26.2
	10%	WB	22.0	22.2	22.4	22.7	22.7	22.4	22.0	21.8	21.8	21.9	22.3	22.1
		MCDB	25.2	25.6	26.0	26.3	26.4	26.2	25.9	25.8	25.8	25.9	25.8	25.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	8.0	8.6	8.6	8.5	8.6	8.9	8.6	8.7	8.7	7.9	7.7
		MCDBR	8.9	9.6	9.5	9.3	9.4	9.4	10.1	9.8	10.1	9.8	8.8	8.8
	5% WB	MCWBR	4.0	4.4	4.3	4.1	4.2	4.2	4.6	4.2	4.3	4.1	3.8	3.7
		MCWBR	8.0	8.4	8.9	8.8	8.7	9.1	8.9	8.9	8.9	8.8	8.2	8.1
(40) Clear-Sky Solar Irradiance	taub	taub	0.421	0.475	0.462	0.417	0.429	0.435	0.446	0.507	0.585	0.611	0.455	0.396
		taud	2.372	2.200	2.249	2.392	2.360	2.347	2.312	2.105	1.878	1.803	2.274	2.457
	Ebn at Noon	Ebn at Noon	913	865	868	885	850	830	827	796	756	745	874	932
		Edh at Noon	128	154	145	122	121	120	126	160	207	226	140	117
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.58	4.71	5.03	4.96	4.90	4.73	4.66	4.68	4.67	4.59	4.67	4.52
	RadStd	RadStd	0.32	0.24	0.31	0.14	0.19	0.21	0.22	0.28	0.32	0.45	0.20	0.25

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page