

PALEMBANG BADARUDIN II, Indonesia

WMO: 962210

Lat: 2.9024S

Lon: 104.6990E

Elev: 33

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 72.3	(c) 73.1	(d) 66.2	(e) 96.7	(f) 89.2	(g) 67.9	(h) 102.6	(i) 88.4	(j) 17.0	(k) 83.7	(l) 14.8	(m) 84.7	(n) 2.9	(o) 200	(p) 0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 13.4	(c) 93.4	(d) 76.8	(e) 92.6	(f) 77.1	(g) 91.6	(h) 77.5	(i) 80.9	(j) 87.3	(k) 80.3	(l) 86.8	(m) 80.0	(n) 86.5	(o) 6.8	(p) 100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	151.6	83.6	78.9	150.1	83.4	78.4	147.8	83.0	44.7	88.2	44.0	87.6	43.6	86.9	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 14.3	(b) 12.2	(c) 11.1	(e) 70.3	(f) 95.4	(g) 1.1	(h) 1.4	(i) 69.5	(j) 96.3	(k) 68.8	(l) 97.1	(m) 68.2	(n) 97.9	(o) 67.4	(p) 98.9		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			70.3	95.4	1.1	1.4	69.5	96.3	68.8	97.1	68.2	97.9	67.4	98.9		
			68.4	83.0	1.4	1.8	67.4	84.3	66.6	85.3	65.8	86.3	64.8	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	81.1	81.3	82.2	82.7	83.3	82.8	82.1	82.4	82.9	82.9	82.4	81.4
	DBStd	1.81	1.70	1.70	1.63	1.72	1.61	1.69	1.59	1.54	1.58	1.80	1.74	1.72
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11791	963	876	999	982	1032	983	995	1006	988	1021	973	973
	CDD65	6316	498	456	534	532	567	533	530	541	538	556	523	508
	CDH74	62191	4406	4043	5125	5293	5934	5535	5275	5524	5645	5645	5065	4701
	CDH80	23071	1314	1250	1834	1953	2225	2121	1973	2236	2430	2344	1911	1480
Wind	WSAvg	4.2	4.6	4.3	3.8	3.0	3.5	4.0	5.0	5.7	5.4	3.8	3.1	3.9
Precipitation	PrecAvg	104.4	10.7	9.8	12.0	10.7	8.6	5.0	4.5	3.8	5.1	7.5	11.3	14.5
	PrecMax	150.3	33.5	25.2	21.3	19.3	25.4	15.0	11.5	9.8	18.5	17.0	24.5	26.1
	PrecMin	65.4	2.2	3.3	5.1	3.8	2.4	1.4	0.0	0.0	0.0	0.1	2.6	7.0
	PrecStd	20.4	6.3	4.5	4.0	4.0	4.7	3.1	2.9	3.0	3.9	3.9	4.6	4.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	91.6	92.9	93.2	93.1	93.0	91.8	93.3	94.3	94.8	94.3	91.6
		MCWB	78.3	78.6	78.9	79.2	79.4	78.3	77.4	76.3	75.3	75.7	76.6	78.2
	2%	DB	89.6	89.8	91.3	91.6	91.6	91.4	91.1	91.7	93.1	93.2	91.8	89.8
		MCWB	77.9	78.2	78.8	79.1	79.1	78.0	77.2	76.2	75.6	76.1	77.7	78.2
	5%	DB	88.0	88.2	89.8	90.3	90.6	90.2	89.8	90.6	91.8	91.7	90.2	88.4
		MCWB	78.1	78.1	78.7	79.1	79.0	78.1	77.0	76.2	75.9	76.6	78.0	78.3
	10%	DB	86.3	86.9	88.2	89.2	89.4	89.3	88.4	89.4	90.7	90.0	88.6	87.0
		MCWB	77.8	78.0	78.6	79.1	79.0	78.1	77.1	76.3	76.2	77.1	78.1	78.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	80.4	81.0	81.6	81.9	80.9	80.0	79.8	79.9	80.1	80.3	80.2
		MCDB	85.8	86.5	87.6	87.5	87.9	87.3	86.9	86.6	86.6	87.0	86.9	85.9
	2%	WB	79.6	79.7	80.1	80.6	80.9	80.1	79.2	78.9	79.1	79.3	79.7	79.6
		MCDB	85.2	85.7	86.8	87.2	87.4	86.6	86.2	86.2	86.4	86.6	86.4	85.4
	5%	WB	79.0	79.1	79.7	80.0	80.1	79.7	78.7	78.2	78.4	78.8	79.1	79.1
		MCDB	84.6	85.1	86.3	86.6	86.6	86.2	85.8	85.6	85.9	86.3	86.0	85.0
	10%	WB	78.4	78.5	79.1	79.5	79.7	79.1	78.1	77.6	77.8	78.2	78.7	78.6
		MCDB	83.7	84.4	85.5	86.0	86.1	85.7	85.0	85.0	85.4	85.5	85.6	84.5
Mean Daily Temperature Range	5% DB	MDBR	12.0	12.5	14.0	13.8	13.4	13.8	14.1	15.4	16.3	15.6	14.4	12.4
		MCDBR	14.0	14.1	15.4	15.1	14.7	14.9	15.3	16.6	17.9	17.6	16.1	14.1
		MCWBR	4.9	4.8	5.5	5.1	4.6	4.6	4.6	4.5	4.6	4.6	4.7	4.9
	5% WB	MCDBR	12.5	13.0	14.4	13.9	13.7	13.8	14.0	15.1	15.5	15.3	14.5	12.8
		MCWBR	5.0	5.1	5.7	5.4	4.9	4.9	4.8	4.9	5.1	5.0	5.0	5.1
Clear-Sky Solar Irradiance	taub		0.464	0.499	0.483	0.454	0.468	0.460	0.478	0.528	0.650	0.686	0.548	0.448
	taud		2.299	2.186	2.241	2.333	2.287	2.298	2.239	2.072	1.742	1.670	2.022	2.347
	Ebn at Noon		277	268	270	270	258	256	253	247	225	219	252	280
	Edh at Noon		44	49	46	41	41	40	43	52	75	82	57	42
All-Sky Solar Radiation	RadAvg		1389	1452	1556	1564	1503	1459	1463	1577	1585	1507	1480	1396
	RadStd		85	62	64	54	49	87	75	67	92	121	63	71

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page