

PALEMBANG BADARUDIN II, Indonesia

WMO: 962210

Lat: 2.9024S

Lon: 104.6990E

Elev: 10

StdP: 101.20

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.4	(c) 22.8	(d) 19.0	(e) 13.8	(f) 31.8	(g) 19.9	(h) 14.7	(i) 31.3	(j) 7.6	(k) 28.7	(l) 6.6	(m) 29.3	(n) 1.3	(o) 200	(p) 0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.5	34.1	24.9	33.7	25.1	33.1	25.3	27.2	30.7	26.8	30.5	26.6	30.3	3.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	28.7	26.1	21.4	28.5	25.8	21.1	28.3	86.0	31.2	84.5	30.9	83.6	30.5	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.4	(b) 5.5	(c) 5.0	(e) 21.3	(f) 35.2	(g) 0.6	(h) 0.8	(i) 20.8	(j) 35.7	(k) 20.5	(l) 36.2	(m) 20.1	(n) 36.6	(o) 19.7	(p) 37.2		
(a) 6.4	(b) 5.5	(c) 5.0	(e) 20.2	(f) 28.4	(g) 0.8	(h) 1.0	(i) 19.7	(j) 29.1	(k) 19.2	(l) 29.6	(m) 18.8	(n) 30.2	(o) 18.2	(p) 30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	27.3	27.4	27.9	28.2	28.5	28.2	27.8	28.0	28.3	28.3	28.0	27.4
	DBStd	1.00	0.95	0.94	0.91	0.96	0.89	0.94	0.89	0.86	0.88	1.00	0.97	0.96
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6551	535	487	555	546	573	546	553	559	549	567	541	541
	CDD18.3	3509	277	253	297	296	315	296	294	301	299	309	291	282
	CDH23.3	34551	2448	2246	2847	2941	3297	3075	2931	3069	3136	3136	2814	2612
	CDH26.7	12817	730	694	1019	1085	1236	1178	1096	1242	1350	1302	1062	822
Wind	WSAvg	1.9	2.0	1.9	1.7	1.4	1.6	1.8	2.3	2.6	2.4	1.7	1.4	1.7
Precipitation	PrecAvg	2653	273	248	306	273	219	126	114	96	129	190	288	369
	PrecMax	3818	850	639	541	491	645	381	291	250	469	433	622	662
	PrecMin	1662	57	85	130	97	61	35	0	0	0	2	67	177
	PrecStd	519	160	114	102	102	120	80	74	75	98	99	117	113
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	33.1	33.8	34.0	33.9	33.2	34.1	34.6	34.9	34.6	33.1	
		MCWB	25.7	25.9	26.1	26.2	26.3	25.7	25.2	24.6	24.0	24.3	24.8	25.7
	2%	DB	32.0	32.1	32.9	33.1	33.1	33.0	32.8	33.1	33.9	34.0	33.2	32.1
		MCWB	25.5	25.7	26.0	26.2	26.2	25.6	25.1	24.5	24.2	24.5	25.4	25.7
	5%	DB	31.1	31.2	32.1	32.4	32.6	32.3	32.1	32.6	33.2	33.2	32.3	31.3
		MCWB	25.6	25.6	25.9	26.2	26.1	25.6	25.0	24.6	24.4	24.8	25.6	25.7
	10%	DB	30.2	30.5	31.2	31.8	31.9	31.8	31.4	31.9	32.6	32.2	31.4	30.6
		MCWB	25.4	25.5	25.9	26.2	26.1	25.6	25.1	24.6	24.6	25.1	25.6	25.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	26.9	27.2	27.6	27.7	27.2	26.7	26.5	26.6	26.7	26.8	26.8
		MCDB	29.9	30.3	30.9	30.9	31.1	30.7	30.5	30.3	30.3	30.6	30.5	30.0
	2%	WB	26.4	26.5	26.7	27.0	27.1	26.7	26.2	26.0	26.1	26.3	26.5	26.4
		MCDB	29.6	29.8	30.5	30.7	30.8	30.3	30.1	30.1	30.2	30.3	30.2	29.7
	5%	WB	26.1	26.1	26.5	26.7	26.7	26.5	25.9	25.7	25.8	26.0	26.2	26.2
		MCDB	29.2	29.5	30.1	30.3	30.4	30.1	29.9	29.8	29.9	30.2	30.0	29.4
	10%	WB	25.8	25.9	26.2	26.4	26.5	26.2	25.6	25.3	25.4	25.7	26.0	25.9
		MCDB	28.7	29.1	29.7	30.0	30.0	29.9	29.4	29.5	29.7	29.7	29.8	29.2
Mean Daily Temperature Range	5% DB	MDBR	6.7	7.0	7.8	7.6	7.5	7.7	7.8	8.6	9.1	8.7	8.0	6.9
		MCDBR	7.8	7.9	8.6	8.4	8.1	8.3	8.5	9.2	10.0	9.8	9.0	7.8
		MCWBR	2.7	2.7	3.1	2.8	2.5	2.5	2.5	2.5	2.6	2.5	2.6	2.7
	5% WB	MCDBR	7.0	7.2	8.0	7.7	7.6	7.7	7.8	8.4	8.6	8.5	8.0	7.1
		MCWBR	2.8	2.8	3.2	3.0	2.7	2.7	2.6	2.7	2.8	2.8	2.8	2.8
Clear-Sky Solar Irradiance	taub	0.464	0.499	0.483	0.454	0.468	0.460	0.478	0.528	0.650	0.686	0.548	0.448	
	taud	2.299	2.186	2.241	2.333	2.287	2.298	2.239	2.072	1.742	1.670	2.022	2.347	
	Ebn at Noon	874	845	850	852	814	806	798	779	708	691	794	883	
	Edh at Noon	138	156	146	129	130	126	135	165	238	258	181	131	
All-Sky Solar Radiation	RadAvg	4.38	4.58	4.90	4.93	4.74	4.60	4.61	4.97	5.00	4.75	4.67	4.40	
	RadStd	0.27	0.19	0.20	0.17	0.15	0.28	0.23	0.21	0.29	0.38	0.20	0.22	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page