

PANGKAL PINANG, Indonesia

WMO: 962370

Lat: 2.1631S

Lon: 106.1370E

Elev: 33

StdP: 100.93

Time Zone: 7.00 (E07)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	23.3	20.5	15.2	29.2	21.1	15.8	28.2	7.9	29.4	6.6	29.1	0.9	270	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	6.6	32.7	25.6	32.2	25.7	31.8	25.8	27.2	30.8	26.9	30.5	26.7	30.3	4.1	80

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.6	29.0	25.8	21.2	28.8	25.6	21.0	28.6	85.6	31.1	84.6	30.8	83.6	30.5	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.2	5.4	DB	21.6	33.9	0.8	0.9	21.0	34.6	20.6	35.1	20.1	35.6	19.6	36.3	(4)
			WB	21.1	28.3	0.6	1.3	20.6	29.2	20.3	30.0	19.9	30.7	19.5	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	26.8	26.9	27.3	27.7	28.0	27.9	27.6	27.8	28.0	28.0	27.5	27.0	
	DBStd	1.00	0.87	0.82	0.87	0.85	0.97	0.96	0.96	0.82	0.84	0.97	0.95	1.02	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	6404	522	473	536	530	559	536	546	552	539	558	527	526	
	CDD18.3	3363	263	240	277	280	301	286	287	294	289	300	277	268	
	CDH23.3	32328	2217	2037	2458	2616	3108	2937	2899	3072	3050	3111	2573	2249	
	CDH26.7	9888	518	521	697	783	1016	948	918	1036	1091	1077	764	520	
Wind	WSAvg	1.9	1.6	1.8	1.5	1.2	1.7	1.9	2.5	2.9	2.7	1.9	1.2	1.3	
Precipitation	PrecAvg	2710	315	260	246	252	237	178	141	119	131	178	272	358	
	PrecMax	3853	885	723	374	580	506	563	429	480	392	442	522	702	
	PrecMin	1611	53	44	17	42	44	57	3	0	0	9	132	112	
	PrecStd	647	191	172	88	121	110	111	104	110	97	121	92	133	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.6	31.9	32.6	32.7	32.7	32.5	32.1	32.3	33.2	33.3	32.9	32.2	
		MCWB	25.7	25.8	26.3	26.0	26.5	26.2	25.8	25.4	24.6	24.9	25.3	26.1	
	2%	DB	30.8	31.0	31.6	31.8	32.1	31.9	31.5	31.7	32.4	32.4	32.1	31.2	
		MCWB	25.6	25.8	26.1	26.3	26.6	26.3	25.8	25.4	24.9	25.3	25.7	26.0	
	5%	DB	30.1	30.3	30.9	31.2	31.6	31.4	31.0	31.2	31.7	31.8	31.3	30.2	
		MCWB	25.6	25.6	26.0	26.2	26.5	26.2	25.7	25.3	25.0	25.4	25.7	25.8	
	10%	DB	29.3	29.6	30.2	30.5	31.0	30.9	30.6	30.8	31.2	31.2	30.5	29.4	
		MCWB	25.3	25.4	25.8	26.1	26.4	26.0	25.5	25.3	25.1	25.4	25.7	25.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.7	26.8	27.2	27.2	27.6	27.2	26.9	26.7	26.7	26.7	26.8	26.7
			MCDB	29.7	30.2	31.0	30.6	31.3	31.0	31.0	30.7	30.6	30.8	30.7	30.2
2%		WB	26.3	26.4	26.7	26.8	27.1	26.9	26.5	26.3	26.2	26.4	26.4	26.4	
		MCDB	29.2	29.7	30.4	30.3	30.8	30.7	30.4	30.3	30.3	30.4	30.3	29.7	
5%		WB	26.0	26.1	26.4	26.6	26.8	26.6	26.1	26.0	25.9	26.1	26.1	26.1	
		MCDB	28.9	29.3	29.9	29.9	30.3	30.2	30.0	30.0	30.1	30.2	29.9	29.3	
10%		WB	25.6	25.7	26.1	26.3	26.6	26.3	25.8	25.6	25.6	25.7	25.8	25.7	
		MCDB	28.3	28.6	29.3	29.4	29.9	29.8	29.5	29.5	29.6	29.6	29.3	28.6	
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.8	6.3	6.3	6.0	5.9	5.9	6.1	6.6	6.6	6.3	5.5	
		MCDBR	6.4	6.7	7.1	6.9	6.7	6.5	6.3	6.7	7.4	7.3	7.4	6.6	
		MCWBR	2.4	2.4	2.8	2.7	2.5	2.4	2.3	2.3	2.4	2.3	2.6	2.6	
	5% WB	MCDBR	5.7	6.0	6.5	6.4	6.2	6.2	6.0	6.2	6.5	6.6	6.5	5.9	
		MCWBR	2.4	2.5	2.8	2.8	2.6	2.6	2.5	2.4	2.6	2.5	2.6	2.6	
Clear-Sky Solar Irradiance	taub	0.445	0.466	0.455	0.426	0.431	0.437	0.442	0.476	0.534	0.556	0.473	0.431		
	taud	2.391	2.309	2.341	2.427	2.422	2.416	2.394	2.272	2.082	2.024	2.282	2.424		
	Ebn at Noon	891	874	874	877	848	829	831	822	795	787	858	898		
	Edh at Noon	126	138	133	118	114	112	116	136	169	181	139	121		
All-Sky Solar Radiation	RadAvg	4.43	4.92	5.09	4.84	4.68	4.53	4.75	5.16	5.11	4.64	4.25	3.93		
	RadStd	0.26	0.35	0.27	0.23	0.23	0.36	0.32	0.33	0.34	0.31	0.22	0.26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page