

TANJUNG PANDAN BULUH TUMBANG, Indonesia

WMO: 962490

Lat: 2.7525S

Lon: 107.7530E

Elev: 144

StdP: 14.62

Time Zone: 7.00 (E07)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	72.1	72.8	66.7	98.8	88.6	68.4	104.9	85.8	18.6	83.3	14.1	82.9	1.4	170	0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	15.0	91.6	76.1	90.6	76.7	89.7	77.2	80.5	86.5	80.0	85.8	79.6	85.4	12.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.1	83.3	78.3	147.9	82.6	78.0	146.4	82.3	44.2	86.7	43.7	86.3	43.3	85.7	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	17.5	14.5	DB	69.3	94.1	1.7	1.6	68.1	95.3	67.1	96.3	66.2	97.2	65.0	98.4
			WB	67.5	82.5	2.0	1.5	66.1	83.6	64.9	84.4	63.8	85.3	62.4	86.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	80.8	79.9	80.2	80.8	80.8	81.5	81.4	81.0	81.4	81.7	81.1	80.2	79.7
	DBStd	1.79	1.49	1.54	1.48	1.50	1.72	1.83	1.80	1.78	1.80	1.85	1.51	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11242	927	846	953	925	975	941	961	975	952	963	905	919
	CDD65	5767	462	426	488	475	510	491	496	510	502	498	455	454
	CDH74	49637	3872	3556	4237	3827	4537	4399	4447	4771	4746	4174	3421	3650
	CDH80	14700	766	821	1139	1001	1395	1427	1525	1782	1873	1415	834	722
(14) Wind	WSAvg	4.6	5.8	5.7	4.1	2.9	3.6	4.3	5.2	6.8	5.9	3.7	2.7	4.2
(15) Precipitation	PrecAvg	128.0	11.6	7.4	10.1	13.9	12.4	8.4	6.0	4.8	5.0	12.4	16.9	18.8
	PrecMax	166.5	26.0	19.8	18.0	18.5	23.6	21.7	18.0	14.3	15.9	24.1	30.5	36.6
	PrecMin	80.2	1.4	0.0	4.6	7.9	4.1	0.8	0.1	0.0	0.0	1.7	6.6	9.8
	PrecStd	24.3	5.1	4.7	3.7	3.2	5.4	4.9	5.0	4.6	4.7	6.5	5.7	6.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	88.5	89.6	90.0	90.9	91.1	90.8	91.7	93.3	93.3	90.1	87.9
		MCWB	78.4	77.7	77.9	79.1	78.8	78.4	77.6	76.0	74.5	74.7	78.1	78.7
	2%	DB	86.1	86.9	88.1	88.6	89.8	89.8	89.5	90.4	91.6	91.3	88.0	86.3
		MCWB	78.2	77.5	78.0	79.1	79.0	78.2	77.3	76.1	75.1	75.7	78.4	78.5
	5%	DB	85.0	85.8	86.9	87.2	88.7	88.8	88.5	89.4	90.5	89.7	86.5	85.2
		MCWB	77.9	77.5	78.0	79.0	79.0	78.2	77.1	76.2	75.6	76.9	78.3	78.3
	10%	DB	84.0	84.7	85.7	85.7	87.2	87.6	87.3	88.3	89.2	87.4	84.9	84.0
		MCWB	77.6	77.3	77.9	78.8	79.0	78.2	77.0	76.1	76.0	77.5	78.2	78.1
	0.4%	WB	79.8	79.8	80.1	80.9	81.2	80.7	79.9	79.6	79.6	80.1	80.1	80.1
		MCDB	84.7	84.9	85.3	86.4	87.2	87.1	86.9	86.4	87.0	86.9	85.7	84.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	79.1	79.0	79.4	80.1	80.5	79.9	79.1	78.6	78.6	79.2	79.5	79.3
		MCDB	83.8	84.0	84.6	85.6	86.7	86.3	86.2	85.8	85.9	85.7	84.9	83.9
	5%	WB	78.6	78.4	78.9	79.6	79.9	79.3	78.3	78.0	77.9	78.7	79.0	78.9
		MCDB	83.2	83.2	84.3	84.9	85.9	85.6	85.2	85.1	85.0	84.7	84.3	83.4
	10%	WB	78.1	77.9	78.3	79.0	79.2	78.8	77.8	77.3	77.2	78.0	78.4	78.4
		MCDB	82.3	82.5	83.3	84.1	85.0	85.0	84.3	84.3	84.1	83.6	83.2	82.4
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	9.7	11.0	11.4	12.0	12.3	13.0	14.0	15.0	13.7	11.2	9.0
		MCDBR	10.1	11.2	12.5	13.0	14.1	14.3	14.6	15.8	17.6	17.3	13.1	10.7
		MCWBR	3.7	3.8	4.2	5.0	5.2	4.9	4.5	4.3	4.4	5.1	5.2	4.4
	5% WB	MCDWR	9.5	10.1	11.1	11.8	12.3	12.6	12.8	13.3	13.8	13.1	11.7	9.6
		MCWBR	4.2	4.1	4.5	5.2	5.5	5.2	4.9	4.8	4.9	5.5	5.2	4.5
(40) Clear-Sky Solar Irradiance	taub		0.435	0.452	0.442	0.419	0.423	0.430	0.437	0.462	0.515	0.541	0.469	0.424
	taud		2.426	2.357	2.388	2.456	2.460	2.456	2.424	2.324	2.142	2.077	2.298	2.449
	Ebn at Noon		286	281	281	280	271	265	265	265	257	254	274	287
	Edh at Noon		39	42	40	36	35	34	36	41	50	55	43	37
(44) All-Sky Solar Radiation	RadAvg		1457	1623	1654	1535	1507	1465	1552	1706	1704	1532	1370	1266
(45)	RadStd		102	142	109	69	94	109	119	120	124	139	89	121

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page