

TANJUNG KARANG RADIN INTEN II, Indonesia

WMO: 962950

Lat: 5.2397S

Lon: 105.1745E

Elev: 88

StdP: 100.27

Time Zone: 7.00 (E07)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.6	(c) 22.2	(d) 17.6	(e) 12.7	(f) 28.9	(g) 18.7	(h) 13.7	(i) 28.2	(j) 8.1	(k) 28.7	(l) 7.4	(m) 28.6	(n) 1.0	(o) 230	(p) 0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.2	34.3	24.1	33.5	24.5	32.9	24.8	26.7	30.8	26.5	30.6	26.2	30.3	4.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.2	28.6	25.4	20.8	28.4	25.1	20.5	28.2	84.4	31.0	83.2	30.9	82.2	30.5	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.1	(b) 6.2	(c) 5.4	(e) 20.5	(f) 35.4	(g) 0.9	(h) 1.1	(i) 19.8	(j) 36.1	(k) 19.3	(l) 36.8	(m) 18.8	(n) 37.4	(o) 18.1	(p) 38.2		
(a) 7.1	(b) 6.2	(c) 5.4	(e) 19.1	(f) 28.0	(g) 1.1	(h) 1.5	(i) 18.2	(j) 29.1	(k) 17.6	(l) 29.9	(m) 16.9	(n) 30.8	(o) 16.1	(p) 31.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	27.2	27.3	27.6	27.9	27.9	27.4	27.0	27.2	27.8	28.4	28.1	27.7		
	DBStd	0.95	0.87	0.83	0.74	0.86	0.82	0.91	0.74	0.83	0.86	0.90	1.08	0.88		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6438	533	484	546	538	556	523	527	534	534	572	543	549		
	CDD18.3	3397	274	251	288	288	297	273	269	276	284	313	293	291		
	CDH23.3	32629	2391	2213	2637	2794	3012	2617	2489	2673	2891	3324	2901	2687		
	CDH26.7	11794	692	669	887	992	1084	909	866	1033	1233	1456	1091	882		
(14) Wind	WSAvg	1.7	1.6	1.7	1.4	1.4	1.5	1.5	1.7	2.1	2.2	2.0	1.5	1.5		
(15) Precipitation	PrecAvg	2185	326	297	301	191	137	96	92	74	75	99	191	306		
	PrecMax	3181	548	425	664	325	285	327	259	280	198	259	372	576		
	PrecMin	1484	166	170	170	80	51	9	2	0	0	0	51	144		
	PrecStd	372	92	66	107	56	55	70	62	69	63	66	86	107		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	32.5	32.9	33.5	33.2	32.8	32.6	33.3	34.6	35.7	35.1	33.3		
		MCWB	25.6	25.9	25.7	25.8	25.7	25.7	24.5	24.1	23.3	22.8	24.6	25.3		
	2%	DB	31.7	31.8	32.2	32.7	32.6	32.2	32.0	32.7	33.7	34.6	33.9	32.4		
		MCWB	25.5	25.7	25.7	25.8	25.6	25.5	24.7	24.2	23.8	23.7	24.8	25.3		
	5%	DB	30.8	31.1	31.6	32.0	32.0	31.7	31.4	32.1	33.0	33.6	32.7	31.6		
		MCWB	25.3	25.6	25.7	25.9	25.7	25.4	24.7	24.1	24.1	24.1	25.0	25.3		
	10%	DB	30.0	30.3	30.8	31.2	31.3	31.0	30.7	31.3	32.3	32.7	31.7	30.8		
		MCWB	25.2	25.4	25.5	25.7	25.7	25.4	24.6	24.2	24.2	24.5	25.1	25.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	26.7	27.0	27.1	27.2	26.7	26.2	26.1	26.0	26.1	26.4	26.6		
		MCDB	30.6	30.7	31.1	31.0	31.0	30.9	30.3	30.3	30.7	31.3	31.0	30.5		
	2%	WB	26.1	26.2	26.5	26.6	26.7	26.3	25.8	25.6	25.5	25.6	26.0	26.1		
		MCDB	29.9	30.2	30.5	30.6	30.7	30.4	30.0	30.0	30.3	30.8	30.6	30.4		
	5%	WB	25.7	26.0	26.1	26.3	26.3	26.1	25.5	25.2	25.2	25.4	25.7	25.7		
		MCDB	29.3	29.8	30.1	30.3	30.3	30.1	29.5	29.6	30.1	30.4	30.1	29.9		
	10%	WB	25.5	25.6	25.7	26.0	26.1	25.7	25.2	24.8	24.8	25.1	25.4	25.5		
		MCDB	28.9	29.2	29.5	30.1	29.9	29.5	29.1	29.2	29.7	30.1	29.8	29.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.4	6.7	7.2	7.3	7.3	7.4	7.9	8.8	9.3	9.2	7.8	6.9		
		MCDBR	7.3	7.4	8.0	8.2	8.2	8.3	8.9	9.7	10.4	10.8	9.5	7.9		
		MCWBR	2.6	2.6	2.8	2.8	2.8	3.0	3.1	3.2	3.1	2.9	2.6	2.5		
	5% WB	MCDBR	6.8	6.9	7.3	7.4	7.2	7.3	7.6	8.2	8.7	8.7	7.7	7.1		
		MCWBR	2.6	2.6	2.9	2.8	2.8	2.9	3.0	3.0	3.0	2.7	2.7	2.6		
(40) Clear-Sky Solar Irradiance	taub		0.447	0.476	0.467	0.467	0.488	0.497	0.530	0.557	0.586	0.599	0.542	0.462		
	taud		2.336	2.251	2.279	2.282	2.207	2.169	2.057	1.967	1.888	1.859	2.033	2.297		
	Ebn at Noon		892	867	863	838	791	768	748	752	754	756	803	875		
	Edh at Noon		134	147	141	135	139	142	161	183	205	214	180	138		
(44) All-Sky Solar Radiation	RadAvg		4.92	4.90	5.21	5.08	4.76	4.46	4.62	5.13	5.39	5.23	4.90	4.74		
	RadStd		0.31	0.31	0.25	0.24	0.24	0.29	0.35	0.26	0.30	0.34	0.23	0.20		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page