

TARAKAN, Indonesia

WMO: 965090

Lat: 3.3271N

Lon: 117.5700E

Elev: 20

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.9	74.5	71.0	114.2	79.9	71.9	117.9	79.5	14.4	78.2	12.0	81.3	3.4	310	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.3	90.5	79.7	89.8	79.5	89.2	79.4	81.5	87.6	81.0	87.0	80.7	86.7	5.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.8	154.5	85.0	79.2	151.6	84.4	79.0	150.3	84.1	45.2	88.3	44.7	87.7	44.3	87.2	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	9.9	8.7	DB	71.0	93.2	1.9	2.6	69.6	95.1	68.5	96.5	67.5	98.0	66.1	99.8	(4)
(5)			WB	69.7	83.7	1.7	1.5	68.5	84.8	67.5	85.7	66.6	86.5	65.4	87.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.9	81.2	81.6	81.7	82.1	82.5	82.1	81.8	82.2	82.3	82.1	82.0	81.7	(6)
(7)		DBStd	1.73	1.75	1.63	1.79	1.57	1.51	1.79	1.74	1.86	1.72	1.72	1.47	1.68	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11661	967	885	983	963	1009	964	986	999	968	994	959	984	(10)
(11)		CDD65	6186	502	465	518	513	544	514	521	534	518	529	509	519	(11)
(12)		CDH74	65666	4929	4745	5442	5535	6046	5574	5524	5802	5623	5671	5414	5361	(12)
(13)		CDH80	20665	1343	1378	1630	1750	2026	1809	1752	1945	1902	1873	1666	1591	(13)
(14)	Wind	WSAvg	2.7	2.7	3.1	2.8	2.4	2.4	2.6	2.9	3.3	2.9	2.5	2.5	2.4	(14)
(15)	Precipitation	PrecAvg	130.7	10.2	9.4	11.2	12.6	12.3	10.2	10.4	10.9	10.4	13.5	12.9	13.8	(15)
(16)		PrecMax	185.9	20.4	16.9	20.5	20.4	29.7	19.0	22.6	23.7	21.3	26.3	23.3	23.1	(16)
(17)		PrecMin	69.1	2.2	1.8	1.3	0.4	1.9	1.9	0.2	1.0	1.2	5.4	0.5	2.6	(17)
(18)		PrecStd	32.1	4.8	4.6	3.8	5.2	6.4	4.4	5.4	5.8	4.3	5.0	6.3	4.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.7	89.9	90.1	90.0	90.9	90.5	90.0	90.8	91.2	91.2	90.4	90.1	(19)
(20)			MCWB	78.8	78.2	77.9	79.8	80.4	80.3	79.6	79.8	79.7	79.8	79.9	80.1	(20)
(21)		2%	DB	88.2	88.6	88.9	89.1	89.5	89.4	89.0	89.5	89.7	89.6	89.1	88.9	(21)
(22)			MCWB	78.7	78.1	78.3	79.8	80.1	80.1	79.4	79.3	79.3	79.5	79.8	79.8	(22)
(23)		5%	DB	87.3	87.6	87.8	88.1	88.5	88.2	87.9	88.4	88.6	88.4	88.0	87.8	(23)
(24)			MCWB	78.6	78.1	78.6	79.6	80.0	79.9	79.3	79.1	79.2	79.5	79.7	79.5	(24)
(25)		10%	DB	86.1	86.4	86.7	87.1	87.5	87.1	86.9	87.3	87.5	87.3	86.9	86.6	(25)
(26)			MCWB	78.3	78.1	78.6	79.4	79.8	79.6	79.1	78.9	79.1	79.3	79.4	79.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.6	80.2	80.9	81.5	81.9	81.9	81.0	81.0	81.6	81.7	81.5	81.1	(27)
(28)			MCD B	87.1	86.2	86.8	87.7	87.7	87.7	87.0	87.7	88.1	87.7	87.6	87.4	(28)
(29)		2%	WB	79.8	79.6	80.0	80.7	81.1	81.0	80.3	80.2	80.7	80.8	80.7	80.5	(29)
(30)			MCD B	85.8	85.5	85.8	86.8	86.9	86.8	86.2	86.4	87.0	87.1	87.0	86.8	(30)
(31)		5%	WB	79.2	79.1	79.5	80.1	80.7	80.5	79.9	79.8	80.0	80.1	80.1	80.0	(31)
(32)			MCD B	84.8	84.8	85.1	85.8	86.4	86.2	85.7	85.9	86.1	86.1	86.0	85.8	(32)
(33)		10%	WB	78.8	78.6	79.0	79.7	80.1	80.0	79.4	79.3	79.6	79.6	79.7	79.5	(33)
(34)			MCD B	84.2	84.1	84.4	85.2	85.5	85.3	85.0	85.1	85.4	85.4	85.2	85.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	9.9	9.8	10.0	10.3	10.2	10.5	10.8	11.2	11.0	10.1	10.0	(35)
(36)			MCDBR	11.6	11.4	11.5	11.4	11.6	11.5	11.7	11.8	12.4	12.5	11.7	11.6	(36)
(37)			MCWBR	4.0	3.8	4.0	4.3	4.4	4.4	4.7	4.6	4.9	4.9	4.6	4.5	(37)
(38)		5% WB	MCD BR	10.5	10.3	10.4	10.5	10.7	10.9	11.1	11.3	11.7	11.6	10.8	10.9	(38)
(39)			MCWBR	4.3	4.1	4.3	4.4	4.5	4.7	4.9	4.9	5.1	5.1	4.6	4.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.398	0.407	0.408	0.410	0.399	0.400	0.404	0.454	0.480	0.505	0.415	0.397	(40)	
(41)		taud	2.553	2.504	2.504	2.492	2.542	2.537	2.518	2.350	2.270	2.199	2.482	2.557	(41)	
(42)		Ebn at Noon	294	292	291	285	281	277	277	268	266	261	286	292	(42)	
(43)		Edh at Noon	33	36	36	35	33	32	33	40	44	48	36	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1420	1623	1597	1663	1626	1526	1564	1670	1663	1574	1511	1458	(44)	
(45)		RadStd	105	142	147	123	86	70	116	81	103	108	89	98	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	+0.31	N/A	N/A	+0.65	+0.85	+0.76	N/A	N/A	+218	+218	(47)

Nomenclature: See separate page