

SUSILO, Indonesia

WMO: 965590

Lat: 0.0657N

Lon: 111.4770E

Elev: 98

StdP: 14.64

Time Zone: 7.00 (E07)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.8	72.4	69.4	108.4	79.9	70.6	113.0	78.6	16.3	79.6	12.0	79.8	1.9	N/A	0.288

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	15.0	94.1	80.9	93.2	80.8	92.3	80.6	84.1	91.5	83.4	90.5	82.6	89.5	4.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.0	167.4	90.0	81.3	163.5	89.1	80.7	159.9	88.3	48.4	91.7	47.5	90.8	46.7	89.8	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.6	8.6	7.4	65.6	96.2	6.2	1.0	61.1	97.0	57.4	97.6	53.9	98.1	49.4	98.9
			68.0	84.3	4.6	1.9	64.7	85.6	62.0	86.7	59.4	87.8	56.0	89.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.1	81.2	81.5	82.1	82.6	83.1	82.7	82.2	82.3	82.4	82.0	81.9	81.4
	DBStd	1.99	1.79	1.96	1.93	2.08	1.85	2.18	2.19	1.96	1.91	1.79	1.58	1.64
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11720	966	882	995	979	1025	981	1000	1002	971	990	956	973
	CDD65	6245	501	462	530	529	560	531	535	537	521	525	506	508
	CDH74	59059	4294	4173	4917	5090	5693	5355	5262	5356	5183	4874	4569	4293
	CDH80	23380	1519	1528	1907	2054	2321	2229	2228	2257	2150	1906	1720	1561
(14) Wind	WSAvg	2.2	2.2	2.1	2.2	2.2	2.0	2.2	2.4	2.5	2.3	2.2	2.4	2.3
(15) Precipitation	PrecAvg	127.1	11.7	10.5	11.2	11.5	9.8	7.9	8.7	7.5	8.9	12.2	13.0	14.1
	PrecMax	180.1	19.1	23.2	19.6	21.5	16.7	14.5	25.9	19.6	16.0	25.9	19.4	31.5
	PrecMin	87.7	4.4	3.7	2.8	7.2	3.7	1.0	0.6	1.4	1.7	0.7	8.8	7.9
	PrecStd	20.4	4.0	5.1	3.9	3.2	3.4	3.3	5.8	5.0	4.1	4.8	2.6	5.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.3	93.2	93.8	94.3	94.7	94.8	95.1	94.6	94.2	93.3	92.7	92.5
		MCWB	80.4	80.0	80.7	80.8	81.6	80.8	81.7	79.5	80.4	80.4	81.2	81.7
	2%	DB	90.7	91.4	92.1	92.7	93.2	92.9	93.2	92.7	92.6	91.7	91.3	90.7
		MCWB	80.0	79.9	80.6	80.7	81.1	80.9	81.0	80.2	80.2	80.6	80.6	80.7
	5%	DB	89.2	89.8	90.5	91.4	91.8	91.6	91.5	91.4	91.4	90.4	90.0	89.2
		MCWB	79.7	79.6	80.4	80.6	80.8	80.6	79.9	79.8	79.9	80.4	80.5	79.8
	10%	DB	87.5	88.0	88.8	89.7	90.0	90.0	89.7	89.9	89.8	88.9	88.4	87.6
		MCWB	79.2	79.3	80.0	80.3	80.5	80.3	79.2	79.4	79.6	80.0	80.0	79.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.2	83.2	84.0	84.4	85.0	84.5	84.8	83.9	83.8	83.6	83.9	83.5
		MCDB	89.9	90.0	91.2	91.8	92.3	92.0	92.8	91.7	91.6	90.6	90.8	90.5
	2%	WB	81.7	81.7	82.6	82.9	83.2	83.2	83.0	82.8	82.6	82.6	82.8	81.9
		MCDB	88.2	88.4	89.0	89.8	90.0	90.1	90.3	90.3	90.1	89.3	89.2	88.6
	5%	WB	80.5	80.6	81.5	81.7	81.9	81.8	81.4	81.4	81.4	81.6	81.6	80.8
		MCDB	86.9	87.4	88.0	88.6	88.7	88.6	88.4	88.5	88.6	88.2	87.8	87.1
	10%	WB	79.5	79.7	80.3	80.5	80.8	80.5	79.9	79.9	80.1	80.2	80.2	79.7
		MCDB	85.8	86.1	86.9	87.7	88.1	87.9	87.3	87.0	87.1	86.6	86.2	86.0
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.4	14.9	15.3	15.0	15.4	16.0	15.8	15.6	15.0	14.7	14.2
		MCDBR	15.9	16.7	17.0	17.4	17.3	17.2	18.0	17.7	17.7	16.8	16.5	15.7
		MCWBR	6.6	6.6	6.8	6.6	6.6	6.7	6.9	7.0	7.0	6.9	7.1	6.4
	5% WB	MCDBR	14.6	15.1	15.8	16.0	15.8	16.1	16.7	16.4	15.8	15.4	15.2	14.8
		MCWBR	7.0	7.2	7.7	7.7	7.5	7.7	8.2	8.2	8.1	7.9	8.1	7.2
(40) Clear-Sky Solar Irradiance	taub		0.402	0.425	0.425	0.404	0.404	0.402	0.423	0.518	0.629	0.610	0.448	0.400
	taud		2.477	2.387	2.385	2.453	2.457	2.464	2.393	2.109	1.809	1.850	2.330	2.485
	Ebn at Noon		294	288	286	285	278	274	270	251	229	236	278	293
	Edh at Noon		36	40	40	36	35	34	37	51	70	68	42	36
(44) All-Sky Solar Radiation	RadAvg		1485	1531	1597	1596	1561	1547	1563	1584	1492	1473	1500	1494
	RadStd		81	64	69	56	70	81	78	83	155	180	79	44

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page