

PONTIANAK SUPADIO, Indonesia

WMO: 965810

Lat: 0.1421S

Lon: 109.4025E

Elev: 10

StdP: 14.69

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	72.5	73.1	68.6	105.0	86.0	70.0	110.5	84.3	18.3	82.6	15.2	84.7	1.3	60	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.8	93.4	79.0	92.8	79.0	91.7	78.9	81.7	89.1	81.0	88.4	80.7	88.0	5.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.3	85.6	79.1	151.2	84.8	78.8	149.7	84.4	45.5	89.7	44.8	89.0	44.3	88.6	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.9	11.7	9.9	70.3	96.0	1.4	1.6	69.3	97.1	68.5	98.1	67.7	99.0	66.7	100.2		
(5)			69.2	84.7	1.6	2.1	68.1	86.2	67.1	87.5	66.2	88.7	65.0	90.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	81.6	81.8	82.5	82.8	83.1	82.8	82.2	82.5	82.5	82.0	81.7	81.4
	DBStd	1.75	1.68	1.60	1.62	1.56	1.65	1.75	1.83	1.72	1.81	1.60	1.52	1.59
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11770	978	890	1009	985	1026	984	998	1009	976	991	952	972
	CDD65	6295	513	470	544	535	561	534	533	544	526	526	502	507
	CDH74	57421	4455	4087	4966	5046	5468	5269	5045	5226	4884	4487	4231	4257
	CDH80	21038	1507	1427	1825	1856	2100	2100	2013	2107	1893	1548	1344	1318
(14) Wind	WSAvg	3.1	3.4	3.3	3.0	2.8	2.6	2.9	3.2	3.5	3.2	2.7	2.9	3.2
(15) Precipitation	PrecAvg	126.4	11.4	8.3	10.1	11.2	10.6	8.7	7.8	7.0	10.7	12.3	15.8	11.9
	PrecMax	193.4	22.9	21.6	23.5	20.9	22.7	25.6	19.7	25.0	22.9	23.2	28.5	22.3
	PrecMin	94.6	2.0	0.7	2.0	5.7	2.5	3.8	0.2	0.2	0.4	2.8	8.1	4.3
	PrecStd	19.2	5.7	4.6	5.5	3.8	5.0	4.1	4.6	5.4	5.7	5.4	4.8	4.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.7	93.0	93.4	93.5	93.6	93.6	93.4	93.6	93.5	93.1	91.8	91.6
		MCWB	78.7	78.3	78.9	79.9	79.9	79.1	78.7	78.3	78.3	79.0	79.2	79.1
	2%	DB	90.7	91.3	91.7	91.8	92.8	92.5	91.8	92.3	92.3	91.4	90.2	89.9
		MCWB	78.7	78.4	78.9	79.6	80.0	79.1	78.6	78.2	78.3	79.2	79.2	79.0
	5%	DB	89.3	89.7	90.7	90.8	91.4	91.3	90.9	91.2	91.2	89.8	89.2	88.3
		MCWB	78.6	78.4	78.8	79.5	80.0	79.2	78.5	78.2	78.3	79.1	79.2	79.2
	10%	DB	87.6	87.9	89.2	89.2	89.7	89.8	89.4	89.7	89.6	87.9	87.4	87.0
		MCWB	78.7	78.4	78.8	79.6	79.9	79.0	78.2	78.0	78.5	79.2	79.2	79.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.1	81.0	81.7	81.8	82.3	81.7	81.6	81.5	81.9	82.2	81.2	81.3
		MCDB	88.0	88.3	89.1	89.0	89.7	88.8	89.1	90.1	90.0	89.2	87.8	87.8
	2%	WB	80.0	80.0	80.5	81.0	81.4	80.8	80.4	80.1	80.6	80.6	80.3	80.1
		MCDB	86.7	87.1	88.0	88.3	88.8	88.2	88.0	88.1	88.5	87.6	86.8	86.3
	5%	WB	79.5	79.4	79.8	80.4	80.8	80.1	79.8	79.6	79.8	79.9	79.8	79.7
		MCDB	86.0	86.2	87.0	87.6	88.2	87.4	87.2	87.3	87.3	86.6	86.1	85.7
	10%	WB	78.9	78.9	79.2	79.8	80.2	79.7	79.1	78.9	79.1	79.3	79.2	79.1
		MCDB	85.4	85.4	86.1	86.6	87.1	86.8	86.4	86.4	86.3	85.8	85.3	84.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.8	14.5	14.8	14.5	14.8	15.0	15.1	15.4	15.1	14.2	13.4	13.0
		MCDBR	15.6	16.3	16.4	16.3	16.6	16.5	16.6	16.9	16.9	16.1	15.2	14.7
		MCWBR	5.7	5.9	5.5	5.8	6.2	5.7	5.6	5.4	5.8	6.2	5.8	5.7
		MCDBR	14.1	14.8	15.1	14.8	15.3	15.6	15.6	15.5	15.5	14.6	14.0	13.5
	5% WB	MCWBR	5.8	5.9	5.8	5.9	6.2	6.0	6.2	6.0	6.1	6.3	5.8	5.9
(40) Clear-Sky Solar Irradiance	taub		0.419	0.443	0.440	0.416	0.417	0.418	0.435	0.531	0.626	0.624	0.465	0.417
	taud		2.441	2.353	2.360	2.428	2.434	2.436	2.381	2.083	1.828	1.825	2.297	2.458
	Ebn at Noon		289	283	281	282	274	270	266	247	230	233	273	288
	Edh at Noon		38	42	41	37	36	35	37	52	69	70	43	37
(44) All-Sky Solar Radiation	RadAvg		1532	1630	1697	1663	1628	1598	1632	1665	1556	1463	1466	1434
	RadStd		97	87	82	54	63	63	85	72	161	166	71	73

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page