

PONTIANAK SUPADIO, Indonesia

WMO: 965810

Lat: 0.1421S

Lon: 109.4025E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.5	22.8	20.3	15.0	30.0	21.1	15.8	29.0	8.2	28.1	6.8	29.3	0.6	60	0.296

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	8.2	34.1	26.1	33.8	26.1	33.2	26.1	27.6	31.7	27.2	31.3	27.0	31.1	2.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.5	22.0	29.8	26.2	21.6	29.3	26.0	21.4	29.1	87.9	32.0	86.4	31.7	85.2	31.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 6.2	5.2	4.4	DB	21.3	35.5	0.8	0.9	20.7	36.2	20.3	36.7	19.8	37.2	19.3	37.9	(4)
(5)			WB	20.7	29.3	0.9	1.2	20.0	30.1	19.5	30.8	19.0	31.5	18.4	32.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	27.5	27.7	28.1	28.2	28.4	28.2	27.9	28.1	28.1	27.8	27.6	27.4	(6)
(7)		DBStd	0.97	0.94	0.89	0.90	0.86	0.92	0.97	1.02	0.95	1.01	0.89	0.84	0.88	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6539	543	494	561	547	570	547	554	561	542	551	529	540	(10)
(11)		CDD18.3	3497	285	261	302	297	312	297	296	302	292	292	279	282	(11)
(12)		CDH23.3	31901	2475	2271	2759	2803	3038	2927	2803	2903	2713	2493	2351	2365	(12)
(13)		CDH26.7	11688	837	793	1014	1031	1167	1167	1118	1171	1052	860	747	732	(13)
(14)	Wind	WSAvg	1.4	1.5	1.5	1.3	1.2	1.2	1.3	1.4	1.6	1.4	1.2	1.3	1.4	(14)
(15)	Precipitation	PrecAvg	3210	290	210	257	285	270	220	198	177	273	312	402	303	(15)
(16)		PrecMax	4912	582	548	596	532	576	649	500	635	582	589	723	567	(16)
(17)		PrecMin	2402	51	17	50	144	64	96	4	5	10	71	205	108	(17)
(18)		PrecStd	487	144	118	139	96	126	104	116	138	144	138	123	116	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	33.9	34.1	34.2	34.2	34.2	34.1	34.2	34.2	34.0	33.2	33.1	(19)
(20)		0.4%	MCWB	25.9	25.7	26.1	26.6	26.6	26.1	25.9	25.7	25.7	26.1	26.2	26.2	(20)
(21)		2%	DB	32.6	32.9	33.2	33.2	33.8	33.6	33.2	33.5	33.5	33.0	32.4	32.2	(21)
(22)		2%	MCWB	25.9	25.8	26.1	26.4	26.6	26.1	25.9	25.7	25.7	26.2	26.2	26.1	(22)
(23)		5%	DB	31.8	32.0	32.6	32.7	33.0	33.0	32.7	32.9	32.9	32.1	31.8	31.3	(23)
(24)		5%	MCWB	25.9	25.8	26.0	26.4	26.7	26.2	25.8	25.7	25.7	26.2	26.2	26.2	(24)
(25)		10%	DB	30.9	31.0	31.8	31.8	32.1	32.1	31.9	32.1	32.0	31.1	30.8	30.5	(25)
(26)		10%	MCWB	25.9	25.8	26.0	26.4	26.6	26.1	25.7	25.6	25.8	26.2	26.2	26.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.2	27.6	27.7	27.9	27.6	27.5	27.5	27.7	27.9	27.3	27.4	(27)
(28)		0.4%	MCDWB	31.1	31.3	31.7	31.7	32.1	31.6	31.7	32.3	32.2	31.8	31.0	31.0	(28)
(29)		2%	WB	26.7	26.7	26.9	27.2	27.4	27.1	26.9	26.7	27.0	27.0	26.8	26.7	(29)
(30)		2%	MCDWB	30.4	30.6	31.1	31.3	31.6	31.2	31.1	31.2	31.4	30.9	30.5	30.2	(30)
(31)		5%	WB	26.4	26.3	26.6	26.9	27.1	26.7	26.5	26.4	26.6	26.6	26.6	26.5	(31)
(32)		5%	MCDWB	30.0	30.1	30.6	30.9	31.2	30.8	30.7	30.7	30.7	30.4	30.1	29.8	(32)
(33)		10%	WB	26.1	26.0	26.2	26.6	26.8	26.5	26.2	26.1	26.2	26.3	26.2	26.2	(33)
(34)		10%	MCDWB	29.6	29.7	30.0	30.3	30.6	30.4	30.2	30.2	30.1	29.9	29.6	29.4	(34)
(35)	Mean Daily Temperature Range		MDBR	7.7	8.1	8.2	8.1	8.2	8.3	8.4	8.6	8.4	7.9	7.4	7.2	(35)
(36)		5% DB	MCDBR	8.7	9.1	9.1	9.1	9.2	9.2	9.2	9.4	9.4	9.0	8.5	8.2	(36)
(37)			MCWBR	3.2	3.3	3.1	3.2	3.5	3.1	3.1	3.0	3.2	3.4	3.2	3.2	(37)
(38)			MCDBR	7.8	8.2	8.4	8.2	8.5	8.5	8.7	8.7	8.6	8.1	7.8	7.5	(38)
(39)		5% WB	MCWBR	3.2	3.3	3.2	3.3	3.5	3.3	3.4	3.4	3.4	3.5	3.2	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.419	0.443	0.440	0.416	0.417	0.418	0.435	0.531	0.626	0.624	0.465	0.417	(40)	
(41)		taud	2.441	2.353	2.360	2.428	2.434	2.436	2.381	2.083	1.828	1.825	2.297	2.458	(41)	
(42)		Ebn at Noon	912	893	887	888	864	850	840	779	726	733	862	909	(42)	
(43)		Edh at Noon	119	132	130	118	113	111	118	165	218	220	136	116	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.83	5.14	5.35	5.24	5.13	5.04	5.14	5.25	4.90	4.61	4.62	4.52	(44)	
(45)		RadStd	0.30	0.27	0.26	0.17	0.20	0.20	0.27	0.23	0.51	0.52	0.22	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page