

SAMARINDA TEMINDUNG, Indonesia

WMO: 966070

Lat: 0.4826S

Lon: 117.1564E

Elev: 755

StdP: 14.30

Time Zone: 8.00 (E08)

Period: 03-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.9	74.5	70.4	115.0	84.5	71.2	118.5	82.8	14.3	85.4	12.3	85.5	1.7	N/A	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	11.3	92.8	78.8	91.9	78.8	91.0	78.7	80.9	88.5	80.4	88.1	80.0	87.4	7.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	154.8	84.1	78.4	151.5	83.5	78.1	150.3	83.3	45.2	88.9	44.7	88.6	44.2	88.0	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.0	9.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	82.1	82.7	82.9	82.7	82.8	82.0	81.6	82.2	82.7	82.5	82.6	82.5
	DBStd	1.95	1.95	2.28	2.18	2.05	1.78	1.78	1.66	1.63	1.89	1.83	1.95	1.87
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11839	994	915	1020	981	1017	961	979	999	981	1008	978	1006
	CDD65	6364	529	495	555	531	552	511	514	534	531	543	528	541
	CDH74	64531	5192	5135	5762	5397	5786	5097	4933	5362	5455	5598	5384	5430
CDH80	21035	1658	1832	2044	1765	1905	1531	1425	1669	1833	1860	1761	1752	
Wind	WSAvg	2.7	2.4	2.9	2.8	2.4	2.4	2.6	2.9	3.5	3.2	2.7	2.4	2.3
Precipitation	PrecAvg	89.7	7.9	6.9	9.2	10.4	8.1	6.9	6.2	4.7	5.4	6.4	8.6	8.9
	PrecMax	114.3	13.3	16.1	17.6	17.3	17.1	14.1	15.9	11.4	10.3	14.6	19.2	18.1
	PrecMin	58.8	0.0	0.0	0.1	4.6	0.9	1.2	0.9	0.0	0.0	0.0	1.7	3.9
	PrecStd	16.9	3.3	4.1	3.8	4.2	3.5	3.3	3.8	2.8	3.2	3.4	4.4	3.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.8	93.6	93.9	93.0	92.1	91.3	90.6	91.6	93.0	92.5	93.2	92.9
		MCWB	78.8	78.5	78.9	79.4	79.5	79.0	77.8	77.8	78.2	78.6	79.1	79.1
	2%	DB	90.9	92.1	92.1	91.4	90.6	89.8	89.0	89.9	91.1	90.8	91.3	91.1
		MCWB	78.6	78.8	78.7	79.4	79.2	78.7	77.8	77.7	78.0	78.6	79.0	79.0
	5%	DB	89.5	90.7	90.7	89.9	89.4	88.5	87.9	88.7	89.7	89.5	89.8	89.5
		MCWB	78.5	78.8	78.7	79.2	79.2	78.6	77.9	77.6	78.1	78.6	78.8	78.7
	10%	DB	87.8	89.1	89.1	88.3	88.1	87.1	86.7	87.4	88.2	88.1	87.9	87.7
		MCWB	78.4	78.5	78.5	79.0	79.1	78.5	77.7	77.5	77.9	78.5	78.6	78.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	80.9	80.8	81.5	81.4	81.0	80.1	80.0	80.6	81.0	80.8	80.9
		MCDB	88.8	89.1	90.0	89.4	88.2	87.7	86.4	87.1	89.0	88.4	89.4	88.8
	2%	WB	79.6	80.0	80.0	80.5	80.6	80.1	79.4	79.1	79.7	80.0	80.0	80.0
		MCDB	87.7	88.3	88.4	88.5	87.3	86.6	85.8	86.2	87.4	87.4	87.8	87.8
	5%	WB	79.1	79.3	79.3	79.9	80.0	79.5	78.8	78.6	79.0	79.3	79.4	79.4
		MCDB	86.6	87.3	87.1	87.1	86.3	85.6	85.3	85.4	86.4	86.2	86.7	86.3
	10%	WB	78.6	78.8	78.9	79.2	79.5	79.0	78.2	78.1	78.4	78.8	79.0	78.9
		MCDB	85.6	86.6	86.2	85.7	85.4	84.6	84.2	84.5	85.1	85.5	85.7	85.3
Mean Daily Temperature Range	5% DB	MDBR	11.7	12.3	12.2	11.6	11.3	10.7	10.7	11.2	12.0	12.1	11.6	11.7
		MCDBR	14.2	14.8	14.7	14.1	13.2	12.7	12.5	13.0	14.2	14.2	14.2	14.0
		MCWBR	4.3	4.3	4.1	4.6	4.0	4.0	3.8	3.5	3.8	4.3	4.1	4.4
	5% WB	MCDBR	12.5	13.4	12.8	12.3	11.9	11.2	11.1	11.5	12.2	12.6	12.3	12.6
		MCWBR	4.4	4.7	4.3	4.5	4.3	4.3	4.1	3.8	4.2	4.5	4.1	4.6
Clear-Sky Solar Irradiance	taub		0.390	0.399	0.401	0.396	0.395	0.397	0.403	0.455	0.494	0.525	0.438	0.396
	taud		2.518	2.483	2.470	2.488	2.504	2.507	2.485	2.311	2.187	2.085	2.366	2.506
	Ebn at Noon		298	296	292	287	280	276	276	267	263	257	281	295
	Edh at Noon		35	37	37	35	34	33	34	42	48	54	40	35
All-Sky Solar Radiation	RadAvg		1403	1573	1558	1526	1469	1381	1442	1526	1558	1495	1432	1417
	RadStd		94	179	123	98	55	76	121	124	108	108	65	94

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page