

KETAPANG RAHADI USMAN, Indonesia

WMO: 966150

Lat: 1.8174S

Lon: 109.9620E

Elev: 14

StdP: 101.16

Time Zone: 7.00 (E07)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	23.0	23.4	20.8	15.5	28.1	21.3	16.0	27.6	7.4	28.3	6.1	27.7	1.7	110	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.0	33.4	26.2	32.9	26.2	32.5	26.2	27.5	31.5	27.2	31.1	27.0	30.9	3.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.4	26.2	21.6	29.2	25.9	21.3	29.0	87.2	31.6	86.0	31.4	85.0	31.2	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 6.4	5.6	4.9	DB	20.6	35.3	2.2	1.7	19.1	36.5	17.8	37.5	16.6	38.4	15.0	39.6	(4)
(5)			WB	19.2	28.7	2.3	1.5	17.5	29.8	16.2	30.7	14.9	31.6	13.3	32.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.9	27.8	28.1	28.3	28.6	28.4	27.9	27.9	28.0	27.9	27.7	27.6	(6)
(7)		DBStd	0.92	0.98	0.84	0.85	0.80	0.84	0.92	0.99	0.85	0.88	0.88	0.79	0.90	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6578	554	499	563	549	576	553	555	556	539	554	532	546	(10)
(11)		CDD18.3	3537	296	266	304	299	318	303	297	298	289	296	282	288	(11)
(12)		CDH23.3	37301	3154	2819	3351	3311	3526	3312	3038	3039	2982	3056	2832	2881	(12)
(13)		CDH26.7	13262	991	909	1200	1235	1372	1294	1141	1163	1111	1088	905	853	(13)
(14)	Wind	WSAvg	2.0	1.9	1.8	1.4	1.4	1.8	2.2	2.6	3.0	2.7	1.8	1.5	1.6	(14)
(15)	Precipitation	PrecAvg	3254	347	248	263	311	238	199	151	97	160	301	447	472	(15)
(16)		PrecMax	4979	649	534	682	606	562	370	402	359	455	669	762	835	(16)
(17)		PrecMin	2191	104	77	40	134	33	51	6	0	11	31	187	249	(17)
(18)		PrecStd	626	168	118	137	119	127	98	121	107	117	166	161	157	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	32.5	32.9	33.5	34.1	33.8	33.6	33.5	33.4	33.2	32.7	32.2	(19)
(20)			MCWB	26.4	26.4	26.2	26.9	26.6	26.4	26.1	25.5	25.5	25.9	26.4	26.5	(20)
(21)		2%	DB	31.7	31.8	32.2	32.7	33.2	33.0	32.6	32.7	32.6	32.4	32.0	31.6	(21)
(22)			MCWB	26.3	26.1	26.3	26.7	26.7	26.3	25.9	25.5	25.5	26.0	26.3	26.3	(22)
(23)		5%	DB	31.1	31.2	31.7	32.1	32.6	32.4	32.0	32.0	32.0	31.8	31.4	31.0	(23)
(24)			MCWB	26.2	25.9	26.3	26.6	26.7	26.3	25.7	25.4	25.6	26.0	26.2	26.2	(24)
(25)		10%	DB	30.5	30.6	31.2	31.5	32.0	31.9	31.3	31.3	31.3	31.1	30.7	30.3	(25)
(26)			MCWB	26.0	25.8	26.1	26.5	26.6	26.2	25.6	25.3	25.5	25.9	26.1	26.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.2	27.5	27.7	27.6	27.3	27.0	26.9	27.1	27.2	27.2	(27)	
(28)			MADB	30.9	30.8	31.3	31.9	31.8	31.7	31.4	31.1	31.2	31.3	30.9	30.7	(28)
(29)		2%	WB	26.9	26.7	26.9	27.2	27.4	27.1	26.7	26.5	26.5	26.7	26.8	26.8	(29)
(30)			MADB	30.4	30.2	30.7	31.3	31.5	31.3	30.8	30.7	30.8	30.8	30.4	30.1	(30)
(31)		5%	WB	26.6	26.5	26.6	27.0	27.1	26.7	26.4	26.1	26.2	26.4	26.6	26.6	(31)
(32)			MADB	29.9	29.9	30.3	30.9	31.2	30.9	30.5	30.4	30.4	30.4	30.0	29.7	(32)
(33)		10%	WB	26.2	26.2	26.3	26.7	26.8	26.5	26.0	25.7	25.9	26.1	26.2	26.3	(33)
(34)			MADB	29.4	29.5	29.9	30.4	30.8	30.5	30.2	30.0	30.1	30.0	29.6	29.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	5.8	6.2	6.5	7.0	7.2	7.3	7.8	7.4	6.8	6.2	5.5	(35)
(36)			MCDBR	6.2	6.5	6.9	7.2	7.7	7.9	8.1	8.4	8.1	7.7	7.2	6.4	(36)
(37)			MCWBR	2.2	2.3	2.4	2.5	2.6	2.7	2.7	2.8	2.7	2.7	2.6	2.4	(37)
(38)		5% WB	MCDBR	5.8	6.1	6.5	6.8	7.2	7.4	7.5	7.8	7.5	7.1	6.6	5.9	(38)
(39)			MCWBR	2.3	2.4	2.4	2.6	2.8	2.8	2.7	2.9	2.8	2.7	2.6	2.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.422	0.444	0.435	0.413	0.415	0.416	0.436	0.518	0.651	0.664	0.504	0.418	(40)	
(41)		taud	2.464	2.382	2.408	2.482	2.481	2.486	2.419	2.145	1.778	1.755	2.197	2.477	(41)	
(42)		Ebn at Noon	911	893	892	890	863	849	837	788	708	705	830	911	(42)	
(43)		Edh at Noon	117	128	124	112	108	105	113	154	229	237	151	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.90	5.21	5.27	5.13	5.15	5.08	5.19	5.48	5.24	4.87	4.78	4.48	(44)	
(45)		RadStd	0.28	0.31	0.29	0.17	0.24	0.25	0.28	0.25	0.45	0.50	0.25	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page