

PANGKALAN BUN ISKANDAR, Indonesia

WMO: 966450

Lat: 2.7044S

Lon: 111.6700E

Elev: 82

StdP: 14.65

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	71.2	72.1	68.5	105.0	79.6	69.7	109.6	77.9	14.4	84.4	12.8	83.8	0.6	320	0.280

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	13.3	91.8	80.8	91.1	80.8	90.3	80.6	83.6	89.6	82.8	88.9	82.4	88.5	6.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.8	166.1	88.5	81.0	161.7	87.7	80.6	159.2	87.2	47.8	90.1	46.9	89.5	46.3	88.7	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.4	11.5	9.8	DB	67.3	94.7	3.3	1.6	64.9	95.8	63.0	96.8	61.2	97.7	58.8	98.8	(4)
(5)			WB	66.9	85.0	3.1	2.1	64.7	86.5	62.9	87.7	61.2	88.8	58.9	90.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	81.2	81.4	81.4	81.7	82.0	81.3	80.3	80.5	81.2	81.6	81.5	81.0	(6)
(7)		DBStd	1.71	1.62	1.78	1.69	1.56	1.73	1.82	1.61	1.64	1.51	1.48	1.56	1.77	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11413	968	880	974	950	991	940	941	946	937	980	945	961	(10)
(11)		CDD65	5938	503	460	509	500	526	490	476	481	487	515	495	496	(11)
(12)		CDH74	51723	4193	3930	4269	4410	4951	4496	4078	4205	4447	4630	4194	3920	(12)
(13)		CDH80	17663	1364	1362	1419	1510	1702	1533	1345	1475	1682	1663	1397	1211	(13)
(14)	Wind	WSAvg	2.8	2.7	2.6	2.3	2.3	2.6	2.8	3.3	3.8	3.8	2.8	2.4	2.6	(14)
(15)	Precipitation	PrecAvg	104.5	8.7	9.6	10.4	9.7	10.5	6.6	6.2	5.8	6.6	7.2	11.1	12.0	(15)
(16)		PrecMax	147.3	13.8	20.1	19.3	15.9	19.1	13.7	13.7	12.1	18.5	26.3	25.1	24.2	(16)
(17)		PrecMin	60.6	0.4	3.1	3.3	4.9	3.9	0.3	0.0	0.5	0.0	0.0	3.3	3.1	(17)
(18)		PrecStd	23.4	3.8	4.6	4.4	3.1	4.3	3.5	4.3	3.5	5.3	5.7	5.5	4.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	92.0	92.5	91.7	91.9	91.7	90.3	90.9	92.4	92.4	92.2	91.6	(19)
(20)			MCWB	80.6	80.8	80.7	81.6	81.9	82.3	80.9	79.8	77.9	81.0	80.8	81.1	(20)
(21)		2%	DB	90.1	90.6	90.6	90.5	90.7	90.1	89.0	89.5	90.7	90.8	90.6	89.9	(21)
(22)			MCWB	80.3	80.3	81.1	81.3	81.7	81.4	79.9	79.6	78.9	80.4	80.8	80.7	(22)
(23)		5%	DB	88.6	89.3	89.0	89.3	89.5	88.9	87.9	88.4	89.6	89.5	89.1	88.2	(23)
(24)			MCWB	79.9	80.0	80.7	81.1	81.1	80.8	79.5	79.1	79.0	80.1	80.6	80.3	(24)
(25)		10%	DB	87.0	87.6	87.3	87.8	88.2	87.6	86.7	87.2	88.4	88.1	87.3	86.5	(25)
(26)			MCWB	79.5	79.7	80.2	80.7	80.6	80.2	78.9	78.6	78.9	79.7	80.3	79.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.6	83.6	84.1	83.6	84.1	84.2	82.7	82.5	82.9	83.2	83.4	83.5	(27)
(28)			MCD B	89.2	90.2	90.1	89.6	90.1	90.0	88.4	88.8	89.1	90.2	89.6	89.7	(28)
(29)		2%	WB	82.1	82.2	82.7	82.7	82.9	82.8	81.7	81.2	81.8	82.1	82.4	82.1	(29)
(30)			MCD B	88.0	88.5	88.6	88.7	89.0	88.6	87.6	87.7	88.3	89.0	88.7	88.0	(30)
(31)		5%	WB	81.1	81.1	81.6	82.0	82.1	81.8	80.7	80.4	80.9	81.2	81.5	81.1	(31)
(32)			MCD B	86.6	87.0	87.3	87.7	88.1	87.5	86.5	86.9	87.4	87.8	87.3	86.5	(32)
(33)		10%	WB	80.0	80.1	80.5	81.0	81.1	80.7	79.7	79.4	79.9	80.2	80.4	80.0	(33)
(34)			MCD B	85.3	85.6	85.7	86.3	86.5	86.2	85.1	85.5	86.2	86.3	85.7	85.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.2	13.6	13.5	13.5	13.3	13.0	13.5	14.1	15.2	14.6	13.8	12.9	(35)
(36)			MCDBR	15.0	15.7	15.5	15.3	15.0	14.8	15.1	16.0	17.1	16.7	15.9	15.1	(36)
(37)			MCWBR	6.6	6.6	7.3	7.1	6.9	7.1	7.2	7.1	7.1	7.4	7.2	6.9	(37)
(38)		5% WB	MCD BR	14.1	14.6	14.6	14.3	14.3	14.2	14.3	14.8	15.4	15.6	14.7	14.1	(38)
(39)			MCWBR	7.6	7.7	8.1	7.8	7.7	7.9	7.9	7.9	8.2	8.2	7.9	7.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.419	0.441	0.433	0.414	0.421	0.424	0.448	0.523	0.650	0.669	0.555	0.424	(40)	
(41)		taud	2.450	2.362	2.393	2.455	2.440	2.430	2.349	2.093	1.749	1.714	2.009	2.436	(41)	
(42)		Ebn at Noon	291	284	284	281	272	266	262	248	225	223	250	287	(42)	
(43)		Edh at Noon	38	42	40	36	36	35	38	51	75	78	58	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1517	1569	1603	1550	1555	1501	1509	1623	1602	1523	1538	1453	(44)	
(45)		RadStd	59	73	67	59	63	94	100	108	127	110	77	71	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page