

BANJARMASIN SYAMSUDIN NOOR, Indonesia

WMO: 966850

Lat: 3.4388S

Lon: 114.7525E

Elev: 20

StdP: 101.08

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	21.9	22.6	17.8	12.8	31.5	19.0	13.8	30.4	7.8	28.9	6.5	29.4	0.4	200	0.310

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.5	35.1	24.8	34.2	25.1	33.8	25.3	27.2	31.6	26.9	31.2	26.7	30.8	3.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	28.8	26.0	21.4	28.7	25.7	21.0	28.4	86.2	32.1	84.9	31.7	83.9	31.2	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.3	5.4	4.7	20.6	36.5	0.7	1.2	20.1	37.4	19.7	38.0	19.3	38.7	18.7	39.5		
(5)			19.6	28.5	1.1	1.2	18.8	29.4	18.1	30.2	17.5	30.9	16.7	31.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	27.5	27.7	27.9	28.3	28.5	28.0	27.5	27.8	28.3	28.7	28.3	27.5		
	DBStd	1.14	1.12	1.11	1.11	1.02	1.03	1.04	1.06	0.99	0.95	1.18	1.10	1.13		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6567	542	494	554	549	573	539	544	553	548	579	548	542		
	CDD18.3	3525	283	261	296	299	315	289	286	295	298	321	298	283		
	CDH23.3	34478	2611	2484	2891	3028	3289	2812	2634	2881	3064	3329	2902	2552		
	CDH26.7	12644	787	771	946	1054	1221	1032	984	1228	1378	1441	1048	754		
(14) Wind	WSAvg	1.7	1.8	1.7	1.7	1.6	1.5	1.5	1.5	1.7	1.8	1.8	1.7	1.7		
(15) Precipitation	PrecAvg	2660	387	322	322	225	210	130	135	100	94	146	252	345		
	PrecMax	3308	589	525	616	463	482	240	415	385	245	287	463	680		
	PrecMin	1847	126	128	150	57	48	7	5	6	0	28	107	26		
	PrecStd	431	120	114	101	88	99	57	96	81	66	82	103	132		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	33.7	33.8	34.1	34.2	34.1	34.0	35.0	35.9	36.5	35.2	33.9		
		MCWB	26.5	26.2	26.6	26.6	26.5	26.0	25.5	24.6	24.3	23.9	25.5	26.4		
	2%	DB	32.2	32.5	32.8	33.1	33.5	33.1	33.0	34.0	34.8	35.2	34.0	32.3		
		MCWB	26.1	26.0	26.2	26.4	26.4	25.6	25.3	24.7	24.2	24.4	25.9	26.3		
	5%	DB	31.2	31.7	32.0	32.3	32.8	32.4	32.2	33.2	34.0	34.2	32.8	31.4		
		MCWB	26.0	26.0	26.1	26.3	26.2	25.6	25.2	24.6	24.3	24.8	26.0	26.1		
	10%	DB	30.4	30.8	31.1	31.5	31.9	31.7	31.4	32.2	33.0	33.1	31.7	30.4		
		MCWB	25.8	25.8	26.0	26.2	26.0	25.6	25.1	24.6	24.3	25.0	26.0	25.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.1	27.3	27.5	27.7	27.2	26.8	26.6	26.6	26.9	27.2	27.2		
		MCDB	31.1	31.1	31.5	32.0	32.2	31.5	31.5	32.0	31.7	31.8	31.8	31.5		
	2%	WB	26.6	26.6	26.7	27.0	27.1	26.7	26.3	26.1	26.1	26.4	26.7	26.7		
		MCDB	30.3	30.3	30.6	31.2	31.4	31.0	30.8	31.2	31.0	31.3	31.1	30.6		
	5%	WB	26.3	26.2	26.5	26.6	26.7	26.3	26.0	25.6	25.6	26.1	26.4	26.3		
		MCDB	29.6	29.7	30.2	30.5	30.7	30.5	30.3	30.6	30.5	30.9	30.7	30.0		
	10%	WB	26.0	26.0	26.2	26.3	26.4	26.0	25.6	25.2	25.2	25.7	26.1	26.1		
		MCDB	29.2	29.4	29.7	30.0	30.2	30.0	29.6	30.0	30.1	30.2	30.2	29.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.5	6.5	6.8	7.2	7.5	7.8	8.2	9.6	10.1	9.5	8.0	6.6		
		MCDBR	7.7	7.7	7.9	8.1	8.6	8.9	9.5	11.0	11.7	11.3	9.5	8.0		
	5% WB	MCWBR	2.7	2.5	2.7	2.6	2.7	2.8	3.1	3.3	3.1	2.9	2.9	2.8		
		MCWBR	7.0	6.9	7.2	7.5	7.9	8.3	9.1	9.2	9.0	8.2	7.2	7.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.423	0.441	0.431	0.415	0.414	0.415	0.437	0.505	0.574	0.586	0.509	0.435		
		taud	2.437	2.378	2.403	2.458	2.458	2.464	2.383	2.144	1.937	1.915	2.158	2.402		
	Ebn at Noon	Ebn at Noon	912	897	895	886	862	847	833	796	764	765	829	897		
		Edh at Noon	121	129	125	114	109	106	117	154	196	202	158	124		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.58	4.68	4.95	5.01	5.00	4.66	4.81	5.39	5.47	5.20	4.91	4.52		
	RadStd	RadStd	0.22	0.26	0.17	0.20	0.22	0.43	0.52	0.47	0.44	0.38	0.18	0.26		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page