

SERANG, Indonesia

WMO: 967370

Lat: 6.1116S

Lon: 106.1319E

Elev: 40

StdP: 100.85

Time Zone: 7.00 (E07)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.8	22.4	18.9	13.8	28.4	19.7	14.5	28.1	7.8	28.3	6.4	29.2	0.1	250	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	8.5	33.8	25.5	33.2	25.5	32.8	25.5	27.2	31.4	26.9	31.1	26.7	30.8	3.1	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	29.3	25.7	21.1	29.0	25.6	20.9	28.8	86.3	31.7	85.0	31.4	83.8	31.0	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.7	4.6	4.0	DB	20.4	35.0	1.0	0.8	19.7	35.6	19.1	36.1	18.6	36.5	17.9	37.1	
			WB	18.9	28.5	1.4	1.1	17.9	29.3	17.1	29.9	16.2	30.6	15.2	31.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.4	27.4	27.7	28.1	28.2	27.8	27.4	27.5	27.9	28.3	28.1	27.7
	DBStd	0.94	1.05	0.92	0.90	0.87	0.86	0.85	0.75	0.78	0.74	0.83	1.01	1.02
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6499	538	488	548	544	565	533	541	544	537	568	543	549
	CDD18.3	3457	279	255	290	294	307	283	282	286	287	310	293	291
	CDH23.3	35081	2686	2461	2926	3067	3241	2859	2761	2883	2991	3307	2996	2903
	CDH26.7	12902	801	749	966	1111	1234	1067	1052	1147	1298	1405	1135	936
Wind	WSAvg	1.1	1.5	1.2	1.3	1.1	0.9	0.8	0.9	1.0	1.0	1.0	1.0	1.4
Precipitation	PrecAvg	1639	311	249	170	144	118	62	72	67	61	91	132	176
	PrecMax	2203	647	582	307	276	354	196	193	171	217	197	304	283
	PrecMin	1029	65	42	58	28	31	0	0	0	0	0	28	32
	PrecStd	291	133	126	80	56	77	51	53	55	60	65	73	75
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	32.7	33.2	33.6	33.5	33.1	32.9	33.1	34.1	34.7	34.6	33.4
		MCWB	25.8	25.8	26.1	26.4	26.4	26.0	25.1	25.1	24.8	25.2	25.4	26.0
	2%	DB	32.0	31.9	32.2	32.8	32.8	32.4	32.2	32.3	33.3	33.7	33.4	32.4
		MCWB	25.7	26.2	26.0	26.5	26.3	25.8	25.0	25.0	24.7	25.3	25.5	25.8
	5%	DB	31.2	31.2	31.5	32.1	32.2	31.8	31.6	31.8	32.7	33.0	32.6	31.7
		MCWB	25.5	26.0	25.9	26.2	26.2	25.7	25.0	24.9	24.7	25.2	25.5	25.6
	10%	DB	30.3	30.4	30.8	31.4	31.6	31.2	31.1	31.3	32.0	32.3	31.8	30.8
		MCWB	25.4	25.8	25.8	26.1	26.0	25.5	24.9	24.7	24.7	25.2	25.4	25.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	27.2	27.5	27.7	27.6	27.2	26.7	26.6	26.7	27.1	27.0	26.9
		MCDB	31.1	31.1	31.5	32.0	31.6	31.2	30.7	31.4	31.5	31.8	31.8	31.5
	2%	WB	26.4	26.7	26.8	27.1	27.1	26.7	26.3	26.1	26.2	26.5	26.5	26.4
		MCDB	30.3	30.4	30.6	31.3	31.2	30.8	30.3	30.6	31.1	31.3	31.1	30.8
	5%	WB	26.1	26.4	26.4	26.7	26.7	26.4	25.9	25.7	25.7	26.1	26.1	26.1
		MCDB	29.8	30.0	30.1	30.7	30.7	30.4	29.9	30.0	30.6	30.9	30.6	30.3
	10%	WB	25.7	26.1	26.1	26.4	26.4	26.1	25.5	25.3	25.4	25.7	25.8	25.7
		MCDB	29.1	29.4	29.6	30.2	30.3	30.0	29.4	29.6	30.1	30.3	30.0	29.6
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.2	6.6	7.0	7.3	7.4	8.1	8.4	9.0	8.5	7.6	6.3
		MCDBR	7.3	7.2	7.6	7.9	8.0	8.2	8.7	8.9	9.9	9.6	8.9	7.6
		MCWBR	2.4	2.7	2.7	2.8	2.7	2.7	2.9	2.9	3.1	2.9	2.6	2.5
	5% WB	MCDBR	6.5	6.6	6.9	7.4	7.4	7.4	7.5	8.0	8.5	8.3	7.7	6.8
		MCWBR	2.5	2.8	2.9	2.9	2.8	2.9	2.9	3.0	3.0	2.9	2.7	2.5
Clear-Sky Solar Irradiance	taub	0.464	0.492	0.498	0.532	0.561	0.563	0.589	0.617	0.643	0.671	0.625	0.506	
	taud	2.324	2.238	2.218	2.105	2.004	1.979	1.906	1.827	1.768	1.713	1.826	2.185	
	Ebn at Noon	879	854	836	781	728	710	699	705	712	704	739	837	
	Edh at Noon	136	149	150	161	170	170	186	210	231	248	222	155	
All-Sky Solar Radiation	RadAvg	4.71	4.70	5.03	5.01	4.82	4.62	4.89	5.45	5.75	5.41	4.87	4.63	
	RadStd	0.42	0.38	0.30	0.24	0.27	0.33	0.38	0.26	0.39	0.46	0.31	0.29	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page