

CURUG BUDIARTO, Indonesia

WMO: 967390

Lat: 6.2871S

Lon: 106.5630E

Elev: 46

StdP: 100.77

Time Zone: 7.00 (E07)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.3	22.0	17.9	12.9	31.3	19.1	13.9	29.5	8.8	30.3	7.2	28.3	0.4	220	0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	9.8	34.1	24.7	33.5	24.9	33.0	25.1	27.2	31.0	26.8	30.8	26.6	30.6	2.9	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.3	21.8	29.0	25.8	21.2	28.6	25.5	20.9	28.4	86.6	31.2	84.6	31.0	83.3	30.7	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.0	5.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			17.9	28.6	2.2	0.8	16.3	29.2	15.0	29.7	13.8	30.1	12.2	30.8	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	26.9	26.8	27.5	28.0	28.1	27.7	27.3	27.6	27.9	28.2	27.8	27.4
	DBStd	0.99	1.10	1.11	0.89	0.88	0.77	0.89	0.76	0.68	0.71	0.77	1.01	1.01
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6419	523	470	542	541	560	530	536	545	536	566	533	538
	CDD18.3	3377	264	237	283	291	302	280	278	287	286	307	283	280
	CDH23.3	31215	2201	1936	2503	2707	2932	2641	2591	2812	2819	3061	2557	2456
	CDH26.7	11585	596	527	817	966	1113	996	1019	1194	1248	1396	939	774
Wind	WSAvg	1.6	2.3	1.7	1.9	1.6	1.0	1.1	1.1	1.1	1.3	1.5	1.7	2.3
Precipitation	PrecAvg	3277	395	393	323	327	291	198	163	159	167	256	323	282
	PrecMax	3995	713	632	519	467	397	453	387	448	495	493	455	508
	PrecMin	2447	190	182	160	105	158	51	28	39	26	63	139	99
	PrecStd	426	127	99	98	90	67	87	98	103	104	127	78	96
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	32.5	33.5	33.7	33.7	33.4	33.2	33.7	34.7	35.4	34.6	33.3
		MCWB	25.9	25.9	25.5	26.0	25.8	25.7	24.4	23.7	23.7	23.8	25.1	25.8
	2%	DB	31.7	31.5	32.5	32.9	32.9	32.7	32.6	33.0	33.6	34.2	33.3	32.3
		MCWB	25.7	25.9	25.8	26.2	25.9	25.7	24.6	24.1	24.2	24.5	25.4	25.7
	5%	DB	30.7	30.6	31.6	32.2	32.2	32.1	32.0	32.4	32.9	33.4	32.4	31.4
		MCWB	25.6	25.8	25.8	26.1	25.9	25.7	24.7	24.3	24.5	24.7	25.5	25.7
	10%	DB	29.8	29.8	30.7	31.4	31.6	31.4	31.3	31.8	32.2	32.6	31.4	30.5
		MCWB	25.4	25.7	25.7	26.0	25.9	25.6	24.8	24.5	24.6	24.9	25.5	25.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.5	27.7	27.4	27.7	27.4	26.7	26.4	26.7	26.7	27.2	27.1
		MCDB	30.7	30.4	30.3	31.5	31.4	31.2	30.0	30.7	31.4	31.5	31.2	30.9
	2%	WB	26.4	26.6	26.7	26.9	27.0	26.7	26.2	25.8	26.1	26.2	26.5	26.5
		MCDB	30.0	29.9	30.6	31.2	30.9	30.6	30.0	30.2	30.9	31.1	30.9	30.4
	5%	WB	26.0	26.1	26.3	26.6	26.6	26.4	25.8	25.5	25.6	25.8	26.1	26.1
		MCDB	29.5	29.5	30.1	30.6	30.4	30.3	29.8	30.0	30.4	30.7	30.6	30.1
	10%	WB	25.6	25.7	25.9	26.2	26.2	26.0	25.5	25.1	25.2	25.4	25.7	25.7
		MCDB	28.7	28.8	29.6	30.1	29.9	29.9	29.4	29.7	29.9	30.3	29.9	29.4
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.1	7.2	7.6	8.0	8.1	9.0	9.5	9.7	9.8	8.0	6.9
		MCDBR	7.5	7.6	8.6	8.6	8.7	9.0	9.9	10.2	10.8	11.0	9.5	8.3
		MCWBR	2.8	3.0	3.2	2.8	2.9	3.1	3.3	3.1	3.2	2.9	2.9	2.9
	5% WB	MCDBR	6.6	6.9	7.6	7.9	7.9	8.2	8.4	9.1	9.1	9.3	8.2	7.3
		MCWBR	2.9	3.2	3.3	3.0	3.1	3.3	3.1	3.1	3.2	3.1	3.1	3.0
Clear-Sky Solar Irradiance	taub	0.480	0.508	0.517	0.551	0.573	0.571	0.590	0.621	0.647	0.686	0.650	0.530	
	taud	2.264	2.177	2.148	2.039	1.961	1.949	1.895	1.809	1.752	1.678	1.763	2.101	
	Ebn at Noon	864	839	820	765	718	703	697	702	709	693	720	817	
	Edh at Noon	144	158	160	172	178	175	188	213	235	257	237	169	
All-Sky Solar Radiation	RadAvg	4.53	4.46	4.87	4.87	4.75	4.60	4.87	5.37	5.65	5.27	4.75	4.56	
	RadStd	0.41	0.35	0.27	0.24	0.25	0.33	0.38	0.26	0.39	0.45	0.28	0.31	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	N/A	+132	+132

Nomenclature: See separate page