

JAKARTA SOEKARNO-HATTA, Indonesia

WMO: 967490

Lat: 6.1255S

Lon: 106.6590E

Elev: 26

StdP: 14.68

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	72.1	73.2	64.4	90.6	84.2	66.2	96.6	82.9	22.4	83.2	19.3	83.4	3.0	190	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	15.6	93.2	77.8	91.8	78.0	91.5	78.1	81.9	88.3	81.2	87.8	80.7	87.4	11.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.0	86.0	79.2	151.6	84.8	79.0	150.5	84.5	45.7	88.7	45.0	88.6	44.4	87.6	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.9	17.3	15.2	68.5	95.8	3.6	1.9	65.9	97.2	63.7	98.3	61.7	99.4	59.0	100.8		
(5)			65.1	83.8	3.1	1.8	62.8	85.1	61.0	86.2	59.2	87.2	56.9	88.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	81.0	81.0	82.2	83.0	83.1	82.5	81.9	82.1	82.8	83.4	83.1	82.2	(6)
(7)		DBStd	1.75	1.92	1.74	1.59	1.54	1.45	1.46	1.39	1.42	1.34	1.44	1.71	1.84	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11808	962	867	997	991	1027	974	988	994	983	1034	993	998	(10)
(11)		CDD65	6333	497	447	532	541	562	524	523	529	533	569	543	533	(11)
(12)		CDH74	66657	4759	4208	5390	5820	6294	5664	5514	5664	5863	6310	5771	5400	(12)
(13)		CDH80	25254	1445	1212	1871	2257	2521	2192	2090	2215	2485	2723	2323	1920	(13)
(14)	Wind	WSAvg	6.3	7.1	6.3	6.5	6.1	5.6	5.7	5.9	6.2	6.1	6.0	6.2	7.6	(14)
(15)	Precipitation	PrecAvg	84.1	14.9	14.6	8.7	7.4	6.4	3.9	3.4	2.4	2.8	4.9	7.1	8.1	(15)
(16)		PrecMax	105.9	29.5	26.4	13.2	11.0	9.8	9.5	13.1	9.8	12.5	14.8	10.8	18.7	(16)
(17)		PrecMin	55.0	5.3	7.2	4.4	2.6	3.3	0.2	0.0	0.0	0.0	0.0	2.7	2.3	(17)
(18)		PrecStd	14.6	5.9	5.4	2.5	2.4	1.9	2.4	3.2	2.7	2.9	4.2	2.2	3.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.8	90.3	91.8	93.2	92.8	91.8	91.5	91.7	93.4	94.0	93.9	93.3	(19)
(20)			MCWB	77.7	79.1	79.2	79.1	79.6	78.7	76.9	76.4	76.0	77.1	77.9	78.1	(20)
(21)		2%	DB	89.8	89.1	90.3	91.5	91.4	91.1	90.0	90.8	91.7	93.0	92.8	91.4	(21)
(22)			MCWB	78.2	79.2	79.1	79.4	79.6	78.6	77.1	76.5	76.9	77.3	78.2	78.4	(22)
(23)		5%	DB	88.0	87.6	89.5	90.0	90.0	89.8	89.5	89.7	91.1	91.5	91.4	89.7	(23)
(24)			MCWB	78.6	79.0	79.1	79.4	79.4	78.4	77.2	76.8	77.0	77.4	78.2	78.3	(24)
(25)		10%	DB	86.3	86.1	87.9	89.4	89.4	89.2	88.1	88.6	89.7	90.2	89.7	88.1	(25)
(26)			MCWB	78.4	78.6	79.1	79.4	79.3	78.3	77.2	76.9	77.0	77.5	78.1	78.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.4	81.4	82.2	82.6	82.6	81.9	81.2	80.9	80.9	81.3	81.8	81.5	(27)
(28)			MCD B	86.7	86.7	88.0	88.9	89.1	88.1	87.5	87.9	88.9	88.7	89.0	88.0	(28)
(29)		2%	WB	80.2	80.2	80.9	81.5	81.6	80.8	80.0	79.8	79.9	80.1	80.5	80.1	(29)
(30)			MCD B	85.6	85.4	87.3	88.2	88.2	87.5	86.5	86.7	87.9	87.9	87.8	87.1	(30)
(31)		5%	WB	79.5	79.6	80.1	80.7	80.8	80.0	79.2	79.0	79.1	79.5	79.7	79.5	(31)
(32)			MCD B	84.9	84.8	86.4	87.6	87.6	86.6	85.6	85.9	87.1	87.4	87.2	86.5	(32)
(33)		10%	WB	78.9	79.0	79.4	79.9	80.0	79.3	78.6	78.2	78.3	78.8	79.0	78.9	(33)
(34)			MCD B	84.3	84.2	85.6	86.6	86.6	85.8	85.0	85.2	86.3	86.9	86.7	85.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.4	11.2	12.7	13.5	13.6	14.0	14.5	15.1	15.9	15.6	14.5	12.9	(35)
(36)			MCDBR	13.7	12.9	14.3	14.6	14.3	14.9	15.2	15.6	16.8	16.7	16.2	15.1	(36)
(37)			MCWBR	6.1	6.1	6.2	6.0	6.0	6.0	5.9	6.2	6.2	6.1	6.1	6.0	(37)
(38)		5% WB	MCDBR	11.9	11.6	13.1	13.7	13.7	14.1	14.1	14.7	15.4	15.2	14.4	13.3	(38)
(39)			MCWBR	6.2	6.1	6.4	6.3	6.3	6.3	6.2	6.6	6.5	6.3	6.2	6.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.483	0.509	0.514	0.539	0.559	0.559	0.577	0.606	0.632	0.670	0.634	0.527	(40)	
(41)		taud	2.262	2.182	2.164	2.085	2.011	1.993	1.942	1.857	1.794	1.717	1.805	2.117	(41)	
(42)		Ebn at Noon	273	266	261	246	232	226	225	226	228	223	232	260	(42)	
(43)		Edh at Noon	46	50	50	52	54	53	57	65	71	78	72	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1453	1435	1567	1565	1516	1463	1557	1721	1819	1695	1520	1454	(44)	
(45)		RadStd	128	110	82	79	81	108	123	84	123	145	94	100	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	+238	+238
(47) Regional (7 neighbors)		+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page