

BOGOR CITEKO, Indonesia

WMO: 967510

Lat: 6.6980S

Lon: 106.9350E

Elev: 950

StdP: 90.42

Time Zone: 7.00 (E07)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.9	17.3	12.1	9.9	20.4	13.4	10.8	19.7	5.4	21.8	4.4	21.7	0.3	N/A	0.175

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.4	27.6	20.9	27.1	21.0	26.6	21.1	22.8	25.4	22.6	25.2	22.3	24.9	2.1	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	18.8	24.5	21.7	18.4	24.2	21.4	18.1	24.0	73.0	25.7	71.8	25.4	70.7	25.1	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.1	3.3	2.8	DB	14.8	29.3	1.9	0.8	13.4	29.9	12.3	30.4	11.2	30.8	9.8	31.4	(4)
(5)			WB	12.0	24.5	0.9	0.8	11.3	25.1	10.8	25.6	10.3	26.1	9.7	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.9	21.1	21.2	21.9	22.4	22.5	22.3	21.7	21.8	22.1	22.3	22.1	21.8
	DBStd	0.91	1.14	1.07	0.78	0.73	0.75	0.73	0.66	0.63	0.65	0.76	0.84	0.83
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	4358	344	314	370	373	388	369	363	365	362	381	362	367
	CDD18.3	1316	86	81	112	123	129	119	105	107	112	122	112	108
	CDH23.3	3398	97	94	200	321	396	365	308	354	407	407	259	189
	CDH26.7	93	2	2	2	7	10	6	4	7	17	25	9	2
Wind	WSAvg	0.7	0.8	0.7	0.7	0.6	0.6	0.6	0.7	0.7	0.7	0.6	0.6	0.7
Precipitation	PrecAvg	3738	422	432	365	374	315	195	178	182	201	320	400	355
	PrecMax	4562	942	727	694	527	547	441	395	425	493	587	636	559
	PrecMin	2770	118	181	154	119	137	51	34	43	52	105	204	96
	PrecStd	475	172	116	121	91	89	90	100	104	110	119	101	115
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	26.8	26.9	27.6	27.8	27.5	27.4	27.5	28.3	28.7	28.0	26.8
		MCWB	21.6	21.1	21.9	22.0	21.6	21.4	20.5	20.1	20.0	19.5	21.0	21.5
	2%	DB	25.5	25.2	26.1	26.7	26.8	26.7	26.3	26.6	27.1	27.3	26.6	25.9
		MCWB	21.3	21.3	21.6	21.9	21.8	21.4	20.4	20.3	20.3	20.4	21.3	21.4
	5%	DB	24.3	24.5	25.3	26.1	26.1	26.1	25.7	25.9	26.4	26.4	25.7	25.2
		MCWB	21.0	21.2	21.5	21.8	21.8	21.5	20.5	20.2	20.3	20.8	21.4	21.3
	10%	DB	23.4	23.7	24.6	25.2	25.5	25.5	25.1	25.3	25.7	25.6	25.0	24.4
		MCWB	20.7	21.0	21.3	21.7	21.8	21.4	20.5	20.3	20.4	21.0	21.5	21.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.4	22.5	22.9	23.2	23.2	22.9	22.5	22.2	22.2	22.5	22.7	22.7
		MCDB	24.8	25.0	25.3	25.8	25.8	25.8	25.2	24.9	25.0	25.3	25.2	25.1
	2%	WB	21.9	22.0	22.3	22.7	22.7	22.5	21.9	21.7	21.7	22.1	22.2	22.2
		MCDB	24.3	24.3	24.8	25.3	25.3	25.3	24.7	24.6	24.8	25.0	24.8	24.6
	5%	WB	21.4	21.6	22.0	22.3	22.4	22.1	21.4	21.3	21.4	21.7	21.9	21.8
		MCDB	23.6	23.7	24.4	25.0	25.1	24.9	24.3	24.4	24.6	24.7	24.6	24.2
	10%	WB	20.9	21.2	21.6	22.0	22.1	21.7	21.0	20.9	21.0	21.4	21.6	21.4
		MCDB	22.8	23.1	23.9	24.6	24.7	24.5	24.0	24.1	24.4	24.4	24.2	23.8
Mean Daily Temperature Range	5% DB	MDBR	4.3	4.5	5.6	6.1	6.4	6.6	7.2	7.7	7.8	7.1	6.2	5.5
		MCDBR	6.3	6.2	6.8	7.2	7.4	7.5	8.2	8.5	8.9	8.5	7.2	6.7
		MCWBR	3.8	4.1	4.2	4.3	4.4	4.6	4.8	4.8	4.8	4.6	4.2	4.0
	5% WB	MCDBR	5.5	5.5	6.0	6.3	6.4	6.5	6.9	7.2	7.3	6.8	6.3	5.9
		MCWBR	3.7	3.9	4.1	4.2	4.3	4.4	4.5	4.5	4.4	4.3	4.1	3.9
Clear-Sky Solar Irradiance	taub	0.426	0.451	0.461	0.489	0.494	0.486	0.494	0.518	0.538	0.584	0.572	0.472	
	taud	2.347	2.272	2.241	2.148	2.112	2.111	2.074	1.985	1.938	1.831	1.880	2.203	
	Ebn at Noon	914	889	868	816	782	772	774	780	791	768	781	868	
	Edh at Noon	133	144	146	154	152	149	157	179	195	221	211	152	
All-Sky Solar Radiation	RadAvg	4.60	4.48	4.90	4.89	4.81	4.66	4.90	5.43	5.68	5.31	4.81	4.67	
	RadStd	0.45	0.42	0.30	0.24	0.24	0.34	0.39	0.28	0.43	0.49	0.29	0.34	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47) Regional (6 neighbors)	+0.48	+0.61	N/A	+0.42	N/A	N/A	N/A	N/A	N/A	+132	+132	(47)

Nomenclature: See separate page