

CIREBON JATIWANGI, Indonesia

WMO: 967910

Lat: 6.7343S

Lon: 108.2630E

Elev: 164

StdP: 14.61

Time Zone: 7.00 (E07)

Period: 83-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	71.5	72.8	60.1	78.1	85.0	62.1	83.8	83.7	12.4	84.5	11.6	85.8	1.2	N/A	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	17.1	96.2	75.7	94.7	76.0	93.3	76.5	81.3	89.4	80.7	88.7	80.1	87.9	7.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	152.4	84.8	78.7	149.7	84.3	78.2	147.2	83.8	45.2	89.3	44.4	89.0	44.0	88.5	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max			
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	10.4	8.8	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	83.0	81.4	81.3	82.4	83.2	83.3	82.5	82.0	82.7	84.1	85.7	84.5	82.6
	DBStd	2.13	2.09	1.94	1.44	1.46	1.45	1.45	1.45	1.37	1.74	2.04	2.35	1.82
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12041	974	876	1006	995	1031	976	991	1015	1024	1108	1034	1011
	CDD65	6566	509	456	541	545	566	526	526	550	574	643	584	546
	CDH74	67377	4501	3871	5000	5558	6061	5468	5383	5901	6424	7659	6398	5153
	CDH80	27199	1390	1205	1814	2091	2450	2208	2180	2570	2970	3715	2779	1827
(14) Wind	WSAvg	2.5	2.2	2.1	1.9	1.8	1.9	2.3	2.9	3.7	3.4	3.3	2.4	1.9
(15) Precipitation	PrecAvg	106.3	18.4	15.0	15.6	9.5	6.6	3.3	1.9	0.9	1.9	4.8	10.5	16.9
	PrecMax	145.6	28.1	29.0	28.2	22.8	18.7	13.2	7.1	4.1	9.0	15.5	21.3	33.4
	PrecMin	67.5	8.7	3.7	6.4	1.5	0.2	0.0	0.0	0.0	0.0	0.0	1.5	6.9
	PrecStd	20.8	4.6	5.9	6.4	4.9	4.7	3.1	2.2	1.5	2.3	4.6	5.5	5.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.1	91.4	92.4	92.7	93.1	92.5	92.4	93.5	96.6	98.6	98.4	93.5
		MCWB	79.9	79.9	79.4	80.0	79.1	78.3	75.5	74.7	74.1	74.2	79.4	80.1
	2%	DB	90.2	89.8	91.1	91.5	91.8	91.5	91.3	92.3	94.8	96.6	95.5	91.6
		MCWB	79.5	79.6	79.2	79.5	79.0	78.0	75.6	74.9	74.5	74.9	78.1	79.5
	5%	DB	88.5	88.5	89.9	90.4	91.0	90.6	90.3	91.4	93.4	95.2	93.6	90.1
		MCWB	79.0	79.3	79.2	79.4	79.0	77.9	75.8	74.9	74.7	75.5	77.8	79.1
	10%	DB	86.8	86.8	88.5	89.1	89.8	89.5	89.2	90.2	92.0	93.6	91.3	88.4
		MCWB	78.4	78.8	78.9	79.2	78.9	77.9	75.9	74.9	75.0	75.9	78.0	78.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.6	81.6	82.4	81.8	80.9	79.9	79.1	79.7	80.0	82.0	81.4
		MCDB	88.8	88.6	89.0	90.0	89.2	89.0	88.0	87.7	89.0	90.5	93.5	90.3
	2%	WB	80.1	80.4	80.6	80.9	80.8	80.0	79.0	78.2	78.8	79.1	80.1	80.4
		MCDB	87.6	87.7	88.2	88.2	88.6	88.1	86.7	86.6	87.5	89.5	89.3	89.0
	5%	WB	79.5	79.7	79.9	80.3	80.1	79.4	78.3	77.4	78.0	78.3	79.4	79.7
		MCDB	86.6	86.6	87.3	87.3	87.8	87.4	85.8	86.1	87.0	88.7	88.5	87.7
	10%	WB	78.8	79.0	79.2	79.8	79.5	78.9	77.5	76.7	77.3	77.6	78.8	79.1
		MCDB	85.4	85.5	86.3	86.6	87.0	86.7	85.0	85.6	86.5	88.0	87.9	86.3
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	12.2	13.9	13.5	14.2	14.9	15.8	16.8	17.3	17.1	15.1	13.3
		MCDBR	14.2	14.4	15.5	14.9	15.6	16.3	17.2	18.0	19.1	19.0	17.9	15.4
		MCWBR	5.3	5.8	5.6	5.2	5.7	6.6	6.3	6.5	5.9	5.5	5.3	5.1
	5% WB	MCDBR	13.2	13.6	14.3	13.6	14.1	14.7	14.6	15.6	15.7	16.3	15.6	14.2
		MCWBR	5.4	5.9	5.7	5.4	5.5	6.4	5.6	5.9	5.8	5.4	5.4	5.3
(40) Clear-Sky Solar Irradiance	taub		0.517	0.524	0.524	0.529	0.510	0.503	0.496	0.514	0.530	0.593	0.597	0.558
	taud		2.136	2.122	2.124	2.103	2.143	2.147	2.159	2.086	2.046	1.887	1.891	2.007
	Ebn at Noon		264	262	258	248	244	240	245	248	253	242	241	252
	Edh at Noon		52	53	52	51	47	46	46	51	56	66	66	59
(44) All-Sky Solar Radiation	RadAvg		1490	1462	1611	1580	1534	1465	1544	1726	1826	1746	1586	1504
(45)	RadStd		128	147	82	75	73	102	113	85	121	158	108	112

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.86	+1.10	N/A	+0.76	N/A	N/A	N/A	N/A	+238	+238

Nomenclature: See separate page