

TEGAL, Indonesia

WMO: 967970

Lat: 6.8681S

Lon: 109.1210E

Elev: 10

StdP: 101.20

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	22.8	23.3	17.5	12.6	26.9	18.4	13.3	26.6	9.9	27.5	8.3	28.0	2.0	200	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	6.6	33.2	25.2	32.7	25.4	32.2	25.5	27.2	31.1	27.0	31.0	26.7	30.6	3.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.6	29.7	25.8	21.2	29.4	25.7	20.9	29.2	86.3	31.4	85.1	31.2	84.1	30.9	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.1	5.2	DB	21.6	35.1	0.8	1.3	21.0	36.0	20.5	36.8	20.0	37.5	19.4	38.4	(4)
(5)			WB	18.9	28.3	1.3	1.1	18.0	29.0	17.2	29.6	16.5	30.2	15.6	31.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.1	27.6	27.4	28.0	28.6	28.6	28.2	27.7	27.6	28.2	28.8	28.6	28.2	(6)	
	DBStd	0.90	0.97	0.85	0.80	0.73	0.70	0.74	0.70	0.74	0.72	0.68	0.80	0.93	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6619	546	487	559	557	578	547	548	547	545	583	559	564	(10)	
	CDD18.3	3577	288	253	301	307	319	297	289	288	295	324	309	306	(11)	
	CDH23.3	38726	2893	2475	3210	3551	3712	3263	2929	2931	3187	3777	3505	3294	(12)	
(13)	CDH26.7	13868	833	683	1059	1331	1444	1226	1072	1079	1222	1492	1313	1114	(13)	
(14)	Wind	WSAvg	2.1	2.3	2.1	1.8	1.7	1.8	2.0	2.1	2.3	2.4	2.4	2.0	2.0	(14)
(15) Precipitation	PrecAvg	1778	366	320	237	137	127	84	50	33	33	52	139	269	(15)	
	PrecMax	2601	657	651	623	380	283	324	203	253	190	215	374	628	(16)	
	PrecMin	1114	152	60	55	0	17	0	0	0	0	0	0	56	(17)	
	PrecStd	405	138	136	137	94	80	79	54	55	47	58	103	142	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	32.0	32.7	32.9	33.0	32.7	32.6	32.7	33.7	34.0	33.6	33.3	(19)	
		MCWB	26.0	26.6	26.3	26.5	26.3	25.3	24.3	24.0	24.2	24.7	25.4	26.1	(20)	
	2%	DB	31.7	31.2	31.7	32.1	32.4	32.2	31.8	31.9	32.7	32.9	32.7	32.2	(21)	
		MCWB	26.1	26.3	26.4	26.5	26.2	25.5	24.6	24.2	24.1	24.9	25.7	26.1	(22)	
	5%	DB	30.9	30.6	31.2	31.7	32.0	31.7	31.3	31.3	32.0	32.2	32.1	31.7	(23)	
		MCWB	26.0	26.2	26.3	26.4	26.2	25.5	24.6	24.3	24.3	25.1	25.8	26.1	(24)	
	10%	DB	30.1	30.0	30.7	31.3	31.6	31.2	30.9	30.8	31.4	31.7	31.6	31.0	(25)	
		MCWB	26.0	26.1	26.2	26.3	26.1	25.5	24.6	24.3	24.4	25.2	25.8	26.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.3	27.7	27.6	27.5	27.1	26.6	26.4	26.5	26.7	27.1	27.2	(27)	
		MCDB	30.8	30.6	31.0	31.4	31.6	31.1	30.6	30.5	30.4	31.5	31.6	31.1	(28)	
	2%	WB	26.7	26.7	27.1	27.1	27.1	26.7	26.2	25.9	26.1	26.3	26.6	26.8	(29)	
		MCDB	30.3	30.1	30.7	31.1	31.2	30.7	30.2	30.0	30.1	31.1	31.2	30.8	(30)	
	5%	WB	26.5	26.5	26.7	26.7	26.8	26.4	25.8	25.5	25.7	26.0	26.3	26.5	(31)	
		MCDB	29.9	29.8	30.2	30.6	30.7	30.4	29.8	29.7	29.9	30.9	30.9	30.5	(32)	
	10%	WB	26.1	26.2	26.4	26.5	26.5	26.1	25.4	25.0	25.2	25.7	26.0	26.2	(33)	
		MCDB	29.4	29.3	29.8	30.3	30.4	30.0	29.3	29.5	29.6	30.4	30.6	30.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.2	5.6	5.8	6.2	6.6	7.2	7.2	7.2	6.6	6.2	5.8	(35)	
		MCDBR	6.2	6.0	6.2	6.2	6.6	7.0	7.6	7.6	7.9	7.2	6.8	6.6	(36)	
	5% WB	MCWBR	2.6	2.6	2.6	2.3	2.5	2.6	3.0	3.1	2.8	2.6	2.6	2.6	(37)	
		MCWBR	5.7	5.6	5.8	5.8	6.1	6.5	6.5	6.5	6.5	6.4	6.2	6.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.545	0.556	0.550	0.565	0.544	0.535	0.534	0.553	0.581	0.657	0.646	0.583	(40)	
		taud	2.061	2.034	2.054	2.001	2.042	2.054	2.047	1.980	1.915	1.743	1.779	1.941	(41)	
	Ebn at Noon		809	800	793	753	739	731	741	752	757	714	724	773	(42)	
		Edh at Noon	177	183	176	178	163	157	161	179	199	241	233	198	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.73	4.71	5.14	5.04	4.91	4.70	4.94	5.52	5.87	5.63	5.06	4.71	(44)	
	RadStd		0.42	0.43	0.28	0.23	0.26	0.31	0.33	0.24	0.34	0.52	0.41	0.38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	+0.32	N/A	N/A	+0.39	+0.35	+0.47	N/A	N/A	N/A	N/A

Nomenclature: See separate page