

SANGKAPURA BAWEAN ISLAND, Indonesia

WMO: 969250

Lat: 5.8510S

Lon: 112.6579E

Elev: 3

StdP: 101.29

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	23.9	24.3	20.4	15.0	27.2	20.9	15.6	27.2	10.3	26.4	8.7	27.6	1.8	280	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	5.0	32.6	27.2	32.1	26.9	31.7	26.7	27.9	31.5	27.5	31.1	27.2	30.7	3.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.5	30.6	26.5	22.0	30.1	26.2	21.6	29.6	89.3	31.7	87.4	31.3	86.0	31.0	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	7.0	6.2	20.4	33.5	3.2	0.7	18.2	34.1	16.3	34.5	14.5	34.9	12.2	35.4		
(5)			19.5	28.7	2.5	0.5	17.7	29.1	16.3	29.4	14.9	29.7	13.1	30.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	28.2	27.6	27.6	27.9	28.2	28.8	28.3	28.0	28.2	28.3	28.8	28.6	27.9
	DBStd	1.01	1.07	0.99	0.81	0.92	0.95	0.98	0.79	0.50	0.65	0.92	1.11	1.15
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6641	545	492	556	547	583	549	557	563	551	584	559	556
	CDD18.3	3599	287	258	297	297	324	299	299	304	301	326	309	297
	CDH23.3	40772	3063	2700	3217	3387	3919	3478	3314	3337	3433	3942	3693	3291
CDH26.7	13478	821	723	1009	1187	1531	1172	928	920	1124	1576	1463	1023	
Wind	WSAvg	2.7	3.0	2.4	1.7	1.7	2.6	3.2	3.6	4.0	3.3	2.7	1.6	2.0
Precipitation	PrecAvg	2342	483	278	269	209	195	103	84	22	47	92	237	425
	PrecMax	3546	1146	628	487	510	605	389	347	101	344	302	825	995
	PrecMin	1230	200	102	91	23	14	3	0	0	0	0	0	161
	PrecStd	661	208	114	119	126	129	102	115	32	79	94	180	176
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.3	31.9	32.1	32.2	32.2	31.7	31.0	30.9	31.6	32.7	33.3	33.1
		MCWB	27.8	27.1	27.1	27.0	27.3	26.7	26.1	25.8	26.0	26.7	27.8	27.7
	2%	DB	31.2	31.2	31.7	31.7	31.7	31.2	30.4	30.3	31.1	32.2	32.7	32.0
		MCWB	26.8	26.7	26.9	26.9	27.0	26.5	25.6	25.4	25.7	26.4	27.2	27.1
	5%	DB	30.5	30.6	31.2	31.4	31.3	30.7	30.0	30.0	30.7	31.7	32.2	31.3
		MCWB	26.4	26.5	26.7	26.8	26.7	26.2	25.3	25.1	25.5	26.3	26.9	26.8
	10%	DB	29.8	30.0	30.8	30.9	30.9	30.2	29.6	29.7	30.4	31.3	31.6	30.6
		MCWB	26.2	26.2	26.5	26.6	26.4	25.9	25.1	24.9	25.3	26.1	26.7	26.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.4	27.7	28.1	27.8	27.9	27.3	26.7	26.5	26.7	27.3	28.5	28.2
		MCDB	31.6	30.9	31.5	31.2	31.5	30.7	30.0	30.0	30.6	31.6	32.7	31.9
	2%	WB	27.3	27.0	27.5	27.4	27.4	26.9	26.2	26.0	26.3	27.0	27.7	27.5
		MCDB	30.3	30.4	30.9	30.8	30.9	30.4	29.5	29.6	30.1	31.4	31.8	31.0
	5%	WB	26.7	26.6	27.0	27.1	27.1	26.6	25.9	25.7	26.0	26.7	27.2	27.1
		MCDB	29.5	29.8	30.4	30.5	30.5	29.9	29.2	29.2	29.8	30.9	31.3	30.4
	10%	WB	26.4	26.3	26.7	26.7	26.7	26.3	25.6	25.4	25.7	26.4	26.8	26.7
		MCDB	29.1	29.2	29.8	30.0	30.0	29.5	28.8	28.9	29.5	30.4	30.7	29.8
Mean Daily Temperature Range	5% DB	MDBR	4.2	4.5	5.3	5.1	4.2	3.8	3.5	3.4	4.3	5.0	5.7	4.8
		MCDBR	5.2	5.6	6.2	5.6	4.6	4.3	3.8	3.6	4.7	5.4	6.3	5.9
		MCWBR	2.4	2.5	2.9	2.4	2.0	1.9	1.7	1.7	2.2	2.5	2.8	2.7
	5% WB	MCDBR	4.9	5.2	5.8	5.4	4.5	4.3	3.6	3.5	4.4	5.2	6.1	5.4
		MCWBR	2.5	2.5	2.8	2.5	2.0	2.0	1.7	1.8	2.2	2.5	2.9	2.7
Clear-Sky Solar Irradiance	taub	0.474	0.471	0.452	0.434	0.429	0.427	0.421	0.441	0.456	0.494	0.490	0.483	
	taud	2.324	2.331	2.382	2.439	2.468	2.463	2.470	2.387	2.321	2.213	2.251	2.285	
	Ebn at Noon	869	872	876	866	843	830	842	848	859	841	849	857	
	Edh at Noon	136	136	127	115	107	105	106	120	133	151	145	140	
All-Sky Solar Radiation	RadAvg	4.47	4.91	5.26	5.24	5.08	4.93	5.34	6.04	6.47	6.18	5.21	4.16	
	RadStd	0.52	0.57	0.40	0.37	0.35	0.42	0.40	0.19	0.32	0.60	0.65	0.55	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	+0.24	+0.73	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page