

BANYUWANGI, Indonesia

WMO: 969870

Lat: 8.2143S

Lon: 114.3555E

Elev: 5

StdP: 101.26

Time Zone: 7.00 (E07)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.1	22.8	18.3	13.2	24.3	19.0	13.8	24.6	5.8	28.5	5.2	27.9	0.6	270	0.308

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	6.7	33.0	26.0	32.5	26.0	32.1	25.9	27.1	31.2	26.8	30.8	26.6	30.6	3.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	29.4	25.7	21.0	29.1	25.5	20.7	29.0	85.5	31.5	84.3	31.1	83.4	30.8	32.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.6	4.1	DB	20.8	35.2	0.6	2.1	20.4	36.7	20.0	37.9	19.6	39.1	19.2	40.6	(4)
(5)			WB	18.3	28.7	1.2	1.2	17.4	29.6	16.7	30.3	16.0	31.0	15.1	31.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.5	27.7	27.7	27.9	28.2	27.8	26.9	26.3	26.1	26.9	28.0	28.6	28.1	(6)
(7)		DBStd	1.16	0.88	0.86	0.87	0.77	0.82	0.95	0.89	0.75	0.83	0.87	0.93	1.11	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6394	548	496	556	546	552	508	504	501	507	557	558	562	(10)
(11)		CDD18.3	3353	290	263	297	296	293	258	246	242	257	298	308	304	(11)
(12)		CDH23.3	33486	2877	2621	3096	3285	3094	2416	1982	1883	2306	3172	3526	3228	(12)
(13)		CDH26.7	10421	911	834	1064	1172	959	582	369	342	600	1081	1362	1144	(13)
(14)	Wind	WSAvg	1.3	1.1	1.1	1.2	1.2	1.3	1.4	1.4	1.5	1.5	1.3	1.2	(14)	
(15)	Precipitation	PrecAvg	1120	185	185	190	71	103	39	42	27	46	64	78	129	(15)
(16)		PrecMax	1770	293	286	403	154	288	142	222	81	155	207	314	337	(16)
(17)		PrecMin	361	83	46	76	25	4	0	0	0	0	0	0	17	(17)
(18)		PrecStd	349	64	71	98	37	93	46	73	25	45	61	87	75	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	33.0	33.1	32.7	32.2	31.6	30.9	30.5	31.7	32.7	33.5	34.1	(19)
(20)			MCWB	25.7	26.0	26.2	25.9	26.1	25.4	25.3	24.7	25.2	25.2	26.0	26.3	(20)
(21)		2%	DB	32.3	32.1	32.3	32.1	31.6	30.7	29.9	29.6	30.7	32.1	32.8	32.9	(21)
(22)			MCWB	25.9	26.0	26.1	26.0	25.9	25.4	24.9	24.3	24.9	25.4	26.0	26.3	(22)
(23)		5%	DB	31.5	31.5	31.7	31.6	31.0	30.1	29.2	29.0	30.1	31.5	32.3	32.1	(23)
(24)			MCWB	25.9	25.9	26.0	26.0	25.8	25.3	24.5	24.2	24.7	25.4	26.0	26.2	(24)
(25)		10%	DB	30.7	30.7	31.0	31.1	30.4	29.5	28.6	28.5	29.6	30.9	31.8	31.3	(25)
(26)			MCWB	25.7	25.8	25.9	26.0	25.6	25.0	24.2	24.0	24.5	25.3	26.0	26.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	27.3	27.2	27.2	27.2	26.7	26.3	25.9	26.4	27.0	27.3	27.5	(27)
(28)			MCDWB	31.3	31.3	31.3	31.2	30.5	29.9	29.3	29.0	29.9	30.7	31.5	31.9	(28)
(29)		2%	WB	26.6	26.7	26.7	26.7	26.7	26.2	25.7	25.3	25.8	26.5	26.9	26.9	(29)
(30)			MCDWB	30.7	30.6	30.8	30.6	30.1	29.4	28.7	28.4	29.3	30.2	31.2	31.4	(30)
(31)		5%	WB	26.2	26.3	26.4	26.5	26.4	25.8	25.2	24.9	25.4	26.1	26.6	26.6	(31)
(32)			MCDWB	30.1	30.1	30.4	30.4	29.8	28.9	28.1	27.9	28.9	29.9	30.9	30.9	(32)
(33)		10%	WB	25.9	26.0	26.1	26.2	26.1	25.5	24.8	24.5	25.0	25.7	26.3	26.2	(33)
(34)			MCDWB	29.7	29.7	30.0	30.0	29.4	28.5	27.6	27.5	28.5	29.4	30.5	30.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.5	6.6	6.3	5.7	5.3	5.1	5.3	5.9	6.5	6.7	6.6	(35)
(36)			MCDBR	7.4	7.3	7.3	6.7	6.1	6.0	5.6	5.7	6.4	7.0	7.3	7.6	(36)
(37)			MCWBR	3.3	3.2	3.3	3.0	2.7	2.7	2.5	2.6	2.8	2.9	3.0	3.2	(37)
(38)		5% WB	MCDWB	6.7	6.6	6.8	6.4	5.8	5.4	5.0	5.1	5.7	6.3	6.8	7.0	(38)
(39)			MCWBR	3.2	3.2	3.3	3.1	2.7	2.6	2.5	2.5	2.6	2.8	3.1	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.521	0.526	0.492	0.472	0.454	0.441	0.430	0.443	0.459	0.507	0.532	0.527	(40)	
(41)		taud	2.134	2.126	2.226	2.284	2.331	2.372	2.397	2.330	2.279	2.140	2.084	2.110	(41)	
(42)		Ebn at Noon	831	825	840	828	814	810	829	842	855	831	816	822	(42)	
(43)		Edh at Noon	165	167	148	134	122	114	113	126	138	162	172	168	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.25	5.44	5.54	5.46	5.14	4.88	5.10	5.64	6.26	6.42	5.86	5.13	(44)	
(45)		RadStd	0.47	0.38	0.43	0.39	0.35	0.28	0.23	0.17	0.27	0.46	0.50	0.46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	+0.64	N/A	-0.18	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page