

WEST ISLAND, Cocos (Keeling) IslandsWMO: **969960**Lat: **12.1892S**Lon: **96.8344E**Elev: **13**StdP: **14.69**Time Zone: **6.50 (MYR)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	74.1	75.0	63.3	87.0	78.3	64.5	90.9	78.4	26.8	78.6	25.3	78.9	13.1	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	6.8	87.4	79.5	86.3	78.5	86.1	78.2	80.8	84.9	80.1	84.2	79.6	83.8	12.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.8	84.0	78.9	150.1	83.7	78.4	147.3	83.3	44.4	85.8	43.9	84.5	43.2	84.3	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	23.2	21.8	DB	71.9	88.1	1.1	0.9	71.1	88.8	70.5	89.3	69.8	89.8	69.0	90.4	(4)
(5)			WB	65.3	81.8	1.8	1.5	64.0	82.9	63.0	83.7	62.0	84.6	60.7	85.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.7	81.6	82.0	82.0	82.1	81.5	80.5	79.4	79.2	79.2	79.9	80.5	80.9
	DBStd	1.79	1.40	1.58	1.57	1.68	1.38	1.54	1.50	1.40	1.38	1.23	1.17	1.32
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11211	979	895	993	962	977	914	912	904	875	928	914	958
	CDD65	5736	514	475	528	512	512	464	447	439	425	463	464	493
	CDH74	57144	5496	5274	5914	5700	5490	4559	3999	3712	3546	4131	4408	4915
	CDH80	11528	1374	1490	1685	1589	1272	764	427	337	350	549	707	984
Wind	WSAvg	13.7	10.7	10.3	10.6	12.8	14.1	14.6	16.2	16.4	16.4	15.2	14.6	12.7
Precipitation	PrecAvg	73.1	7.2	7.5	9.6	10.4	7.6	8.0	7.7	4.3	3.1	2.2	3.2	4.5
	PrecMax	117.3	22.1	38.9	24.8	23.4	22.4	25.6	20.2	18.0	10.9	11.3	14.1	17.6
	PrecMin	33.2	0.0	0.3	1.5	1.7	0.7	0.3	1.0	0.6	0.1	0.0	0.1	0.1
	PrecStd	21.2	5.7	5.9	4.9	5.8	5.1	5.2	4.8	3.4	2.9	2.2	3.4	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.8	88.0	88.0	88.0	86.4	86.0	84.5	84.4	84.4	84.6	85.8	86.3
		MCWB	78.9	79.2	80.2	80.9	79.6	79.0	77.3	77.1	76.8	76.2	76.7	77.3
	2%	DB	86.3	86.4	86.7	86.4	85.9	84.6	83.9	82.8	83.2	84.3	84.5	85.7
		MCWB	77.3	78.2	79.1	79.4	79.1	77.7	76.7	75.3	75.2	75.9	75.8	76.9
	5%	DB	85.9	86.2	86.2	86.1	84.6	84.2	82.7	82.6	82.6	83.1	84.2	84.5
		MCWB	77.0	78.0	78.6	79.0	78.0	77.4	75.6	75.0	74.6	75.0	75.6	76.1
	10%	DB	84.6	85.7	85.7	85.3	84.3	83.3	82.3	82.1	82.2	82.6	83.2	84.1
		MCWB	76.2	77.7	78.3	78.5	77.7	76.8	75.3	74.7	74.2	74.6	75.1	75.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	80.8	81.4	81.9	81.4	80.1	79.2	78.9	78.5	78.7	79.2	79.8
		MCDB	84.7	85.3	85.6	86.4	84.9	83.7	81.8	82.0	82.4	82.7	82.7	83.1
	2%	WB	79.3	80.0	80.4	80.8	80.1	79.1	78.2	77.4	77.1	77.5	78.3	79.0
		MCDB	83.8	84.7	84.9	85.0	83.7	82.8	81.6	81.2	81.5	81.9	82.1	82.7
	5%	WB	78.8	79.2	79.7	80.0	79.4	78.5	77.3	76.5	76.2	76.7	77.5	78.3
		MCDB	83.4	84.0	84.3	84.2	83.2	82.4	81.1	80.8	80.9	81.5	81.6	82.3
	10%	WB	78.1	78.7	79.1	79.2	78.8	77.9	76.6	75.6	75.4	76.0	76.7	77.6
		MCDB	82.8	83.6	83.7	83.6	82.8	81.9	80.7	80.4	80.4	81.2	81.3	82.0
Mean Daily Temperature Range	5% DB	MDBR	7.0	6.9	6.8	6.1	5.6	5.4	5.3	5.3	5.7	6.0	6.1	6.6
		MCDBR	7.6	7.3	7.2	6.6	5.9	5.9	5.7	5.6	6.0	6.3	6.6	7.0
		MCWBR	3.9	4.0	3.9	3.8	3.7	3.6	3.7	3.6	3.7	3.7	3.7	3.7
	5% WB	MCDBR	6.9	7.0	6.9	6.4	5.8	5.8	5.5	5.4	5.7	6.0	5.9	6.4
		MCWBR	4.0	4.1	4.1	3.9	3.7	3.6	3.8	3.7	3.7	3.7	3.7	3.9
Clear-Sky Solar Irradiance	taub	0.389	0.393	0.394	0.408	0.415	0.412	0.413	0.408	0.421	0.428	0.427	0.401	
	taud	2.593	2.595	2.598	2.556	2.518	2.512	2.498	2.489	2.434	2.410	2.441	2.546	
	Ebn at Noon	303	299	293	279	267	262	265	275	281	285	289	298	
	Edh at Noon	33	33	32	32	31	31	32	34	37	39	38	35	
All-Sky Solar Radiation	RadAvg	2096	2054	1867	1647	1504	1359	1434	1685	1879	2073	2077	2098	
	RadStd	197	130	109	118	95	100	101	80	145	151	180	131	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page