

WEST ISLAND, Cocos (Keeling) IslandsWMO: **969960**Lat: **12.1892S**Lon: **96.8344E**Elev: **4**StdP: **101.28**Time Zone: **6.50 (MYR)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	23.4	23.9	17.4	12.4	25.7	18.1	13.0	25.8	12.0	25.9	11.3	26.0	5.8	120	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	3.8	30.8	26.4	30.2	25.8	30.0	25.7	27.1	29.4	26.7	29.0	26.4	28.8	5.4	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.7	28.9	26.1	21.4	28.7	25.8	21.0	28.5	85.4	29.9	84.1	29.2	82.6	29.0	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	10.4	9.7	22.2	31.2	0.6	0.5	21.7	31.5	21.4	31.8	21.0	32.1	20.6	32.4		
(5)			18.5	27.7	1.0	0.8	17.8	28.3	17.2	28.7	16.7	29.2	15.9	29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	27.5	27.8	27.8	27.8	27.5	26.9	26.4	26.2	26.2	26.6	26.9	27.2		
	DBStd	0.99	0.78	0.88	0.87	0.94	0.77	0.85	0.83	0.78	0.77	0.68	0.65	0.74		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6228	544	497	552	534	543	508	507	502	486	516	508	532		
	CDD18.3	3187	286	264	293	284	284	258	248	244	236	257	258	274		
	CDH23.3	31747	3053	2930	3286	3167	3050	2533	2222	2062	1970	2295	2449	2731		
	CDH26.7	6404	763	828	936	883	707	424	237	187	194	305	393	547		
(14) Wind	WSAvg	6.1	4.8	4.6	4.8	5.7	6.3	6.5	7.3	7.3	7.3	6.8	6.5	5.7		
(15) Precipitation	PrecAvg	1858	184	191	244	263	192	202	195	108	80	57	82	115		
	PrecMax	2980	561	988	630	595	569	649	513	456	277	287	359	447		
	PrecMin	844	1	7	39	42	17	7	25	14	3	0	2	3		
	PrecStd	538	144	150	125	148	130	133	123	86	73	57	86	97		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.0	31.1	31.1	31.1	30.2	30.0	29.2	29.1	29.1	29.2	29.9	30.2		
		MCWB	26.1	26.2	26.8	27.2	26.5	26.1	25.2	25.0	24.9	24.6	24.8	25.2		
	2%	DB	30.2	30.2	30.4	30.2	29.9	29.2	28.8	28.2	28.4	29.0	29.2	29.8		
		MCWB	25.2	25.7	26.2	26.3	26.2	25.4	24.8	24.1	24.0	24.4	24.3	24.9		
	5%	DB	29.9	30.1	30.1	30.0	29.2	29.0	28.2	28.1	28.1	28.4	29.0	29.2		
		MCWB	25.0	25.6	25.9	26.1	25.6	25.2	24.2	23.9	23.6	23.9	24.2	24.5		
	10%	DB	29.2	29.8	29.8	29.6	29.0	28.5	27.9	27.8	27.9	28.1	28.4	29.0		
		MCWB	24.6	25.4	25.7	25.9	25.4	24.9	24.1	23.7	23.5	23.7	23.9	24.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.8	27.1	27.5	27.7	27.4	26.7	26.2	26.1	25.9	25.9	26.2	26.6		
		MCDB	29.3	29.6	29.8	30.2	29.4	28.7	27.7	27.8	28.0	28.2	28.1	28.4		
	2%	WB	26.3	26.7	26.9	27.1	26.7	26.2	25.7	25.2	25.0	25.3	25.7	26.1		
		MCDB	28.8	29.3	29.4	29.4	28.7	28.2	27.5	27.3	27.5	27.7	27.8	28.2		
	5%	WB	26.0	26.2	26.5	26.6	26.3	25.8	25.2	24.7	24.5	24.8	25.3	25.7		
		MCDB	28.5	28.9	29.0	29.0	28.4	28.0	27.3	27.1	27.2	27.5	27.6	28.0		
	10%	WB	25.6	26.0	26.1	26.2	26.0	25.5	24.8	24.2	24.1	24.5	24.9	25.3		
		MCDB	28.2	28.7	28.7	28.6	28.2	27.7	27.1	26.9	26.9	27.3	27.4	27.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.9	3.8	3.8	3.4	3.1	3.0	2.9	2.9	3.2	3.3	3.4	3.6		
		MCDBR	4.2	4.1	4.0	3.7	3.3	3.3	3.2	3.1	3.3	3.5	3.7	3.9		
	5% WB	MCWBR	2.2	2.2	2.2	2.1	2.0	2.0	2.1	2.0	2.1	2.0	2.1	2.1		
		MCWBR	3.8	3.9	3.8	3.6	3.2	3.2	3.1	3.0	3.1	3.3	3.3	3.6		
(40) Clear-Sky Solar Irradiance	taub		0.389	0.393	0.394	0.408	0.415	0.412	0.413	0.408	0.421	0.428	0.427	0.401		
	taud		2.593	2.595	2.598	2.556	2.518	2.512	2.498	2.489	2.434	2.410	2.441	2.546		
	Ebn at Noon		954	943	924	880	842	827	835	867	886	900	912	940		
	Edh at Noon		105	104	101	101	99	97	100	106	118	124	121	110		
(44) All-Sky Solar Radiation	RadAvg		6.61	6.48	5.89	5.19	4.74	4.28	4.52	5.31	5.92	6.53	6.55	6.62		
	RadStd		0.62	0.41	0.34	0.37	0.30	0.32	0.32	0.25	0.46	0.47	0.57	0.41		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page