

POSO KASIGUNCU, Indonesia

WMO: **970960**Lat: **1.4203S**Lon: **120.6569E**Elev: **2**StdP: **101.30**Time Zone: **8.00 (E08)**Period: **95-19**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	21.9	22.5	18.3	13.2	27.6	19.5	14.2	27.4	6.0	31.7	5.4	31.2	0.4	N/A	0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.8	33.0	25.8	32.6	25.9	32.2	26.1	27.7	31.4	27.3	31.1	27.1	31.0	3.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.6	22.2	29.9	26.2	21.6	29.6	26.0	21.4	29.4	87.9	31.5	86.5	31.4	85.5	31.1	33.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.5	5.3	4.8	20.0	34.8	1.3	1.4	19.1	35.8	18.3	36.6	17.6	37.4	16.7	38.4		
(5)			18.7	30.1	2.0	1.8	17.3	31.4	16.1	32.4	15.0	33.4	13.6	34.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	27.3	27.2	27.7	27.6	27.8	27.5	27.4	27.7	27.6	27.6	27.7	27.7		
	DBStd	0.76	0.64	0.81	0.61	0.71	0.64	0.79	0.76	0.85	0.88	0.73	0.72	0.69		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6416	537	482	548	529	553	524	539	548	529	546	531	549		
	CDD18.3	3374	278	248	289	279	295	274	281	289	279	288	281	291		
	CDH23.3	34192	2670	2343	2924	2810	3033	2702	2769	2973	2947	3046	2966	3010		
	CDH26.7	12579	867	779	1046	993	1144	966	1013	1150	1202	1216	1117	1086		
(14) Wind	WSAvg	1.3	1.0	1.1	1.2	1.2	1.3	1.2	1.5	1.8	1.8	1.5	1.3	1.1		
(15) Precipitation	PrecAvg	2288	162	160	223	275	259	205	167	129	130	163	185	200		
	PrecMax	3297	417	389	337	472	601	408	425	266	306	460	418	567		
	PrecMin	1535	3	19	74	88	102	28	29	1	45	34	56	55		
	PrecStd	461	103	109	70	102	132	82	95	79	73	96	85	124		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.2	32.7	32.7	33.0	32.7	32.7	33.3	33.8	33.4	33.0	32.7		
		MCWB	26.6	26.4	26.8	27.0	27.0	26.4	25.1	24.3	23.8	25.3	26.6	26.8		
	2%	DB	31.6	31.7	32.2	32.2	32.4	32.2	32.1	32.5	32.8	32.5	32.2	32.1		
		MCWB	26.4	26.3	26.5	26.9	26.9	26.4	25.6	24.8	24.7	25.8	26.6	26.7		
	5%	DB	31.1	31.2	31.7	31.7	32.0	31.6	31.6	32.0	32.2	32.0	31.9	31.7		
		MCWB	26.3	26.2	26.4	26.7	26.9	26.2	25.6	25.1	25.1	26.0	26.6	26.7		
	10%	DB	30.6	30.7	31.1	31.1	31.4	31.0	31.0	31.4	31.6	31.5	31.4	31.1		
		MCWB	26.2	26.1	26.3	26.5	26.7	26.1	25.6	25.2	25.2	26.0	26.5	26.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.3	27.5	27.7	27.7	28.0	27.5	27.7	27.2	27.1	27.4	27.6	27.7		
		MCDB	30.9	30.7	31.4	31.5	31.8	31.3	30.9	31.0	31.1	31.5	31.4	31.4		
	2%	WB	27.0	26.9	27.2	27.2	27.5	27.0	26.7	26.5	26.6	26.9	27.2	27.2		
		MCDB	30.6	30.6	31.0	31.1	31.3	30.9	30.6	30.5	30.8	31.0	31.1	31.0		
	5%	WB	26.7	26.6	26.8	27.0	27.1	26.7	26.3	26.1	26.2	26.6	26.9	27.0		
		MCDB	30.1	30.2	30.6	30.8	31.0	30.4	30.1	30.1	30.4	30.7	30.8	30.8		
	10%	WB	26.4	26.2	26.5	26.6	26.8	26.4	25.9	25.7	25.8	26.2	26.6	26.7		
		MCDB	29.7	29.8	30.2	30.2	30.6	30.0	29.7	29.6	29.9	30.3	30.4	30.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.1	7.3	7.3	7.7	7.5	7.8	8.2	8.8	8.5	7.8	7.3		
		MCDBR	7.5	7.8	7.9	7.9	8.2	8.3	8.3	8.7	9.4	9.0	8.2	7.8		
		MCWBR	3.4	3.5	3.6	3.6	3.7	3.6	3.7	3.8	4.2	4.0	3.7	3.5		
	5% WB	MCDBR	7.0	7.4	7.4	7.6	7.8	7.6	7.8	8.2	8.7	8.2	7.9	7.4		
		MCWBR	3.5	3.7	3.6	3.6	3.7	3.6	3.8	3.9	4.1	3.8	3.7	3.5		
(40) Clear-Sky Solar Irradiance	taub		0.415	0.422	0.423	0.414	0.410	0.401	0.406	0.431	0.455	0.521	0.466	0.429		
	taud		2.461	2.437	2.441	2.465	2.491	2.536	2.518	2.429	2.355	2.143	2.313	2.428		
	Ebn at Noon		917	912	903	889	869	864	865	862	861	815	863	899		
	Edh at Noon		117	121	120	114	107	100	103	116	129	161	135	120		
(44) All-Sky Solar Radiation	RadAvg		4.88	4.98	5.09	5.00	4.82	4.56	4.63	5.04	5.63	5.50	5.17	4.84		
	RadStd		0.25	0.28	0.22	0.18	0.20	0.29	0.39	0.35	0.29	0.32	0.20	0.27		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	+0.40	+0.26	+0.77	N/A	+0.42	+0.37	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page