

UJANG PANDANG PAOTERE, Indonesia

WMO: 971820

Lat: 5.1103S

Lon: 119.4197E

Elev: 2

StdP: 101.30

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	23.9	17.7	12.7	25.8	18.8	13.6	26.2	15.0	26.3	11.1	27.1	1.8	130	0.372

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	7.1	33.4	27.2	33.0	27.2	32.7	27.1	28.8	32.0	28.4	31.8	28.1	31.7	3.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.0	31.6	27.5	23.3	31.3	27.1	22.8	31.0	93.8	32.1	91.8	32.0	90.2	31.8	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	6.4	5.4	21.7	35.2	2.0	2.0	20.2	36.6	19.0	37.8	17.9	38.9	16.4	40.4		
			18.6	30.0	1.2	0.6	17.8	30.4	17.0	30.7	16.3	31.1	15.5	31.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.3	27.5	27.6	28.1	28.7	29.0	28.4	28.0	28.2	28.6	29.1	28.9	27.8
	DBStd	1.10	1.32	1.12	1.19	0.92	0.78	0.83	0.77	0.69	0.73	0.74	0.84	1.31
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6692	542	493	560	561	589	553	559	564	557	593	568	553
	CDD18.3	3651	283	260	302	311	331	303	301	306	307	334	318	295
	CDH23.3	42327	2916	2718	3316	3658	4051	3524	3416	3655	3829	4256	3849	3140
(13) Wind	CDH26.7	16099	847	817	1139	1434	1694	1350	1264	1446	1613	1902	1586	1007
	WSAvg	2.2	2.8	2.7	2.2	1.9	1.8	1.8	1.9	2.1	2.1	2.2	2.1	2.5
	PrecAvg	3170	732	556	391	225	122	78	44	17	35	104	254	611
	PrecMax	5052	1282	1124	717	563	262	196	289	109	310	422	732	978
	PrecMin	2208	133	77	170	47	28	8	0	6	10	5	55	174
	PrecStd	700	229	240	168	107	63	60	64	24	58	97	156	227
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	32.6	33.0	33.3	33.6	33.2	32.7	32.7	33.4	34.1	33.7	32.9
		MCWB	27.9	27.6	28.1	28.0	27.7	27.0	26.3	25.8	26.4	27.0	27.6	28.1
	2%	DB	32.0	31.8	32.3	32.8	33.0	32.5	32.1	32.2	32.7	33.4	33.1	32.2
		MCWB	27.6	27.4	27.8	27.6	27.5	26.7	26.0	25.7	26.1	26.9	27.6	27.8
	5%	DB	31.2	31.2	31.8	32.3	32.6	32.1	31.6	31.7	32.3	32.9	32.6	31.6
		MCWB	27.2	27.2	27.5	27.5	27.3	26.5	25.8	25.5	26.0	26.7	27.5	27.6
	10%	DB	30.3	30.4	31.1	31.8	32.1	31.5	31.2	31.4	31.9	32.4	32.0	30.8
		MCWB	26.8	26.9	27.2	27.3	27.1	26.3	25.6	25.4	25.9	26.6	27.4	27.2
	0.4%	WB	28.6	28.6	29.0	29.2	28.9	28.3	27.7	27.6	28.2	28.2	29.2	28.9
		MCDB	31.8	31.8	32.1	32.5	32.5	31.7	31.4	31.4	31.6	32.5	32.1	32.0
	2%	WB	28.0	28.0	28.4	28.5	28.2	27.7	27.0	26.9	27.3	27.8	28.6	28.2
		MCDB	31.3	31.0	31.6	32.0	32.1	31.5	31.2	31.0	31.3	32.1	31.9	31.5
(33) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	27.5	27.5	27.9	28.0	27.8	27.1	26.5	26.5	26.9	27.4	28.1	27.7
		MCDB	30.6	30.4	31.1	31.6	31.8	31.1	30.7	30.7	31.1	31.8	31.8	31.0
	10%	WB	26.9	27.0	27.4	27.5	27.4	26.7	26.1	26.0	26.5	27.0	27.6	27.2
		MCDB	29.8	29.9	30.5	31.1	31.3	30.6	30.3	30.4	30.8	31.5	31.4	30.2
	5% DB	MDBR	4.9	5.2	5.6	6.3	6.4	6.4	6.6	6.8	7.0	7.1	6.4	5.2
		MCDBR	6.2	6.5	6.6	6.8	6.9	7.0	7.2	7.2	7.4	7.5	6.9	6.5
(37) Mean Daily Temperature Range	5% WB	MCWBR	3.4	3.6	3.7	3.7	3.7	3.6	3.7	4.1	4.5	4.3	3.9	3.7
		MCDBR	5.9	5.9	6.3	6.5	6.6	6.4	6.6	6.7	7.0	7.1	6.6	6.2
	5% WB	MCWBR	3.6	3.6	3.9	3.9	3.7	3.6	3.8	4.3	4.5	4.3	4.1	3.8
	Clear-Sky Solar Irradiance	taub	0.434	0.434	0.425	0.416	0.414	0.415	0.405	0.414	0.434	0.474	0.473	0.440
		taud	2.435	2.417	2.448	2.489	2.497	2.496	2.516	2.462	2.382	2.259	2.289	2.417
(42) All-Sky Solar Radiation	Ebn at Noon	904	903	900	883	858	843	859	873	879	857	863	896	
	Edh at Noon	121	124	119	110	105	102	102	111	125	144	139	123	
(44) All-Sky Solar Radiation	RadAvg	4.55	4.83	5.29	5.41	5.24	4.89	5.29	6.07	6.61	6.51	5.74	4.61	
	RadStd	0.46	0.43	0.36	0.33	0.26	0.39	0.37	0.30	0.33	0.53	0.46	0.43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	+0.24	N/A	N/A	+0.55	+0.72	+0.88	N/A	N/A	N/A	N/A

Nomenclature: See separate page