

BAU-BAU BETO AMBIRI, Indonesia

WMO: 971920

Lat: 5.4878S

Lon: 122.5708E

Elev: 7

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	70.6	71.9	62.1	83.3	86.6	64.6	91.2	84.8	15.9	82.9	14.0	83.5	1.7	130	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	12.9	92.4	77.1	91.4	77.5	90.5	77.6	81.2	87.7	80.8	87.4	80.5	86.9	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.5	153.0	84.5	79.0	150.8	84.2	78.6	148.7	83.9	44.9	88.2	44.4	87.7	44.0	87.3	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.4	9.8	DB	65.4	95.3	5.2	1.9	61.7	96.7	58.7	97.8	55.8	98.9	52.0	100.4	(4)
(5)			WB	65.3	83.4	2.3	2.2	63.6	85.0	62.3	86.3	61.0	87.5	59.3	89.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	82.9	82.3	82.1	81.9	81.4	80.2	79.6	80.3	81.4	82.7	83.1	82.7
	DBStd	2.00	1.89	1.55	1.63	1.45	1.77	1.76	1.73	1.53	1.58	1.45	1.71	1.89
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11577	1019	906	995	957	972	907	919	941	941	1015	992	1013
	CDD65	6102	554	486	530	507	507	457	454	476	491	550	542	548
	CDH74	62979	6175	5167	5636	5222	4933	4105	3894	4443	5002	6112	6251	6039
CDH80	21904	2172	1730	1860	1679	1513	1162	1126	1590	1960	2507	2484	2121	
Wind	WSAvg	3.7	4.2	3.9	3.4	3.0	2.9	3.3	3.8	4.5	4.2	4.0	3.8	3.7
Precipitation	PrecAvg	70.9	10.9	8.7	8.4	5.9	7.3	6.3	3.5	1.0	2.4	1.9	5.2	10.0
	PrecMax	113.4	26.3	13.8	14.4	13.4	20.5	16.9	13.1	5.7	8.7	10.6	11.2	16.7
	PrecMin	38.2	4.8	0.9	3.0	0.0	1.3	1.0	0.0	0.0	0.0	0.0	0.0	4.1
	PrecStd	22.1	5.2	3.5	3.5	3.3	4.2	4.9	4.3	1.6	2.9	2.9	3.3	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.5	91.3	90.8	90.9	90.9	89.5	89.2	90.8	93.0	94.2	93.7	92.7
		MCWB	79.6	80.0	80.4	78.9	78.7	77.5	75.9	74.3	74.1	74.5	77.8	79.8
	2%	DB	90.7	89.8	89.5	89.6	89.5	88.2	88.0	89.6	91.3	92.1	91.9	90.7
		MCWB	79.6	79.6	79.9	79.1	79.0	77.6	75.9	73.9	74.3	75.8	78.1	79.7
	5%	DB	89.3	88.6	88.4	88.5	88.3	87.2	87.0	88.5	89.9	90.8	90.7	89.3
		MCWB	79.7	79.4	79.7	79.1	79.0	77.5	75.8	73.9	74.4	76.5	78.2	79.8
	10%	DB	87.9	87.5	87.4	87.3	87.0	85.9	85.7	87.3	88.7	89.6	89.3	88.0
		MCWB	79.5	79.1	79.5	79.1	78.9	77.3	75.7	74.0	74.7	76.9	78.5	79.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.6	81.3	81.8	81.4	81.4	80.8	79.2	78.4	79.5	80.5	81.4	81.6
		MCDB	88.3	88.1	88.0	87.2	87.4	86.1	84.9	84.0	85.4	87.7	88.4	88.6
	2%	WB	80.8	80.5	80.9	80.7	80.6	79.7	78.3	77.4	78.6	79.7	80.6	80.9
		MCDB	87.6	87.5	87.3	86.6	86.6	85.0	84.0	84.2	85.2	87.1	87.6	87.6
	5%	WB	80.2	80.0	80.3	80.1	80.0	78.9	77.6	76.5	77.9	79.1	80.0	80.4
		MCDB	86.6	86.6	86.6	85.8	85.8	84.3	83.4	83.9	84.7	86.6	86.9	87.0
	10%	WB	79.8	79.5	79.8	79.6	79.4	78.1	76.9	75.7	77.0	78.5	79.5	80.0
		MCDB	85.9	85.7	85.8	85.2	85.0	83.3	82.7	83.3	84.1	85.9	86.3	86.0
Mean Daily Temperature Range	5% DB	MDBR	10.5	11.1	11.1	11.2	11.1	11.3	12.5	14.8	15.8	15.0	12.9	10.9
		MCDBR	12.4	12.5	12.4	13.0	13.4	13.4	14.6	16.5	17.8	16.9	15.0	12.6
		MCWBR	4.3	4.8	5.0	4.8	5.0	5.2	5.2	4.9	5.1	5.3	4.9	4.6
	5% WB	MCDBR	11.0	11.5	11.4	11.4	11.6	11.0	11.7	13.5	13.5	13.8	12.6	11.5
		MCWBR	4.2	4.8	5.1	5.0	5.2	5.2	5.4	5.4	5.5	5.4	5.1	4.7
Clear-Sky Solar Irradiance	taub	0.424	0.425	0.415	0.406	0.417	0.429	0.416	0.418	0.424	0.447	0.443	0.425	
	taud	2.457	2.446	2.472	2.519	2.489	2.449	2.483	2.453	2.417	2.333	2.369	2.449	
	Ebn at Noon	290	290	288	283	271	263	269	276	281	279	282	289	
	Edh at Noon	38	38	37	34	33	34	33	36	38	43	41	38	
All-Sky Solar Radiation	RadAvg	1619	1632	1695	1646	1517	1392	1559	1820	2034	2063	1903	1571	
	RadStd	119	100	105	117	118	145	134	115	117	163	161	133	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page