

BAU-BAU BETO AMBIRI, Indonesia

WMO: 971920

Lat: 5.4878S

Lon: 122.5708E

Elev: 2

StdP: 101.30

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	22.2	16.7	11.9	30.4	18.1	13.0	29.3	7.1	28.3	6.2	28.6	0.8	130	0.316

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	7.2	33.6	25.1	33.0	25.3	32.5	25.4	27.3	30.9	27.1	30.8	26.9	30.5	3.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.2	26.1	21.5	29.0	25.9	21.2	28.8	86.5	31.2	85.4	31.0	84.4	30.7	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 5.9	5.1	4.4	DB	18.6	35.2	2.9	1.1	16.5	35.9	14.8	36.6	13.2	37.2	11.1	38.0	(4)
(5)			WB	18.5	28.6	1.3	1.2	17.6	29.4	16.8	30.2	16.1	30.9	15.1	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	28.3	28.0	27.8	27.7	27.4	26.8	26.5	26.9	27.4	28.2	28.4	28.1	(6)	
	DBStd	1.11	1.05	0.86	0.91	0.80	0.98	0.98	0.96	0.85	0.88	0.81	0.95	1.05	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6432	566	503	553	532	540	504	511	523	523	564	551	563	(10)	
	CDD18.3	3390	308	270	294	282	282	254	252	264	273	306	301	304	(11)	
	CDH23.3	34988	3431	2871	3131	2901	2741	2281	2163	2468	2779	3396	3473	3355	(12)	
(13)	CDH26.7	12169	1207	961	1033	933	841	646	626	883	1089	1393	1380	1178	(13)	
(14)	Wind	WSAvg	1.7	1.9	1.7	1.5	1.3	1.3	1.5	1.7	2.0	1.9	1.8	1.7	1.6	(14)
(15) Precipitation	PrecAvg	1800	276	222	214	150	185	161	90	26	61	48	131	253	(15)	
	PrecMax	2880	668	350	367	341	521	428	333	144	220	270	285	424	(16)	
	PrecMin	970	122	23	76	0	32	26	0	0	0	0	0	104	(17)	
	PrecStd	562	133	88	90	83	107	125	109	40	74	73	85	95	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.6	33.0	32.7	32.7	32.7	31.9	31.8	32.7	33.9	34.6	34.3	33.7	(19)	
		MCWB	26.4	26.7	26.9	26.1	25.9	25.3	24.4	23.5	23.4	23.6	25.4	26.5	(20)	
	2%	DB	32.6	32.1	31.9	32.0	32.0	31.2	31.1	32.0	33.0	33.4	33.3	32.6	(21)	
		MCWB	26.5	26.5	26.6	26.1	26.1	25.3	24.4	23.3	23.5	24.3	25.6	26.5	(22)	
	5%	DB	31.8	31.4	31.3	31.4	31.3	30.6	30.5	31.4	32.2	32.7	32.6	31.8	(23)	
		MCWB	26.5	26.3	26.5	26.2	26.1	25.3	24.3	23.3	23.6	24.7	25.7	26.6	(24)	
	10%	DB	31.1	30.8	30.8	30.7	30.5	30.0	29.8	30.7	31.5	32.0	31.8	31.1	(25)	
		MCWB	26.4	26.2	26.4	26.2	26.0	25.2	24.3	23.3	23.7	25.0	25.8	26.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	27.4	27.6	27.4	27.4	27.1	26.2	25.8	26.4	26.9	27.4	27.6	(27)	
		MCDB	31.3	31.2	31.1	30.7	30.8	30.1	29.4	28.9	29.7	30.9	31.3	31.4	(28)	
	2%	WB	27.1	27.0	27.2	27.0	27.0	26.5	25.7	25.2	25.9	26.5	27.0	27.2	(29)	
		MCDB	30.9	30.8	30.7	30.3	30.3	29.5	28.9	29.0	29.6	30.6	30.9	30.9	(30)	
	5%	WB	26.8	26.6	26.8	26.7	26.7	26.0	25.3	24.7	25.5	26.2	26.7	26.9	(31)	
		MCDB	30.3	30.3	30.3	29.9	29.9	29.1	28.5	28.8	29.3	30.3	30.5	30.5	(32)	
	10%	WB	26.6	26.4	26.6	26.5	26.3	25.6	24.9	24.3	25.0	25.8	26.4	26.6	(33)	
		MCDB	30.0	29.9	29.9	29.6	29.4	28.5	28.2	28.5	28.9	29.9	30.2	30.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.8	6.1	6.1	6.2	6.2	6.3	6.9	8.2	8.8	8.3	7.2	6.1	(35)	
		MCDBR	6.9	7.0	6.9	7.2	7.4	7.5	8.1	9.1	9.9	9.4	8.3	7.0	(36)	
	5% WB	MCWBR	2.4	2.7	2.8	2.7	2.8	2.9	2.9	2.7	2.8	2.9	2.7	2.6	(37)	
		MCWBR	6.1	6.4	6.3	6.3	6.4	6.1	6.5	7.5	7.5	7.7	7.0	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.424	0.425	0.415	0.406	0.417	0.429	0.416	0.418	0.424	0.447	0.443	0.425	(40)	
		taud	2.457	2.446	2.472	2.519	2.489	2.449	2.483	2.453	2.417	2.333	2.369	2.449	(41)	
	Ebn at Noon	Ebn at Noon	915	913	909	892	855	829	848	869	887	881	890	910	(42)	
		Edh at Noon	119	121	116	107	105	107	105	112	121	134	129	119	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	5.10	5.14	5.34	5.19	4.78	4.39	4.91	5.74	6.41	6.50	6.00	4.95	(44)	
	RadStd	RadStd	0.38	0.32	0.33	0.37	0.37	0.46	0.42	0.36	0.37	0.51	0.51	0.42	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page