

DENPASAR NGURAH RAI, Indonesia

WMO: 972300

Lat: 8.7494S

Lon: 115.1770E

Elev: 3

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	71.5	73.1	65.9	95.6	76.6	67.4	100.8	77.5	20.8	81.3	19.5	81.3	1.5	10	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	10.9	90.5	79.9	89.7	79.7	88.9	79.6	81.8	87.2	81.0	86.6	80.7	86.4	9.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.0	85.7	79.2	151.6	84.6	79.1	150.8	84.5	45.5	87.9	44.8	87.8	44.5	87.0	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.0	17.7	15.7	67.9	93.1	2.0	2.5	66.5	94.9	65.3	96.3	64.2	97.7	62.7	99.5		
(5)			65.3	83.8	1.8	1.6	64.0	84.9	62.9	85.9	61.9	86.8	60.6	87.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	82.2	82.4	82.5	82.6	81.9	81.0	80.0	79.7	80.5	82.1	83.0	82.6	(6)
(7)		DBStd	2.01	1.80	1.67	1.63	1.46	1.71	1.83	1.70	1.77	1.78	1.69	1.46	1.82	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11574	1000	906	1007	979	990	930	931	921	914	995	991	1010	(10)
(11)		CDD65	6099	535	486	542	529	525	480	466	456	464	530	541	545	(11)
(12)		CDH74	65542	5989	5518	6212	6181	5905	4952	4278	3991	4375	5708	6218	6215	(12)
(13)		CDH80	20360	1956	1851	2162	2233	1927	1265	831	774	1118	1866	2259	2118	(13)
(14)	Wind	WSAvg	7.3	8.1	7.5	6.0	6.0	7.0	8.5	9.2	9.2	7.4	6.3	5.2	7.0	(14)
(15)	Precipitation	PrecAvg	61.3	13.7	11.8	8.5	3.5	3.6	1.9	1.3	0.3	1.7	3.8	5.9	10.5	(15)
(16)		PrecMax	91.1	30.2	25.7	17.5	13.3	13.7	9.8	9.8	2.4	9.8	33.3	17.6	18.0	(16)
(17)		PrecMin	31.5	4.2	1.7	1.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	2.0	(17)
(18)		PrecStd	16.6	7.0	5.9	3.6	3.2	3.7	2.2	2.1	0.6	2.4	6.6	5.0	4.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.7	91.3	91.3	91.4	89.7	89.5	88.1	87.9	88.2	90.0	91.5	91.5	(19)
(20)			MCWB	79.8	80.2	80.3	80.9	79.8	79.4	78.9	77.6	77.7	79.2	79.9	80.5	(20)
(21)		2%	DB	89.2	89.3	89.5	89.5	88.1	87.6	86.1	86.0	87.5	89.2	89.9	89.6	(21)
(22)			MCWB	79.7	79.7	80.0	79.9	79.6	79.1	77.8	76.6	77.5	78.9	79.6	80.0	(22)
(23)		5%	DB	87.9	88.0	88.1	88.1	87.6	86.2	84.5	84.5	86.1	88.0	89.2	88.1	(23)
(24)			MCWB	79.8	79.7	79.8	79.8	79.5	78.3	76.6	75.9	77.0	78.8	79.5	79.8	(24)
(25)		10%	DB	86.4	87.1	87.5	87.6	86.3	85.3	84.0	83.9	84.9	87.2	87.9	87.4	(25)
(26)			MCWB	79.2	79.3	79.7	79.7	78.7	77.7	76.2	75.6	76.4	78.6	79.5	79.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	81.9	82.2	82.1	81.6	80.5	79.9	79.1	80.0	81.6	81.9	82.5	(27)
(28)			MCD B	87.0	87.4	87.7	87.7	86.2	86.3	85.4	84.5	85.2	86.9	87.6	87.7	(28)
(29)		2%	WB	80.8	80.9	81.0	81.0	80.6	79.7	78.9	78.2	79.1	80.4	81.0	81.2	(29)
(30)			MCD B	86.5	86.7	86.8	86.6	85.8	85.2	83.9	83.5	84.2	86.0	86.7	86.7	(30)
(31)		5%	WB	80.2	80.2	80.4	80.6	80.0	79.1	78.2	77.3	78.4	79.8	80.4	80.6	(31)
(32)			MCD B	85.7	85.9	86.3	86.1	85.1	84.3	83.0	82.6	83.5	85.2	86.1	86.1	(32)
(33)		10%	WB	79.6	79.7	79.9	80.0	79.5	78.5	77.4	76.5	77.7	79.2	79.9	79.9	(33)
(34)			MCD B	85.0	85.1	85.4	85.4	84.5	83.5	82.1	81.7	82.9	84.4	85.4	85.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.5	9.8	10.1	10.5	10.0	9.0	8.5	8.9	10.4	10.8	10.9	9.5	(35)
(36)			MCD BR	10.8	11.0	11.3	11.3	10.9	10.2	9.1	9.6	11.2	11.4	11.9	10.9	(36)
(37)			MCWBR	5.1	5.2	5.3	5.2	5.2	5.1	4.5	4.6	4.5	4.6	4.7	4.9	(37)
(38)		5% WB	MCD BR	10.0	10.2	10.5	10.6	10.0	9.5	8.8	8.8	9.8	10.6	11.2	10.1	(38)
(39)			MCWBR	5.2	5.2	5.4	5.2	5.0	4.9	4.7	4.5	4.6	4.7	4.9	5.1	(39)
(40)	Clear-Sky Solar Irradiance	taub		0.472	0.472	0.447	0.442	0.436	0.427	0.419	0.430	0.447	0.487	0.497	0.477	(40)
(41)		taud		2.309	2.315	2.377	2.400	2.409	2.432	2.447	2.388	2.332	2.216	2.211	2.291	(41)
(42)		Ebn at Noon		277	277	279	271	263	261	266	271	274	269	268	275	(42)
(43)		Edh at Noon		44	44	40	38	36	34	34	38	42	48	48	44	(43)
(44)	All-Sky Solar Radiation	RadAvg		1682	1736	1771	1773	1656	1569	1633	1818	2012	2073	1918	1686	(44)
(45)		RadStd		179	156	160	122	108	77	62	48	82	117	158	164	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+1.12	N/A	-0.31	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	+1.12	N/A	-0.31	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page