

DENPASAR NGURAH RAI, Indonesia

WMO: 972300

Lat: 8.7494S

Lon: 115.1770E

Elev: 1

StdP: 101.31

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.9	22.9	18.9	13.7	24.8	19.7	14.4	25.3	9.3	27.4	8.7	27.4	0.7	10	0.395

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	6.1	32.5	26.6	32.1	26.5	31.6	26.4	27.7	30.7	27.2	30.3	27.1	30.2	4.0	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	29.8	26.2	21.7	29.2	26.1	21.5	29.2	88.1	31.1	86.4	31.0	85.5	30.6	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.9	7.0	DB	19.9	33.9	1.1	1.4	19.1	34.9	18.5	35.7	17.9	36.5	17.1	37.5	(4)
(5)			WB	18.5	28.8	1.0	0.9	17.8	29.4	17.2	29.9	16.6	30.4	15.9	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	27.9	28.0	28.0	28.1	27.7	27.2	26.7	26.5	26.9	27.8	28.4	28.1	(6)	
	DBStd	1.12	1.00	0.93	0.90	0.81	0.95	1.01	0.94	0.98	0.99	0.94	0.81	1.01	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6430	556	503	559	544	550	517	517	512	508	553	551	561	(10)	
	CDD18.3	3388	297	270	301	294	292	267	259	253	258	294	301	303	(11)	
	CDH23.3	36412	3327	3066	3451	3434	3281	2751	2377	2217	2431	3171	3454	3453	(12)	
	CDH26.7	11311	1087	1028	1201	1241	1071	703	462	430	621	1037	1255	1177	(13)	
(14) Wind	WSAvg	3.3	3.6	3.3	2.7	2.7	3.1	3.8	4.1	4.1	3.3	2.8	2.3	3.1	(14)	
(15) Precipitation	PrecAvg	1558	347	300	217	90	92	48	33	8	44	97	151	267	(15)	
	PrecMax	2313	766	652	444	338	349	248	248	61	248	845	448	456	(16)	
	PrecMin	801	106	42	31	1	1	0	0	0	0	0	0	52	(17)	
	PrecStd	421	177	149	91	81	95	56	53	15	62	167	128	120	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	33.0	33.0	33.0	32.1	31.9	31.2	31.0	31.2	32.2	33.1	33.0	(19)	
		MCWB	26.6	26.8	26.8	27.2	26.6	26.3	26.0	25.3	25.4	26.2	26.6	27.0	(20)	
	2%	DB	31.8	31.9	32.0	31.9	31.2	30.9	30.0	30.0	30.8	31.8	32.1	32.0	(21)	
		MCWB	26.5	26.5	26.6	26.6	26.4	26.1	25.4	24.8	25.3	26.1	26.4	26.7	(22)	
	5%	DB	31.0	31.1	31.2	31.2	30.9	30.1	29.2	29.1	30.1	31.1	31.8	31.2	(23)	
		MCWB	26.6	26.5	26.6	26.6	26.4	25.7	24.8	24.4	25.0	26.0	26.4	26.6	(24)	
	10%	DB	30.2	30.6	30.8	30.9	30.2	29.6	28.9	28.8	29.4	30.7	31.1	30.8	(25)	
		MCWB	26.2	26.3	26.5	26.5	25.9	25.4	24.6	24.2	24.7	25.9	26.4	26.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	27.7	27.9	27.8	27.6	26.9	26.6	26.2	26.7	27.6	27.7	28.0	(27)	
		MCDB	30.5	30.8	30.9	31.0	30.1	30.2	29.7	29.1	29.5	30.5	30.9	30.9	(28)	
	2%	WB	27.1	27.1	27.2	27.2	27.0	26.5	26.1	25.7	26.2	26.9	27.2	27.3	(29)	
		MCDB	30.3	30.4	30.4	30.3	29.9	29.6	28.9	28.6	29.0	30.0	30.4	30.4	(30)	
	5%	WB	26.8	26.8	26.9	27.0	26.7	26.2	25.7	25.2	25.8	26.6	26.9	27.0	(31)	
		MCDB	29.8	29.9	30.1	30.1	29.5	29.0	28.3	28.1	28.6	29.6	30.0	30.1	(32)	
	10%	WB	26.5	26.5	26.6	26.7	26.4	25.9	25.2	24.7	25.4	26.2	26.6	26.6	(33)	
		MCDB	29.4	29.5	29.7	29.7	29.2	28.6	27.8	27.6	28.3	29.1	29.7	29.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	5.5	5.6	5.8	5.5	5.0	4.7	5.0	5.8	6.0	6.1	5.3	(35)	
		MCDBR	6.0	6.1	6.3	6.3	6.1	5.7	5.1	5.4	6.2	6.3	6.6	6.1	(36)	
	5% WB	MCWBR	2.8	2.9	3.0	2.9	2.9	2.8	2.5	2.5	2.5	2.5	2.6	2.7	(37)	
		MCWBR	5.5	5.7	5.9	5.9	5.5	5.3	4.9	4.9	5.5	5.9	6.2	5.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.472	0.472	0.447	0.442	0.436	0.427	0.419	0.430	0.447	0.487	0.497	0.477	(40)	
		taud	2.309	2.315	2.377	2.400	2.409	2.432	2.447	2.388	2.332	2.216	2.211	2.291	(41)	
	Edn at Noon		874	872	878	854	829	822	838	853	865	848	846	866	(42)	
		Edh at Noon	139	138	127	119	112	107	107	119	131	150	152	140	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.30	5.47	5.58	5.59	5.22	4.95	5.15	5.73	6.34	6.54	6.04	5.32	(44)	
	RadStd		0.56	0.49	0.50	0.38	0.34	0.24	0.19	0.15	0.26	0.37	0.50	0.52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	+0.62	N/A	-0.17	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	+0.62	N/A	-0.17	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page