

SUMBAWA BESAR BRANGBIJI, Indonesia

WMO: 972600

Lat: 8.4884S

Lon: 117.4135E

Elev: 3

StdP: 101.29

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.2	20.9	14.8	10.5	27.5	16.0	11.4	26.9	7.7	30.2	6.8	30.6	1.7	140	0.321

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	8.5	34.5	24.5	33.7	24.7	33.2	24.9	27.3	31.2	27.1	30.9	26.7	30.6	3.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.6	26.0	21.3	29.3	25.7	21.0	29.1	86.6	31.5	85.3	31.2	84.2	30.8	33.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 6.7	6.0	5.3	DB	18.3	36.8	2.3	1.3	16.7	37.8	15.4	38.5	14.1	39.3	12.4	40.2	(4)
(5)			WB	15.8	28.7	1.1	1.7	15.0	29.9	14.3	30.9	13.7	31.9	12.9	33.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.6	27.0	27.0	27.3	27.9	27.8	27.1	26.7	26.9	27.9	28.7	28.7	27.6	(6)
(7)		DBStd	1.11	0.82	0.77	0.78	0.88	0.88	0.97	0.90	0.95	0.97	0.93	1.01	0.88	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6409	528	475	536	537	551	514	518	523	538	581	561	547	(10)
(11)		CDD18.3	3367	270	242	277	287	293	264	259	264	288	322	311	289	(11)
(12)		CDH23.3	34219	2556	2248	2692	2993	2997	2539	2393	2547	3063	3712	3562	2917	(12)
(13)	CDH26.7	13393	739	634	891	1182	1234	1039	980	1092	1394	1688	1534	986	(13)	
(14)	Wind	WSAvg	2.2	1.8	1.9	1.7	1.8	2.1	2.5	2.6	2.7	2.5	2.1	1.7	(14)	
(15)	Precipitation	PrecAvg	1328	266	265	229	110	51	26	8	6	8	34	121	206	(15)
(16)		PrecMax	2058	744	531	399	253	203	196	86	55	43	185	423	445	(16)
(17)		PrecMin	804	32	66	89	1	0	0	0	0	0	0	8	41	(17)
(18)		PrecStd	344	150	125	88	71	58	46	18	14	13	41	99	99	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.4	32.1	32.9	33.7	33.6	33.2	32.8	33.4	35.0	35.6	35.5	33.4	(19)
MCWB			26.3	26.4	26.5	25.8	25.5	24.9	23.6	23.4	22.9	24.2	25.1	26.6	(20)	
2%		DB	31.4	31.2	32.0	33.0	32.9	32.5	32.2	32.7	34.0	34.5	34.2	32.3	(21)	
		MCWB	26.2	26.3	26.3	25.7	25.4	24.7	23.6	23.3	23.3	24.5	25.5	26.4	(22)	
5%		DB	30.7	30.6	31.3	32.4	32.3	31.9	31.6	32.1	33.2	33.7	33.2	31.6	(23)	
		MCWB	26.0	26.2	26.2	25.9	25.3	24.5	23.5	23.1	23.5	24.7	25.8	26.3	(24)	
10%		DB	30.0	29.9	30.6	31.7	31.7	31.3	31.1	31.5	32.5	32.9	32.4	30.8	(25)	
		MCWB	26.0	26.0	26.1	26.0	25.2	24.4	23.4	23.0	23.7	24.9	25.9	26.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.2	27.6	27.5	27.5	26.7	26.4	25.7	26.4	27.3	27.7	27.6	(27)
MCD B			30.8	30.5	31.3	31.5	31.4	30.9	30.2	30.4	31.3	31.8	31.7	31.7	(28)	
2%		WB	26.7	26.8	27.0	27.0	26.9	26.1	25.7	25.0	25.7	26.6	27.1	27.1	(29)	
		MCD B	29.9	29.8	30.5	31.2	30.9	30.5	29.9	30.3	30.7	31.4	31.5	31.0	(30)	
5%		WB	26.5	26.6	26.6	26.7	26.5	25.6	25.1	24.4	25.2	26.1	26.7	26.7	(31)	
		MCD B	29.6	29.6	30.1	30.8	30.6	30.1	29.6	30.0	30.4	31.2	31.2	30.4	(32)	
10%		WB	26.2	26.2	26.3	26.4	26.0	25.1	24.4	23.9	24.7	25.7	26.3	26.4	(33)	
		MCD B	29.2	29.1	29.7	30.4	30.2	29.7	29.1	29.7	30.0	30.8	30.9	30.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.2	6.1	7.0	8.2	8.7	9.2	9.7	10.4	10.6	9.8	8.5	6.9	(35)
MCDBR			7.3	7.2	8.1	9.2	9.3	9.7	10.2	10.7	11.2	10.6	9.4	7.8	(36)	
MCWBR			3.5	3.4	4.0	3.9	3.7	3.7	3.8	3.8	3.8	3.9	3.6	3.5	(37)	
5% WB		MCDBR	6.4	6.3	7.2	8.0	8.2	8.4	8.6	9.9	9.9	9.5	8.5	7.1	(38)	
		MCWBR	3.4	3.3	3.7	3.8	3.9	3.7	3.8	4.1	4.0	4.1	3.7	3.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.471	0.478	0.445	0.433	0.430	0.425	0.420	0.433	0.455	0.496	0.502	0.479	(40)	
taud		2.287	2.270	2.361	2.403	2.406	2.422	2.421	2.363	2.290	2.162	2.174	2.263	(41)		
Ebn at Noon		874	866	880	862	836	825	837	851	858	840	842	864	(42)		
Edh at Noon		142	144	129	119	113	108	110	122	137	159	158	144	(43)		
(44)	All-Sky Solar Radiation	RadAvg	5.06	5.17	5.34	5.45	5.25	4.99	5.14	5.75	6.37	6.55	6.08	5.21	(44)	
(45)		RadStd	0.55	0.48	0.50	0.42	0.33	0.23	0.18	0.17	0.26	0.37	0.45	0.47	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page