

KUPANG EL TARI, Indonesia

WMO: 973720

Lat: 10.1677S

Lon: 123.6704E

Elev: 354

StdP: 14.51

Time Zone: 8.00 (E08)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	68.3	69.9	57.3	71.0	83.2	60.2	78.8	81.7	29.8	84.9	28.0	84.2	3.0	120	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	15.4	93.9	77.0	92.6	77.2	91.4	77.3	82.6	88.5	81.9	87.8	81.2	87.2	12.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	163.0	86.7	80.2	158.8	85.9	79.6	155.5	85.3	46.9	88.8	46.0	88.1	45.3	87.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.8	20.1	17.9	DB	63.8	97.3	2.5	1.1	62.0	98.1	60.6	98.7	59.2	99.3	57.4	100.1	
			WB	60.4	84.3	2.3	1.3	58.7	85.2	57.4	85.9	56.1	86.6	54.4	87.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	80.9	80.8	81.0	82.2	81.9	80.3	79.7	80.1	81.3	83.1	83.6	82.0
	DBStd	2.29	2.03	1.90	1.83	1.78	1.74	2.31	2.13	1.95	2.14	2.11	1.72	2.14
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11463	958	861	961	967	990	909	921	933	939	1025	1008	991
	CDD65	5988	493	441	496	517	525	459	456	468	489	560	558	526
	CDH74	59912	4833	4195	4735	5295	5211	4105	3883	4098	5071	6448	6569	5469
	CDH80	22013	1405	1218	1527	2083	1920	1343	1299	1528	2133	2870	2857	1830
Wind	WSAvg	6.9	4.9	4.4	4.0	5.7	8.7	10.1	10.8	10.4	7.9	7.1	5.0	4.0
Precipitation	PrecAvg	66.5	15.7	17.2	10.1	3.8	0.9	0.4	0.2	0.1	0.2	0.8	4.3	12.8
	PrecMax	93.2	26.3	33.8	19.2	9.7	4.1	2.8	1.2	1.1	1.9	4.3	13.1	40.1
	PrecMin	49.0	4.7	6.3	1.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.4
	PrecStd	13.5	5.6	7.9	5.0	2.9	1.2	0.6	0.3	0.2	0.5	1.2	2.9	7.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.9	90.6	91.6	93.5	91.9	91.3	90.9	91.9	94.5	96.0	95.6	92.3
		MCWB	80.1	80.9	79.6	77.3	76.0	76.1	74.6	73.5	74.6	76.6	77.1	80.7
	2%	DB	89.0	88.9	89.9	91.7	90.8	89.6	89.3	90.3	92.5	94.1	93.4	90.5
		MCWB	80.3	80.6	79.9	77.5	76.6	75.8	74.1	73.1	74.9	76.9	78.4	80.8
	5%	DB	87.5	87.6	88.5	90.6	89.7	88.2	87.9	88.9	90.9	92.4	91.7	89.0
		MCWB	80.1	80.3	79.7	77.8	76.8	75.4	73.8	73.1	75.0	77.0	79.0	80.7
	10%	DB	86.1	86.1	87.0	89.1	88.5	86.8	86.5	87.4	89.3	90.7	90.3	87.5
		MCWB	79.7	79.7	79.5	78.0	76.5	74.9	73.2	72.7	74.9	77.0	79.1	80.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.8	83.0	82.9	82.7	81.6	79.2	79.2	78.7	79.7	81.9	82.7	83.5
		MCDB	87.6	88.3	88.8	88.7	88.2	87.5	87.4	87.6	89.6	90.1	90.4	88.9
	2%	WB	81.6	81.9	81.7	81.1	79.9	77.8	77.3	77.0	78.6	80.3	81.7	82.5
		MCDB	86.6	87.1	87.4	88.0	87.0	86.3	85.9	86.9	88.4	89.4	89.4	88.0
	5%	WB	80.7	81.0	80.8	80.1	78.6	76.8	76.0	75.6	77.6	79.3	80.9	81.6
		MCDB	86.0	86.1	86.4	87.2	86.4	85.3	84.2	85.5	87.2	88.5	88.6	87.0
	10%	WB	80.0	80.1	80.0	79.2	77.5	75.9	74.9	74.5	76.7	78.4	80.1	80.8
		MCDB	84.9	84.9	85.3	86.1	85.3	84.2	82.9	84.0	86.0	87.5	87.7	86.0
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.6	12.3	14.9	14.3	14.1	15.0	16.4	18.3	17.6	15.4	11.2
		MCDBR	12.6	13.1	14.8	16.7	15.4	15.4	16.2	17.7	19.7	19.3	17.0	13.3
		MCWBR	5.8	6.3	6.9	6.0	5.7	5.7	6.3	7.3	7.3	6.9	6.1	6.1
	5% WB	MCDBR	11.4	11.7	13.0	14.4	14.3	13.9	14.5	16.3	18.0	17.4	15.4	12.0
		MCWBR	6.0	6.4	6.9	7.0	6.5	5.9	6.7	7.4	8.4	8.5	7.6	6.4
Clear-Sky Solar Irradiance	taub		0.422	0.414	0.403	0.389	0.400	0.398	0.382	0.382	0.414	0.439	0.441	0.426
	taud		2.467	2.486	2.512	2.549	2.507	2.491	2.521	2.499	2.399	2.335	2.359	2.438
	Ebn at Noon		292	293	291	286	273	268	276	284	283	282	285	290
	Edh at Noon		38	37	35	32	32	32	31	34	39	43	42	39
All-Sky Solar Radiation	RadAvg		1751	1821	1818	1866	1711	1584	1695	1956	2166	2234	2172	1846
	RadStd		205	207	184	161	100	82	46	43	67	85	118	146

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page