

TERNATE BABULLAH, Indonesia

WMO: 974300

Lat: 0.8293N

Lon: 127.3814E

Elev: 75

StdP: 14.66

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	73.2	73.9	66.3	97.2	81.9	67.9	102.8	81.2	20.8	82.3	18.1	83.2	2.8	250	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.9	89.9	78.4	89.1	78.3	88.4	78.2	80.9	86.9	80.3	86.3	79.9	86.0	9.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.4	85.0	78.4	147.9	84.4	78.1	146.4	84.1	44.6	87.2	44.0	86.8	43.5	86.3	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.9	15.2	13.1	70.2	93.2	2.4	3.3	68.5	95.5	67.1	97.4	65.7	99.3	64.0	101.7		
(5)			67.2	84.5	2.3	2.3	65.5	86.1	64.2	87.5	62.8	88.8	61.2	90.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	81.4	81.3	81.8	81.7	81.8	81.2	81.0	81.3	81.1	81.6	81.4	81.5	
	DBStd	1.54	1.38	1.44	1.64	1.52	1.47	1.62	1.75	1.82	1.39	1.33	1.28	1.45	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11474	973	876	986	952	986	936	962	971	934	978	943	977	
	CDD65	5999	508	456	521	502	521	486	497	506	484	513	493	512	
	CDH74	62151	5217	4677	5495	5312	5532	4922	5021	5174	4915	5386	5129	5371	
	CDH80	19107	1408	1312	1707	1677	1829	1510	1482	1569	1539	1823	1647	1604	
Wind	WSAvg	5.0	6.4	6.1	6.1	4.8	4.0	4.2	4.9	5.2	4.8	4.4	4.4	5.2	
Precipitation	PrecAvg	95.5	9.3	6.9	7.4	8.5	10.5	9.0	6.6	5.0	4.7	6.7	7.5	10.1	
	PrecMax	146.2	20.6	17.2	15.6	17.4	21.0	15.5	16.3	12.2	15.9	24.9	21.4	24.4	
	PrecMin	53.7	2.4	0.2	0.6	2.2	3.5	2.9	1.4	1.0	1.0	0.4	0.0	0.4	
	PrecStd	25.2	4.6	4.3	3.9	3.6	3.3	3.3	3.7	3.6	3.3	5.9	5.1	6.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.0	89.2	90.1	90.0	90.2	89.8	89.5	90.1	89.6	90.5	89.8	89.5	
		MCWB	79.6	78.7	79.3	79.8	79.2	78.5	76.8	76.7	76.7	78.3	78.2	79.4	
	2%	DB	87.5	87.7	88.7	88.6	89.0	88.4	88.1	88.8	88.3	88.9	88.5	88.2	
		MCWB	78.9	78.4	78.7	79.3	79.0	78.2	76.9	76.6	77.0	78.0	78.4	79.3	
	5%	DB	86.5	86.8	87.6	87.6	88.0	87.4	87.1	87.5	87.4	87.9	87.6	87.2	
		MCWB	78.6	78.2	78.4	79.0	79.0	78.1	76.9	76.6	77.2	78.1	78.5	79.1	
	10%	DB	85.5	85.8	86.6	86.6	87.0	86.3	86.0	86.3	86.4	86.9	86.6	86.2	
		MCWB	78.4	78.0	78.2	78.8	78.9	78.0	76.9	76.5	77.2	78.0	78.6	78.9	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	80.5	80.9	81.0	81.2	80.8	80.0	79.5	79.8	80.6	80.9	81.5
			MCDB	86.9	86.9	87.3	87.4	87.3	86.9	86.6	85.9	85.8	86.7	86.5	86.5
2%		WB	79.9	79.4	79.9	80.3	80.4	79.9	79.1	78.8	79.0	79.8	80.0	80.3	
		MCDB	85.6	85.5	86.3	86.4	86.7	86.0	85.5	85.6	85.5	86.2	85.9	86.0	
5%		WB	79.2	79.0	79.2	79.8	79.9	79.2	78.4	78.2	78.4	79.2	79.5	79.8	
		MCDB	84.8	84.9	85.5	85.9	86.0	85.3	84.6	84.8	84.9	85.7	85.5	85.4	
10%		WB	78.8	78.4	78.8	79.2	79.4	78.7	77.9	77.6	78.0	78.7	79.0	79.2	
		MCDB	84.3	84.1	85.0	85.1	85.5	84.8	84.0	84.1	84.4	85.4	85.1	84.8	
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.9	10.3	10.4	10.9	10.5	10.2	10.3	11.2	11.5	11.0	9.8	
		MCDBR	10.4	11.0	11.3	11.5	12.0	11.9	11.3	11.6	12.4	12.6	12.3	11.2	
		MCWBR	4.7	4.7	4.8	4.9	5.3	5.2	4.9	4.7	5.3	5.6	5.4	5.1	
	5% WB	MCDBR	9.6	10.1	10.6	10.9	11.2	11.0	10.6	10.8	11.4	11.7	10.9	10.2	
		MCWBR	4.8	4.8	4.9	5.2	5.4	5.4	5.1	5.1	5.4	5.7	5.4	5.1	
Clear-Sky Solar Irradiance	taub	0.422	0.429	0.427	0.427	0.414	0.408	0.408	0.416	0.427	0.466	0.439	0.432		
	taud	2.480	2.448	2.453	2.448	2.502	2.530	2.537	2.497	2.452	2.319	2.405	2.442		
	Ebn at Noon	288	287	285	279	275	273	275	279	281	272	280	283		
	Edh at Noon	36	38	38	37	34	32	32	35	37	43	39	37		
All-Sky Solar Radiation	RadAvg	1658	1759	1819	1779	1705	1530	1593	1694	1806	1861	1743	1674		
	RadStd	85	145	165	127	101	107	175	192	176	138	116	126		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page