

LABUHA OESMAN SADIK, Indonesia

WMO: 974600

Lat: 0.6379S

Lon: 127.5010E

Elev: 98

StdP: 14.64

Time Zone: 9.00 (E09)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	70.5	71.6	66.9	99.3	72.3	68.3	104.4	74.0	12.5	84.1	11.2	83.9	0.3	N/A	0.277

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.5	90.6	78.2	89.8	78.3	89.1	78.3	80.2	86.8	79.9	86.5	79.5	86.2	6.4	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	148.8	83.9	78.1	146.4	83.6	77.5	143.7	83.3	44.0	87.2	43.6	86.8	43.2	86.6	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	9.8	8.2	66.6	93.4	4.4	3.0	63.5	95.5	60.9	97.3	58.5	98.9	55.3	101.1		
(5)			66.0	83.3	1.9	1.7	64.6	84.5	63.5	85.5	62.4	86.4	61.0	87.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.4	81.1	80.8	81.1	81.2	80.9	79.9	78.9	78.8	79.4	80.5	81.1	81.4
	DBStd	1.58	1.31	1.32	1.31	1.20	1.20	1.42	1.35	1.49	1.36	1.18	1.07	1.37
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11102	965	863	963	937	958	897	897	893	881	944	932	972
	CDD65	5627	500	443	498	487	493	447	432	428	431	479	482	507
	CDH74	51991	4779	4152	4777	4650	4732	3893	3451	3482	3777	4582	4727	4989
	CDH80	16927	1619	1418	1680	1577	1578	1096	858	873	1094	1606	1746	1782
Wind	WSAvg	2.1	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.3	2.5	2.6	2.0	2.0
Precipitation	PrecAvg	77.3	8.5	8.3	7.8	7.2	6.7	5.2	5.1	4.6	4.2	5.2	6.6	7.9
	PrecMax	139.4	14.6	16.6	12.6	11.9	10.7	12.0	13.1	12.0	11.5	13.6	14.6	14.8
	PrecMin	45.8	2.9	2.8	1.7	2.0	0.1	0.1	0.0	0.0	0.0	0.0	1.3	0.0
	PrecStd	27.2	3.6	4.0	3.1	2.7	3.3	4.0	4.4	4.4	3.9	4.3	3.7	3.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.6	90.6	90.8	91.0	90.0	89.1	88.0	88.1	89.0	90.3	90.9	91.6
		MCWB	77.8	78.2	77.9	78.4	78.7	78.7	77.5	77.7	77.8	77.6	78.4	78.2
	2%	DB	89.2	89.4	89.8	89.6	89.0	87.9	86.6	86.7	87.7	89.0	89.8	90.2
		MCWB	78.2	77.9	77.9	78.8	78.7	78.7	77.5	77.4	77.5	78.0	78.1	78.4
	5%	DB	88.4	88.4	88.8	88.6	88.2	86.8	85.6	85.6	86.4	88.0	88.9	89.1
		MCWB	78.2	77.9	78.0	78.7	78.8	78.5	77.4	77.1	77.4	78.0	78.2	78.5
	10%	DB	87.4	87.3	87.6	87.4	87.1	85.6	84.4	84.5	85.4	87.0	87.7	87.8
		MCWB	78.1	77.8	78.0	78.6	78.7	78.3	77.2	77.0	77.2	77.9	78.4	78.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.0	79.9	80.1	80.5	80.7	80.4	79.2	79.2	79.4	80.3	81.0	80.8
		MCDB	86.4	87.3	87.2	87.3	86.3	86.5	85.5	84.9	85.8	86.9	87.7	87.5
	2%	WB	79.3	79.1	79.3	79.8	80.0	79.7	78.7	78.4	78.9	79.6	79.9	79.9
		MCDB	86.1	86.4	86.5	86.6	85.9	85.7	84.5	84.2	85.3	86.3	86.8	86.9
	5%	WB	78.9	78.7	78.9	79.2	79.6	79.1	78.2	78.0	78.3	79.0	79.2	79.2
		MCDB	86.0	85.8	86.1	86.0	85.6	85.0	83.6	83.6	84.4	85.7	86.2	86.3
	10%	WB	78.4	78.2	78.3	78.9	79.1	78.6	77.6	77.4	77.8	78.3	78.7	78.8
		MCDB	85.3	85.0	85.2	85.6	85.2	84.3	82.8	82.8	83.7	85.0	85.7	85.9
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.3	13.6	13.1	12.9	11.6	11.8	11.6	12.8	14.3	14.4	13.5
		MCDBR	14.5	14.9	15.5	14.8	14.6	13.6	13.7	13.2	14.3	15.6	15.8	15.4
		MCWBR	5.9	6.0	6.3	6.2	6.6	6.4	6.5	6.2	6.8	7.2	6.9	6.3
	5% WB	MCDBR	13.3	13.6	14.1	13.5	13.1	12.3	12.1	11.9	12.9	14.2	14.6	13.9
		MCWBR	5.9	6.0	6.2	6.1	6.4	6.3	6.2	6.2	6.5	7.0	7.0	6.4
Clear-Sky Solar Irradiance	taub	0.425	0.433	0.427	0.415	0.404	0.406	0.409	0.416	0.426	0.458	0.434	0.430	
	taud	2.465	2.431	2.450	2.486	2.537	2.543	2.537	2.500	2.459	2.341	2.416	2.439	
	Ebn at Noon	288	286	285	282	278	273	274	278	281	276	283	285	
	Edh at Noon	37	39	38	36	32	32	32	34	37	42	38	37	
All-Sky Solar Radiation	RadAvg	1669	1744	1780	1727	1682	1486	1520	1636	1742	1843	1756	1669	
	RadStd	92	131	140	89	113	129	204	231	197	132	110	127	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page