

SORONG DEO, Indonesia

WMO: 975020

Lat: 0.8911S

Lon: 131.2858E

Elev: 10

StdP: 14.69

Time Zone: 9.00 (E09)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	73.1	73.7	70.7	113.2	79.3	71.6	116.6	79.0	17.0	82.4	15.3	83.4	2.3	100	0.319

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	11.2	90.2	79.4	89.6	79.4	88.9	79.3	81.4	87.4	80.9	87.0	80.6	86.6	8.4	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.7	154.0	85.2	79.2	151.3	84.6	78.8	149.7	84.2	45.1	87.6	44.6	87.4	44.2	87.0	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.3	11.1	DB	70.3	91.6	4.0	0.5	67.4	92.0	65.0	92.3	62.8	92.5	59.9	92.9	(4)
(5)			WB	69.5	83.3	3.8	1.0	66.7	84.0	64.5	84.6	62.4	85.1	59.6	85.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	81.7	81.9	81.9	81.9	81.8	80.6	79.9	80.0	80.7	81.6	81.8	82.0
	DBStd	1.65	1.41	1.68	1.57	1.45	1.35	1.54	1.61	1.45	1.46	1.28	1.19	1.47
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11428	984	892	989	956	986	919	927	929	920	980	955	991
	CDD65	5953	519	472	524	506	521	469	462	464	470	515	505	526
	CDH74	58225	5410	4976	5537	5241	5280	4207	3835	3793	4213	5070	5148	5515
CDH80	17832	1770	1630	1845	1695	1656	1100	893	893	1142	1652	1690	1866	
Wind	WSAvg	4.1	3.9	4.6	4.0	3.7	3.6	3.9	4.6	5.0	4.7	4.2	3.7	3.7
Precipitation	PrecAvg	126.7	8.3	7.4	10.0	8.9	12.2	13.9	14.5	11.3	10.4	7.5	8.2	8.8
	PrecMax	209.0	14.4	12.2	22.7	14.4	25.9	25.8	40.8	33.7	19.0	17.4	14.1	16.5
	PrecMin	58.1	2.6	2.0	3.1	3.5	3.2	0.8	0.7	0.3	0.6	0.1	1.1	2.0
	PrecStd	35.3	3.4	3.0	4.8	3.2	6.3	5.6	8.9	9.0	6.0	5.4	3.5	3.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.0	90.1	90.5	90.6	90.4	89.1	88.1	88.8	89.5	90.8	90.3	90.7
		MCWB	78.9	78.8	78.5	79.9	79.7	79.9	78.9	79.1	79.3	79.6	79.7	80.0
	2%	DB	89.0	89.0	89.4	89.4	89.1	87.8	87.0	87.2	88.1	89.5	89.1	89.4
		MCWB	79.0	78.8	78.5	79.6	80.0	79.4	78.6	78.8	79.1	79.4	79.6	79.6
	5%	DB	88.0	88.1	88.4	88.2	88.0	86.7	85.9	86.0	86.9	88.3	88.1	88.4
		MCWB	78.8	78.6	78.7	79.6	79.9	79.2	78.3	78.4	78.9	79.2	79.5	79.5
	10%	DB	87.0	87.0	87.1	87.1	86.9	85.5	84.6	84.7	85.7	87.1	87.1	87.3
		MCWB	78.7	78.4	78.7	79.4	79.7	78.9	78.0	78.0	78.7	79.0	79.4	79.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.9	80.9	80.9	81.7	81.8	81.3	80.6	80.6	81.0	81.7	81.5	81.8
		MCDB	87.1	87.7	86.8	87.8	87.6	86.9	86.4	86.4	86.6	88.3	87.6	88.1
	2%	WB	80.2	80.0	80.1	80.8	81.0	80.5	79.6	79.7	80.1	80.7	80.8	80.9
		MCDB	86.2	86.4	86.1	87.0	86.7	85.9	84.9	85.4	85.7	87.2	87.0	87.2
	5%	WB	79.7	79.4	79.6	80.3	80.6	79.9	79.0	79.0	79.6	80.0	80.3	80.3
		MCDB	85.7	85.6	85.6	86.2	86.3	85.0	84.0	84.6	85.0	86.2	86.3	86.5
	10%	WB	79.2	79.0	79.1	79.8	80.0	79.3	78.4	78.3	79.0	79.5	79.8	79.8
		MCDB	85.0	85.0	85.0	85.3	85.2	84.0	82.9	83.3	84.2	85.4	85.5	85.7
Mean Daily Temperature Range	5% DB	MDBR	11.1	10.8	11.0	11.1	11.0	10.3	10.1	10.3	10.7	11.9	11.6	11.2
		MCDBR	12.3	11.9	12.2	12.4	12.3	11.9	11.5	11.8	12.3	13.6	12.9	12.7
		MCWBR	4.4	4.0	4.0	4.6	5.0	4.9	4.5	4.7	5.0	5.3	5.0	4.7
	5% WB	MCDBR	11.7	11.1	11.2	11.6	11.1	10.8	10.4	10.9	11.2	12.3	11.9	11.7
		MCWBR	4.6	4.4	4.3	4.8	4.9	4.9	4.6	4.9	5.0	5.4	5.0	5.0
Clear-Sky Solar Irradiance	taub	0.404	0.404	0.404	0.399	0.398	0.408	0.412	0.422	0.427	0.449	0.421	0.410	
	taud	2.522	2.515	2.518	2.530	2.547	2.531	2.516	2.475	2.457	2.364	2.456	2.499	
	Ebn at Noon	294	295	292	287	279	272	273	276	281	278	287	291	
	Edh at Noon	35	36	35	34	32	32	33	35	37	41	37	35	
All-Sky Solar Radiation	RadAvg	1651	1709	1761	1702	1663	1492	1513	1628	1682	1777	1694	1620	
	RadStd	60	105	102	84	70	102	121	136	118	130	107	113	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page