

FAK-FAK TOREA, Indonesia

WMO: 976300

Lat: 2.9194S

Lon: 132.2650E

Elev: 130

StdP: 99.77

Time Zone: 9.00 (E09)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.7	22.2	19.8	14.8	23.5	20.6	15.5	23.9	8.7	25.0	8.0	25.1	2.6	20	0.292

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	6.3	31.5	25.5	30.9	25.7	30.4	25.7	26.7	29.8	26.5	29.5	26.2	29.2	3.8	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.4	28.5	25.6	21.1	28.4	25.2	20.7	28.2	84.5	30.1	83.4	29.7	82.4	29.5	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	5.5	4.8	19.9	33.5	1.0	1.8	19.2	34.8	18.6	35.8	18.0	36.9	17.2	38.2		
(5)			19.2	28.0	1.1	0.9	18.4	28.7	17.8	29.2	17.1	29.7	16.3	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	26.8	26.6	26.5	26.4	26.2	25.6	24.9	24.8	25.3	26.0	26.6	26.8	(6)
(7)		DBStd	1.04	0.84	0.81	0.80	0.65	0.69	0.80	0.78	0.82	0.85	0.70	0.63	0.80	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5856	520	466	513	492	502	467	463	458	459	497	497	521	(10)
(11)		CDD18.3	2814	262	233	254	242	244	217	204	200	209	238	247	263	(11)
(12)		CDH23.3	22453	2361	2048	2144	2072	2028	1529	1186	1107	1407	1952	2212	2407	(12)
(13)	CDH26.7	5039	707	594	576	489	419	207	88	66	162	391	613	727	(13)	
(14)	Wind	WSAvg	2.3	2.4	2.4	2.3	2.2	2.1	2.2	2.2	2.4	2.3	2.4	2.3	2.3	(14)
(15)	Precipitation	PrecAvg	3477	248	218	273	309	328	371	392	307	290	249	216	220	(15)
(16)		PrecMax	4927	575	418	509	813	692	1156	974	709	641	578	419	371	(16)
(17)		PrecMin	542	65	17	22	29	28	34	20	1	8	24	15	38	(17)
(18)		PrecStd	993	109	103	109	173	160	255	223	183	188	138	106	95	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.2	32.2	31.7	30.8	30.1	29.6	28.7	28.7	29.3	30.2	31.0	32.2	(19)
MCWB			25.3	24.5	25.5	25.8	25.8	25.5	25.1	25.0	25.4	25.6	26.1	25.4	(20)	
2%		DB	31.3	31.1	30.7	30.1	29.7	28.9	28.2	28.0	28.7	29.7	30.5	31.3	(21)	
		MCWB	25.5	25.4	25.6	25.8	25.8	25.3	24.8	24.8	25.2	25.5	25.9	25.8	(22)	
5%		DB	30.6	30.4	30.1	29.7	29.2	28.5	27.7	27.5	28.2	29.2	30.0	30.6	(23)	
		MCWB	25.5	25.5	25.6	25.7	25.6	25.2	24.6	24.6	25.0	25.4	25.7	25.8	(24)	
10%		DB	30.0	29.7	29.4	29.2	28.8	28.0	27.1	26.9	27.7	28.7	29.5	29.9	(25)	
		MCWB	25.5	25.3	25.5	25.6	25.5	25.0	24.4	24.4	24.8	25.2	25.6	25.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.1	26.9	26.7	26.6	26.7	26.2	25.7	26.0	26.2	26.6	26.9	27.0	(27)
MCDWB			30.1	30.3	29.9	29.3	29.0	28.3	27.7	27.2	28.3	29.2	29.9	30.6	(28)	
2%		WB	26.5	26.2	26.2	26.2	26.3	25.7	25.3	25.4	25.7	26.1	26.4	26.6	(29)	
		MCDWB	29.9	29.6	29.5	29.0	28.7	27.9	27.2	26.9	27.9	28.8	29.5	30.0	(30)	
5%		WB	26.1	25.9	26.0	26.0	26.1	25.5	25.0	25.0	25.3	25.7	26.1	26.2	(31)	
		MCDWB	29.6	29.3	29.3	28.9	28.5	27.7	27.0	26.8	27.5	28.3	29.2	29.6	(32)	
10%		WB	25.7	25.6	25.6	25.7	25.7	25.2	24.7	24.7	25.0	25.4	25.7	25.9	(33)	
		MCDWB	29.1	28.9	28.8	28.5	28.1	27.3	26.5	26.3	27.1	28.0	28.8	29.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.4	6.4	6.1	5.5	5.3	4.6	4.2	4.1	4.6	5.5	6.1	6.3	(35)
MCDBR			7.4	7.3	7.0	6.3	5.8	5.4	5.0	4.8	5.3	6.1	6.8	7.4	(36)	
MCWBR			3.3	3.3	3.3	3.1	3.0	2.7	2.6	2.6	2.8	3.0	3.4	3.5	(37)	
5% WB		MCDBR	6.7	6.5	6.3	5.7	5.5	5.1	4.6	4.3	4.9	5.6	6.3	6.6	(38)	
		MCWBR	3.6	3.5	3.3	3.1	3.1	2.7	2.6	2.6	2.8	3.0	3.3	3.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.414	0.417	0.413	0.404	0.407	0.416	0.416	0.425	0.435	0.462	0.441	0.425	(40)	
taud		2.502	2.484	2.498	2.534	2.528	2.513	2.509	2.474	2.440	2.328	2.402	2.460	(41)		
Ebn at Noon		921	918	912	896	869	847	853	866	878	866	888	906	(42)		
Edh at Noon		113	116	113	106	102	102	103	111	118	134	124	117	(43)		
(44)	All-Sky Solar Radiation	RadAvg	5.00	5.27	5.18	5.09	5.04	4.57	4.58	4.91	5.25	5.55	5.41	4.98	(44)	
(45)		RadStd	0.29	0.33	0.28	0.25	0.25	0.32	0.33	0.37	0.34	0.40	0.28	0.33	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page