

JAYAPURA SENTANI, Indonesia

WMO: 976900

Lat: 2.5760S

Lon: 140.5183E

Elev: 325

StdP: 14.52

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	72.2	73.0	68.0	104.3	81.6	69.4	109.3	80.6	16.5	84.9	14.3	85.4	0.7	310	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	13.8	93.0	78.6	91.8	78.5	91.3	78.5	81.4	89.0	80.7	88.5	80.1	87.7	9.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	153.3	86.2	78.6	150.1	85.4	78.0	147.4	84.6	45.4	89.4	44.7	88.9	44.1	88.1	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	17.3	14.5	70.6	95.1	0.5	1.2	70.2	95.9	69.9	96.7	69.6	97.3	69.2	98.2		
(5)			67.1	83.5	2.5	2.2	65.3	85.0	63.9	86.3	62.4	87.5	60.6	89.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	82.2	81.8	81.9	82.1	82.3	81.5	81.0	81.4	81.7	82.5	82.5	82.6	
	DBStd	1.82	1.71	1.86	1.88	1.67	1.60	1.69	1.78	1.85	1.82	1.77	1.72	1.78	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11666	998	890	989	964	1002	946	960	975	952	1006	974	1010	
	CDD65	6191	533	470	524	514	537	496	495	510	502	541	524	545	
	CDH74	60509	5276	4551	5073	5070	5378	4757	4552	4833	4817	5474	5222	5506	
	CDH80	21333	1855	1525	1692	1746	1910	1618	1487	1707	1752	2085	1936	2020	
Wind	WSAvg	4.5	6.0	6.3	6.5	4.3	3.6	3.5	3.5	3.7	3.7	3.9	3.9	4.9	
Precipitation	PrecAvg	69.7	8.2	7.2	9.2	6.2	4.7	3.9	3.9	4.1	3.5	4.4	5.6	8.2	
	PrecMax	92.3	25.0	15.0	16.3	13.3	15.2	9.9	11.7	9.8	7.0	9.3	12.8	16.4	
	PrecMin	48.4	1.7	1.9	3.2	0.6	1.6	0.9	0.7	0.6	1.1	0.3	1.6	1.9	
	PrecStd	12.9	5.0	3.0	3.0	3.2	3.0	2.3	2.6	2.7	1.7	2.2	3.0	3.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.1	92.4	92.7	92.8	92.2	91.7	91.8	91.9	93.0	93.5	93.4	93.4	
		MCWB	79.0	78.6	78.3	78.8	78.9	78.8	78.1	77.9	77.8	78.2	78.9	79.0	
	2%	DB	91.4	91.1	91.0	91.0	90.9	90.4	90.0	90.8	91.4	92.0	91.8	91.7	
		MCWB	78.5	78.2	77.9	78.9	79.0	78.7	78.0	78.0	78.2	78.4	78.9	78.7	
	5%	DB	89.9	89.6	89.6	89.6	89.8	89.3	88.8	89.5	89.9	90.9	90.5	90.6	
		MCWB	78.2	77.7	77.9	78.7	79.0	78.5	77.8	78.0	77.9	78.4	78.7	78.6	
	10%	DB	88.3	87.9	87.9	88.0	88.3	87.8	87.4	88.0	88.4	89.3	88.8	89.2	
		MCWB	77.9	77.4	77.7	78.6	78.8	78.2	77.6	77.5	77.7	78.1	78.5	78.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.0	81.1	80.7	81.7	82.1	81.7	80.8	81.0	80.9	81.2	81.8	81.3
			MCDB	89.4	88.6	88.6	88.4	88.8	88.8	88.5	88.8	89.4	89.7	89.5	89.8
2%		WB	80.0	79.9	79.7	80.6	80.9	80.1	79.6	79.8	79.7	80.0	80.5	80.1	
		MCDB	88.2	87.4	87.4	87.6	87.8	87.1	86.9	87.6	88.0	88.7	88.3	88.6	
5%		WB	79.2	79.0	78.9	79.8	80.0	79.2	78.8	78.9	78.9	79.2	79.7	79.4	
		MCDB	87.0	86.3	86.3	86.6	86.9	86.3	85.7	86.6	86.9	87.5	87.3	87.5	
10%		WB	78.5	78.3	78.2	79.0	79.2	78.6	78.1	78.1	78.1	78.6	78.9	78.8	
		MCDB	85.9	85.0	85.1	85.8	86.0	85.4	84.7	85.3	85.7	86.5	86.5	86.7	
Mean Daily Temperature Range	5% DB	MDBR	13.4	12.8	12.8	13.1	13.3	13.1	13.0	13.9	14.2	14.5	14.1	13.8	
		MCDBR	15.8	15.2	15.3	14.9	15.0	15.2	15.6	15.8	16.3	16.8	16.1	16.0	
		MCWBR	5.9	5.5	5.5	5.8	6.1	6.2	6.6	6.5	6.4	6.7	6.2	6.0	
	5% WB	MCDBR	14.4	13.7	13.8	14.0	14.0	13.7	13.9	14.9	14.9	15.2	14.6	14.6	
		MCWBR	5.9	5.8	5.6	6.2	6.4	6.2	6.4	6.6	6.3	6.5	6.3	6.0	
Clear-Sky Solar Irradiance	taub	0.395	0.399	0.398	0.397	0.400	0.405	0.409	0.417	0.417	0.432	0.420	0.410		
	taud	2.538	2.516	2.521	2.521	2.503	2.489	2.477	2.449	2.447	2.394	2.444	2.479		
	Ebn at Noon	298	297	294	287	278	272	273	277	284	283	288	292		
	Edh at Noon	35	36	35	34	33	33	34	36	37	40	38	36		
All-Sky Solar Radiation	RadAvg	1526	1506	1534	1572	1507	1433	1400	1561	1579	1660	1537	1494		
	RadStd	144	120	111	97	70	90	108	80	103	81	85	124		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page