

JAYAPURA SENTANI, Indonesia

WMO: 976900

Lat: 2.5760S

Lon: 140.5183E

Elev: 99

StdP: 100.14

Time Zone: 9.00 (E09)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.4	22.8	20.0	14.9	27.5	20.8	15.6	27.0	7.4	29.4	6.4	29.7	0.3	310	0.320

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	7.7	33.9	25.9	33.2	25.8	32.9	25.8	27.5	31.6	27.1	31.4	26.7	31.0	4.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.9	30.1	25.9	21.4	29.7	25.6	21.1	29.2	87.8	31.9	86.2	31.6	84.7	31.1	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	7.8	6.5	DB	21.4	35.0	0.3	0.7	21.2	35.5	21.1	35.9	20.9	36.3	20.7	36.8	(4)
(5)			WB	19.5	28.6	1.4	1.2	18.5	29.5	17.7	30.2	16.9	30.8	15.9	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.9	27.7	27.7	27.9	28.0	27.5	27.2	27.5	27.6	28.0	28.1	(6)	
(7)		DBStd	1.01	0.95	1.03	1.04	0.93	0.89	0.94	0.99	1.03	1.01	0.98	0.96	0.99	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6481	554	494	549	536	557	526	533	542	529	559	541	561	(10)
(11)		CDD18.3	3439	296	261	291	286	298	276	275	283	279	301	291	303	(11)
(12)		CDH23.3	33616	2931	2528	2818	2817	2988	2643	2529	2685	2676	3041	2901	3059	(12)
(13)		CDH26.7	11852	1031	847	940	970	1061	899	826	948	973	1158	1076	1122	(13)
(14)	Wind	WSAvg	2.0	2.7	2.8	2.9	1.9	1.6	1.5	1.5	1.7	1.7	1.8	2.2	(14)	
(15)	Precipitation	PrecAvg	1770	209	183	234	157	119	100	98	104	90	113	141	208	(15)
(16)		PrecMax	2345	636	380	413	337	386	252	297	250	178	235	326	416	(16)
(17)		PrecMin	1230	44	49	81	16	41	22	17	15	28	8	40	47	(17)
(18)		PrecStd	328	126	77	77	82	75	59	65	68	43	56	76	89	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.9	33.6	33.7	33.8	33.4	33.2	33.2	33.3	33.9	34.2	34.1	34.1	(19)
MCWB			26.1	25.9	25.7	26.0	26.0	26.0	25.6	25.5	25.4	25.7	26.1	26.1	26.1	(20)
2%		DB	33.0	32.8	32.8	32.8	32.7	32.5	32.2	32.7	33.0	33.3	33.2	33.2	33.2	(21)
		MCWB	25.9	25.7	25.5	26.1	26.1	26.0	25.6	25.5	25.6	25.8	26.0	26.0	26.0	(22)
5%		DB	32.2	32.0	32.0	32.0	32.1	31.8	31.5	31.9	32.2	32.7	32.5	32.6	32.6	(23)
		MCWB	25.7	25.4	25.5	26.0	26.1	25.9	25.5	25.5	25.5	25.8	26.0	25.9	25.9	(24)
10%		DB	31.3	31.1	31.0	31.1	31.3	31.0	30.8	31.1	31.4	31.8	31.6	31.8	31.8	(25)
		MCWB	25.5	25.2	25.4	25.9	26.0	25.6	25.3	25.3	25.4	25.6	25.8	25.7	25.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.2	27.3	27.1	27.6	27.8	27.6	27.1	27.2	27.2	27.4	27.7	27.4	(27)
MCDWB			31.9	31.4	31.5	31.3	31.6	31.6	31.4	31.5	31.9	32.1	32.0	32.1	32.1	(28)
2%		WB	26.7	26.6	26.5	27.0	27.2	26.7	26.5	26.6	26.5	26.7	27.0	26.7	26.7	(29)
		MCDWB	31.2	30.8	30.8	30.9	31.0	30.6	30.5	30.9	31.1	31.5	31.3	31.4	31.4	(30)
5%		WB	26.2	26.1	26.1	26.5	26.7	26.2	26.0	26.1	26.0	26.2	26.5	26.3	26.3	(31)
		MCDWB	30.6	30.1	30.2	30.4	30.5	30.1	29.9	30.3	30.5	30.8	30.7	30.8	30.8	(32)
10%		WB	25.9	25.7	25.7	26.1	26.2	25.9	25.6	25.6	25.6	25.9	26.1	26.0	26.0	(33)
		MCDWB	29.9	29.5	29.5	29.9	30.0	29.7	29.3	29.6	29.8	30.3	30.3	30.4	30.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.4	7.1	7.1	7.3	7.4	7.3	7.2	7.7	7.9	8.1	7.8	7.7	(35)
MCDBR			8.8	8.5	8.5	8.3	8.3	8.5	8.7	8.8	9.0	9.3	9.0	8.9	8.9	(36)
MCWBR			3.3	3.1	3.1	3.2	3.4	3.5	3.7	3.6	3.5	3.7	3.4	3.3	3.3	(37)
5% WB		MCDBR	8.0	7.6	7.7	7.8	7.8	7.6	7.7	8.3	8.3	8.4	8.1	8.1	8.1	(38)
		MCWBR	3.3	3.2	3.1	3.5	3.6	3.5	3.6	3.7	3.5	3.6	3.5	3.3	3.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.395	0.399	0.398	0.397	0.400	0.405	0.409	0.417	0.417	0.432	0.420	0.410	(40)	
taud		2.538	2.516	2.521	2.521	2.503	2.489	2.477	2.449	2.447	2.394	2.444	2.479	2.479	(41)	
Ebn at Noon		938	935	926	904	876	858	860	873	894	893	907	919	919	(42)	
Edh at Noon		109	112	111	107	105	104	107	114	117	125	119	114	114	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.81	4.75	4.84	4.96	4.75	4.52	4.41	4.92	4.98	5.23	4.84	4.71	(44)	
(45)		RadStd	0.45	0.38	0.35	0.31	0.22	0.28	0.34	0.25	0.33	0.25	0.27	0.39	0.39	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page